

	<b>1214 Church Street</b> <b>Nashville, TN 37246</b> <b>(615) 747-3970</b> www.nespower.com Attachments@nespower.com	 Overview Map	Design Date:	11/20/2017	Reviewed By:	C.Duncan	OK Poles				<input type="checkbox"/>				
			Design By:	C.Duncan	Revise By:		1								
			Drawn By:	M.Greenwell	City / Township:	Nashville					Pole Count				
			Application #:	17L-02233	County:	Davidson					New Attachments				
			Proposee Code:	City of Belle Meade Surveillance System 5	Line Dept:	WSC	ENG WO#:	318531	ENG WR#:	991351422	Overlash				
Operator shall not install Attachments without having received a License for each pole. This Cover Map shall not be considered a License to Attach.											Utility:			Other:	Total:
Communications cables shall be no closer than 40" from utility conductors at pole and 30" at midspan.											1	0	1		
All Companies must tag attachments with approved permanent identification markers.											1	0	1		
											0	0	0		
											0	0	0		
											0	0	0		

Drawing Title: E(P)PC = Existing (Proposed) Pole Clearance problem E (P)BC = Existing (Proposed) Between Clearance problem E(P)OL = Existing (Proposed) Pole Overload E(P)JH = Existing (Proposed) Attached to J-Hook E(P)TT = Existing (Proposed) Trim Trees  
 E(P)GC = Existing (Proposed) Ground Clearance problem E(P)NA = Existing (Proposed) Not Attached to pole E(P)GA = Existing (Proposed) Guy / Anchor problem PPA= Proposed Cable already Attached PCA = Proposed Cannot attach



**CONSTRUCTION NOTE:**  
 The installation of Y down guys is not authorized in any application without prior written approval from NES.

 <b>1214 Church Street</b> <b>Nashville, TN 37246</b> <b>(615) 747-3970</b> <a href="http://www.nespower.com">www.nespower.com</a> <a href="mailto:Attachments@nespower.com">Attachments@nespower.com</a>	<p style="text-align: center; font-size: 2em; font-weight: bold;">N ↑</p> <p style="text-align: center;">Sheet 1 of 1</p>	Design Date:	11/20/2017	Reviewed By:	C.Duncan	OK Poles				Utility: Other: Total:		
		Design By:	C.Duncan	Revise By:		1					1	0
		Drawn By:	M.Greenwell	City / Township:	Nashville							
		Application #:	17L-02233	County:	Davidson							
		Proposee Code:	City of Belle Meade Surveillance System 5	Line Dept:	WSC	ENG WO#:	318531	ENG WR#:	991351422			
Operator shall not install Attachments without having received a License for each pole. This Cover Map shall not be considered a License to Attach.										All Companies must tag attachments with approved permanent identification markers.		
Communications cables shall be no closer than 40" from utility conductors at pole and 30" at midspan.												
Drawing Title	E(P)PC = Existing (Proposed) Pole Clearance problem E (P)BC = Existing (Proposed) Between Clearance problem E(P)OL = Existing (Proposed) Pole Overload E(P)JH = Existing (Proposed) Attached to J-Hook E(P)TT = Existing (Proposed) Trim Trees											
	E(P)GC = Existing (Proposed) Ground Clearance problem E(P)NA = Existing (Proposed) Not Attached to pole E(P)GA = Existing (Proposed) Guy / Anchor problem PPA= Proposed Cable already Attached PCA = Proposed Cannot attach											