
	1214 Church Street Nashville, TN 37246 (615) 747-3970 www.nespower.com Attachments@nespower.com	 Overview Map	Design Date:	11/20/2017	Reviewed By:	C.Duncan	OK Poles				<table border="1"> <tr> <td>Utility:</td> <td>Other:</td> <td>Total:</td> </tr> <tr> <td>1</td> <td>0</td> <td>1</td> </tr> </table>			Utility:	Other:	Total:	1	0	1
			Utility:	Other:	Total:														
1	0	1																	
Design By:	C.Duncan	Revise By:		<table border="1"> <tr> <td>1</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table>				1							Pole Count	1	0	1	
1																			
Drawn By:	M.Greenwell	City / Township:	Nashville					New Attachments	1	0	1								
Application #:	17L-00223	County:	Davidson					Overlash	0	0	0								
Proposee Code:	City of Belle Meade Video Surveillance System 12	Line Dept:	WSC	ENG WO#:	318544	ENG WR#:	991351435	Rearrangement	0	0	0								
							Midspan Poles	0	0	0									
							Pole Replacements	0	0	0									



Operator shall not install Attachments without having received a License for each pole. This Cover Map shall not be considered a License to Attach.
 Communications cables shall be no closer than 40" from utility conductors at pole and 30" at midspan.
 All Companies must tag attachments with approved permanent identification markers.

Drawing Title: E(P)PC = Existing (Proposed) Pole Clearance problem E (P)BC = Existing (Proposed) Between Clearance problem E(P)OL = Existing (Proposed) Pole Overload E(P)JH = Existing (Proposed) Attached to J-Hook E(P)TT = Existing (Proposed) Trim Trees
 E(P)GC = Existing (Proposed) Ground Clearance problem E(P)NA = Existing (Proposed) Not Attached to pole E(P)GA = Existing (Proposed) Guy / Anchor problem PPA= Proposed Cable already Attached PCA = Proposed Cannot attach



11425077
1-1
City of Belle Meade:
- Attach top of cabinet at 20'0"
- Attach meter base on the SE side of pole
- Attach top of power riser at 24'3"

CONSTRUCTION NOTE:
The installation of Y down guys is not authorized in any application without prior written approval from NES.

 1214 Church Street Nashville, TN 37246 (615) 747-3970 www.nespower.com Attachments@nespower.com	 Sheet 1 of 1	Design Date:	11/20/2017	Reviewed By:	C.Duncan	OK Poles	<table border="1"> <tr><td><input checked="" type="checkbox"/></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></tr> </table>				<input checked="" type="checkbox"/>										Utility:	Other:	Total:
		<input checked="" type="checkbox"/>																					
Design By:	C.Duncan	Revise By:																					
Drawn By:	M.Greenwell	City / Township:	Nashville																				
Application #:	17L-00223	County:	Davidson																				
Proposee Code:	City of Belle Meade Video Surveillance System 12	Line Dept:	WSC	ENG WO#:	318544	ENG WR#:	991351435																
Operator shall not install Attachments without having received a License for each pole. This Cover Map shall not be considered a License to Attach.											All Companies must tag attachments with approved permanent identification markers.												
Communications cables shall be no closer than 40" from utility conductors at pole and 30" at midspan.																							
Drawing Title	E(P)PC = Existing (Proposed) Pole Clearance problem E (P)BC = Existing (Proposed) Between Clearance problem E(P)OL = Existing (Proposed) Pole Overload E(P)JH = Existing (Proposed) Attached to J-Hook E(P)TT = Existing (Proposed) Trim Trees																						
	E(P)GC = Existing (Proposed) Ground Clearance problem E(P)NA = Existing (Proposed) Not Attached to pole E(P)GA = Existing (Proposed) Guy / Anchor problem PPA= Proposed Cable already Attached PCA = Proposed Cannot attach																						