
	<b>1214 Church Street</b> <b>Nashville, TN 37246</b> <b>(615) 747-3970</b> www.nespower.com Attachments@nespower.com	 Overview Map	Design Date:	11/20/2017	Reviewed By:	C.Duncan	OK Poles				<table border="1"> <tr> <td>Utility:</td> <td>Other:</td> <td>Total:</td> </tr> <tr> <td>1</td> <td>0</td> <td>1</td> </tr> </table>			Utility:	Other:	Total:	1	0	1
			Utility:	Other:	Total:														
1	0	1																	
Design By:	C.Duncan	Revise By:		1															
Drawn By:	M.Greenwell	City / Township:	Nashville																
Application #:	17L-02225	County:	Davidson																
Proposee Code:	City of Belle Meade Surveillance System 14	Line Dept:	WSC				ENG WO#:	318543	ENG WR#:	991351434									



Operator shall not install Attachments without having received a License for each pole. This Cover Map shall not be considered a License to Attach.  
 Communications cables shall be no closer than 40" from utility conductors at pole and 30" at midspan.  
 All Companies must tag attachments with approved permanent identification markers.

Drawing Title: E(P)PC = Existing (Proposed) Pole Clearance problem E (P)BC = Existing (Proposed) Between Clearance problem E(P)OL = Existing (Proposed) Pole Overload E(P)JH = Existing (Proposed) Attached to J-Hook E(P)TT = Existing (Proposed) Trim Trees  
 E(P)GC = Existing (Proposed) Ground Clearance problem E(P)NA = Existing (Proposed) Not Attached to pole E(P)GA = Existing (Proposed) Guy / Anchor problem PPA= Proposed Cable already Attached PCA = Proposed Cannot attach



11445005  
1-1  
City of Belle Meade:  
- Attach top of cabinet at 18'8"  
- Attach meter base on the SW side of pole  
- Attach top of power riser at 29'4"

**CONSTRUCTION NOTE:**  
The installation of Y down guys is not authorized in any application without prior written approval from NES.

 <b>1214 Church Street</b> <b>Nashville, TN 37246</b> <b>(615) 747-3970</b> www.nespower.com Attachments@nespower.com	 Sheet 1 of 1	Design Date:	11/20/2017	Reviewed By:	C.Duncan	OK Poles	<input checked="" type="checkbox"/>	Utility:	Other:	Total:
		Design By:	C.Duncan	Revise By:		1				
		Drawn By:	M.Greenwell	City / Township:	Nashville					
		Application #:	17L-02225	County:	Davidson					
		Proposee Code:	City of Belle Meade Surveillance System 14	Line Dept:	WSC	ENG WO#:	318543	ENG WR#:	991351434	
Operator shall not install Attachments without having received a License for each pole. This Cover Map shall not be considered a License to Attach.								All Companies must tag attachments with approved permanent identification markers.		
Communications cables shall be no closer than 40" from utility conductors at pole and 30" at midspan.										
Drawing Title	E(P)PC = Existing (Proposed) Pole Clearance problem E (P)BC = Existing (Proposed) Between Clearance problem E(P)OL = Existing (Proposed) Pole Overload E(P)JH = Existing (Proposed) Attached to J-Hook E(P)TT = Existing (Proposed) Trim Trees									
	E(P)GC = Existing (Proposed) Ground Clearance problem E(P)NA = Existing (Proposed) Not Attached to pole E(P)GA = Existing (Proposed) Guy / Anchor problem PPA= Proposed Cable already Attached PCA = Proposed Cannot attach									