

CERTIFIED BID TAB
KING WELL REBUILD PROJECT #1512

| | QTY | Rowe Drilling | | | Professional Pump | | | AC Schultes | |
|--|--------|---------------|------------|--|-------------------|------------|--|-------------|------------|
| | | EACH | TOTAL | | EACH | TOTAL | | EACH | TOTAL |
| Televise Well | 1.00 | 2,000.00 | 2,000.00 | | 1,200.00 | 1,200.00 | | 1,500.00 | 1,500.00 |
| Clean and Airlift Debris | 1.00 | 19,320.00 | 19,320.00 | | 8,900.00 | 8,900.00 | | 14,250.00 | 14,250.00 |
| Design and Install 12" Stainless Steel, Schedule 20 Liner | 500.00 | 165.00 | 82,500.00 | | 160.00 | 80,000.00 | | 142.00 | 71,000.00 |
| Design and Install 5" Stainless Steel Liner, Schedule 40 | 210.00 | 86.00 | 18,060.00 | | 160.00 | 33,600.00 | | 80.00 | 16,800.00 |
| Design and Install 5" Stainless Steel wire wrap screen | 75.00 | 106.00 | 7,950.00 | | 160.00 | 12,000.00 | | 165.00 | 12,375.00 |
| Install Chlorinated, Washed, and Sized Gravel Pack from Total Depth to Surface | 1.00 | 22,420.00 | 22,420.00 | | 7,500.00 | 7,500.00 | | 13,650.00 | 13,650.00 |
| Install Test Pump and run 12 hour capacity test | 1.00 | 14,380.00 | 14,380.00 | | 8,500.00 | 8,500.00 | | 11,400.00 | 11,400.00 |
| Design and Purchase Line Shaft Turbine Pump (300 GPM @ 500 TDH, Intake Depth 400 feet) | 1.00 | 31,620.00 | 31,620.00 | | 28,450.00 | 28,450.00 | | 31,923.00 | 31,923.00 |
| Televise Well | 1.00 | 2,000.00 | 2,000.00 | | 1,200.00 | 1,200.00 | | 1,500.00 | 1,500.00 |
| Install Turbine Pump | 1.00 | 11,600.00 | 11,600.00 | | 4,000.00 | 4,000.00 | | 5,700.00 | 5,700.00 |
| Chlorinate Well and Sample | 1.00 | 7,050.00 | 7,050.00 | | 500.00 | 500.00 | | 2,000.00 | 2,000.00 |
| 6" Carbon Steel Column Pipe | 1.00 | 125.00 | 125.00 | | 28.00 | 28.00 | | 40.00 | 40.00 |
| Total Bid Price | | | 219,025.00 | | | 185,878.00 | | | 182,138.00 |
| Deduct for Using Existing Discharge Head on New Pump Assembly | | | -1,785.00 | | | 0.00 | | | -250.00 |

Signed:



Dated:

7-26-18