



## RFB 2207 HVAC Filter Replacement

### ADDENDUM 1 February 7<sup>th</sup>, 2022

This addendum is to post the following updates:

The Job Site Completion Time has been added as Appendix C

#### Questions from Pre Bid Meeting on Filter Changes in Schools

1. BSH – Vents on main wall. Is that in their contract to clean?
  - a. No, only area directly around filter
2. Do they have to haul filters off or can they be placed in dumpsters located at schools?
  - a. Can be placed in school dumpster if room available
3. Can they use equipment to pull filters up on roof?
  - a. Yes, any soft rope material that will not damage roof cap/flashing.
4. Do they have to clean all return vents?
  - a. No, only areas directly around filter
5. If at any time that there's a long break in school being in session (ie summer vacation) would you rather for them to change the filters right before school starts or keep on track with time frame of changes?
  - a. No, keep a quarterly frequency regardless of breaks. If lining up with breaks is more convenient for access, then we will try to accommodate.
6. Do they have any schools that they have to do on Saturdays?
  - a. No, these are to be done during normal business hours
7. How soon can we get them a count on washable filters at BSHFA?
  - a. Boiling Springs Freshman Academy – 119 (D2 is currently looking to purchase the extra set before contract is awarded)
  - b. Shoally Creek Elementary – 110 (Spare set is purchased and available at the school)
8. How soon can we get the names from units for roll filters at CSF and MES?
  - a. AAF-HermanNelson