

**CITY OF SPRINGFIELD ELECTRIC DEPARTMENT  
1000 CENTRAL AVENUE  
SPRINGFIELD, TENNESSEE 37172**

**PROPOSAL CONTRACT**

**SIXTY-EIGHT (68) HORIZONTAL POST TYPE INSULATORS**

**BID OPENING DATE: October 11, 2016**

**TIME: 2:00 p.m.**

Contents:

- I. Proposal/Bid Preparation
- II. Base Bid
- III. Specifications

**68-HORIZONTAL POST TYPE INSULATORS  
Bid Opening**

**Date: October 11, 2016      Time: 2:00 p.m.**

---

Quantity	Description	Price Each	Total
68	69 KV HORIZONTAL POST-TYPE INSULATORS	\$ _____	\$ _____

Terms and Length of Warranty/Guarantee: \_\_\_\_\_

Other Terms and Conditions: \_\_\_\_\_

Exceptions/Substitutions:

1. \_\_\_\_\_
2. \_\_\_\_\_
3. \_\_\_\_\_
4. \_\_\_\_\_

---

**Notes:**

1. Bidder must submit with bid proposal complete specifications, pictures, and literature describing and illustrating the proposed equipment.
2. Include all shipping charges with bid proposal. Pricing shall include delivery to 1000 Central Avenue, Springfield, Tennessee 37172.
3. Sales tax is not to be included. We are a tax-exempt local government agency.

Notes:

4. Final payment shall be made to successful BIDDER by OWNER within thirty (30) days after:
  - a. Delivery of product, and assembly if applicable, and;
  - b. The approval by the OWNER of all work performed under the proposal, and;
  - c. An affidavit has been submitted to OWNER by BIDDER stating that payment has been made for all labor, materials, and subcontractors under this proposal.
5. BIDDER agrees to be bound by the bid price in this proposal for a period of sixty (60) days from the date of the opening of the bid.
6. The OWNER reserves the right to reject any or all bids, to waive any informality in bids, and to accept in whole or part such bid or bids as may be deemed in the best interest of OWNER.

\_\_\_\_\_  
Signature – BIDDER

\_\_\_\_\_  
Signature - OWNER

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Title

\_\_\_\_\_  
Address

\_\_\_\_\_  
Date

\_\_\_\_\_  
Telephone No.

\_\_\_\_\_  
Date

\_\_\_\_\_**SPECIFICATIONS FOLLOW THIS PAGE**\_\_\_\_\_

### **III. SPECIFICATIONS**

**Provide Sixty-Eight (68) 69 KV Horizontal Post-type Insulators as follows:**

- Rated voltage 69 KV
- Polymer length 26" to 31" maximum
- Section length 39" to 44" maximum
- Leakage distance 82" or greater
- 60-Hz dry flashover 330 KV
- Rod diameter 2.5"
- Must be horizontal clamp end fitting
- Maximum design tension 2,500 lbs.
- Base must be aluminum gain with 12" bolt hole spacing for 2.5" rod