



ADDENDUM NO. 1

Issue Date: August 30, 2024

Project Name: Annual Utility Services Labor Contract

RFP Number: 2025005

RFP Opening Date: **September 10, 2024**

This addendum is being released to provide responses to questions received to date.

The information and documents contained in this addendum are hereby incorporated in the Request for Proposals. **This addendum must be acknowledged where indicated on the Firm Information form, or the proposal may be declared non-responsive.**

Questions and Answers

1.	What is the Engineer's Estimate/Budget for this Project?
	Estimated Budget is \$1,805,000
2.	Is a Bid Bond required?
	No Bid Bond is required for this project as it is a Request for Proposals.
3.	Please confirm there is no pre-bid meeting.
	Correct, there is no pre-proposal meeting scheduled.
4.	The bids docs state the package requires a Certificate Regarding Debarment, but there wasn't one provided. Can this form be provided?
	This item is not required. Updated Submittal Instructions are below.
5.	Page 22 of 50 / "Ductile Iron & Polyvinyl Chloride Pipe for Gravity Wastewater System Application, Part E." Can the bid documents be updated per the ductile iron lining manufacturer's recommendation? For lining ductile iron, Permax PCS-9043, Glass Flake Epoxy - has been updated several years ago to Permax CTF. All of the ductile iron manufacturers tested/approve Permax CTF for domestic sewer service.
	Please bid per the May 2019 Utility Construction Standards – The alternate product may be approved on a case by case basis by IRCDUS Engineering.

6.	For a proposal to qualify does, a contractor need to provide pricing for all bid items, or can a contractor provide pricing for specific bid items?
	Contractor <i>will not</i> be disqualified for providing pricing on specific bid items
7.	Would you please give me some specifics on the requirements for the Public Construction Bond? Is this something we purchase beforehand?
	A Public Construction Bond will be required for certain individual projects and would be required to be received, approved and recorded by the County prior to commencement of work on that project.
8.	Is there a timeframe on how long we should have been in business and a requirement on how long we should have held our CGC / CUC license?
	There are no requirements for length of time with licensure.

Modifications

Page 37 of 50: Item j. Certification regarding debarment is hereby removed from the Submittal Instructions.