



ADDENDUM NO. 1

Issue Date: May 30, 2023

Project Name: Treasure Shores Beach Park Septic to Sewer Conversion

Bid Number: 2023022

Bid Opening Date: **June 8, 2023 (updated)**

This addendum is being released to answer questions received to date and to extend the due date. The information and documents contained in this addendum are hereby incorporated in the Bid Documents. **This addendum must be acknowledged where indicated on the Bid Form, or the bid will be declared non-responsive.**

Questions and Answers

1. Bid item #14: 2" HDPE DR-11 FM Directional Bore has quantity listed as 340 LF, the scaled-out quantity is ~260 LF, will this quantity be revised in a forthcoming addendum?

Line item 14. 2" HDPE DR-11 Force main (Directional Bore) is confirmed at a quantity of 240 LF.

2. Please verify the size of the water main at the wet tap location.

Per plan page C-1, the size & location of existing water service have not verified, it is the responsibility of the Contractor to verify and locate the existing service for the proposed tap.

Attachments

Addendum 1 – Bid Form

Bid Form – Addendum 1

Project Name **Treasure Shores Beach Park Septic to Sewer Conversion**

Bid #: 2023022
 Bid Opening Date and Time: June 8, 2022 2:00 P.M.
 Bid Opening Location: Purchasing Division
 1800 27th Street
 Vero Beach, FL 32960

The following addenda are hereby acknowledged:

Addendum Number	Date
_____	_____
_____	_____
_____	_____
_____	_____

In accordance with all terms, conditions, specifications, and requirements, the Bidder offers the following:

Item	Unit Price	Unit	Quantity	Total
1. Mobilization	\$	LS	1	\$
2. Clearing	\$	LS	1	\$
3. Final Grade (Lift Station Pad)	\$	SY	70	\$
4. Erosion Control (FDOT Right-of-Way)	\$	LS	1	\$
5. Maintenance of Traffic (FDOT Right-of-Way)	\$	LS	1	\$
6. Sidewalk Removal (FDOT Right-of-Way)	\$	SY	10	\$
7. Abandon Existing Septic Tank & Drain field Removal	\$	LS	1	\$
8. Sod, Bahia (FDOT Right-of-Way & Lift Station Pad)	\$	SY	100	\$
9. Select Fill Material (Lift Station Pad)	\$	CY	135	\$
10. 6" Thick Reinforced Concrete (FDOT Sidewalk)	\$	SY	10	\$
11. 1" Service Saddle & Tap	\$	EA	1	\$
12. 1" PE Water Service	\$	LF	49	\$
13. Hose Bib	\$	EA	1	\$

Item	Unit Price	Unit	Quantity	Total
14. 2" HDPE DR-11 Force Main (Directional Bore)	\$	LF	240	\$
15. 2" HDPE DR-11 Force Main (Open Cut)	\$	LF	23	\$
16. 4" PVC Gravity Sewer	\$	LF	7	\$
17. 6"x4" Service Saddle & Tap	\$	EA	1	\$
18. 4" Gate Valve	\$	EA	1	\$
19. 4"x2" Reducer	\$	EA	1	\$
20. Private Duplex Lift Station	\$	LS	1	\$
21. Electrical for Lift Station	\$	LS	1	\$
22. 2" Gate Valve	\$	EA	1	\$
23. 2" Curb Stop	\$	EA	1	\$
24. Meter Box	\$	EA	1	\$
25. Survey StakeOut	\$	LS	1	\$
26. Testing	\$	LS	1	\$
27. As-Builts	\$	LS	1	\$
28. Public Construction Bond (if total bid exceeds \$100,000)	\$	LS	1	\$
Total Bid Price			\$	

Total Bid Price in Words

Project completion time after receipt of "Notice to Proceed" or PO: _____ **DAYS**

The undersigned hereby certifies that they have read and understand the contents of this solicitation and agree to furnish at the prices shown any or all of the items above, subject to all instructions, conditions, specifications, and attachments hereto. Failure to have read all the provisions of this solicitation shall not be cause to alter any resulting contract or request additional compensation.

Company Name: _____

Company Address: _____

City, State _____ Zip Code _____

Telephone: _____ Fax: _____

E-mail: _____

Business Tax Receipt Number: _____ FEIN Number: _____

Authorized Signature: _____ **Date:** _____

Name: _____ Title: _____
(Type / Printed)