

Marymeade Roadway Extension

Addendum #1

(posted November 14, 2017)

1. What mix type shall the asphalt binder and surface be? (Intermediate B and Surface C?)
Yes, Intermediate Type B and Surface Type C
2. The bid documents state award will be based on the lump sum total bid price but will payment be based on unit prices as measured in the field?
Contract will be awarded based on total bid cost. This is a unit price contract and invoices will be paid based on units completed and confirmed in the field.
3. Will there be an adjustment for the asphalt liquid binder based on the current SCDOT index?
Yes
4. On sheets C9 and C10 it references street lights. Typically SCE&G installs these and they are not part of our contract and there is no bid item for it (only 3" electrical conduit for the street lights). Are these intended to be installed by the contractor?
SCE&G will install the street lights. The contractor will install the conduit for the power. SCE&G will submit a drawing of where the lights will be placed prior to the contractor installing the 3" conduit. This drawing will be provided to the contractor.
5. I've noticed that on some documents, the project name is Marymeade Drive Extension, and on others, it is Marymeade Roadway Extension. How do you want it bonded?
Bond as Marymeade Roadway Extension