

Marymeade Roadway Extension

Addendum #2

(posted November 15, 2017)

1. There is reference to an 'Attachment A' on pg. 22 of the 'Construction Bid Solicitation Package 102317', but I am unable to locate any such attachment. Is it required?

'Attachment A' is not required

2. The existing inlets will likely need inlet protection but there is no direct pay item. Should I incorporate this cost into the available erosion pay items?

Yes, please include any inlet protection in the erosion control pay item.

3. Landscaping appears to be outside of the Limits Of Disturbance for the roadway. Can you confirm the location shown on sheet L1 is the only area in which trees will be planted? Also, the line item indicates Ligustrums or Wax Myrtles while the plan set indicates Leyland Cypress or Similarly Accepted Evergreens. Is there a preference?

The location shown on Sheet L1 is the only location trees and landscaping is being planted on this project. Either Ligustrums or Wax Myrtles are to be planted.

4. Pay item #24 indicated placing 3" conduits. Will this be all PVC and/or any galvanized components?

All PVC

5. Pay item #17 Suitable fill: how will this be measured?

Measured by Plans and the Town would like truck tickets for fill material

6. How will the quantities for this project be determined for payment. Plan or Field measure?

Plans

7. Pay Item #4 As-builts: for storm drains only or for any/all improvements? Additionally, will video of the relatively short pipe runs be required?

As-builts are for all improvements. No video is required for pipe installations.