



ADDENDUM NO. 4

Issue Date: September 30, 2019

Project Name: Hobart Park Baseball Field Project

Bid Number: 2020005

Bid Opening Date: October 4, 2019

This addendum is being released to address the final questions received.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid will be declared non-responsive.**

Questions and Answers

1. Addendum #3 contains contradictions with regards to sod and sprigging grow-in and warranties as it is stated in different places as 21 days, 8 weeks & 26 weeks – please clarify the intention.
There is a 26 week warranty period for the sprigging grow in.
2. Please provide the Water Use Permit detailing the specifications of the existing well for the site.
There is no existing well on-site that can be used for this project. A new well is needed. If it is deemed necessary for a Consumptive Use Permit by the Water Management District, the Owner will secure said permit.
3. Sheet M1.1 shows louvers to be installed at the outside restroom walls. Architectural plans do not show louvers. Louvers are labeled as windows. Please advise.
Contractor shall provide (2) 16x16 transfer grilles and (1) 20x20 transfer grille equal to Metalaire RH, aluminum, with plenum box. Mount 16x16 grilles in bathroom ceiling and 20x20 in entryway ceiling (exterior). Provide 12" diameter flexible R-4.2 duct to connect each 16x16 grille to the 20x20 grille.