



**Wi-Fi in Public Parks Project #2001
CDBG Grant CV1-022
REQUEST FOR BID (RFB) – Re Bid**

ADDENDUM I

Answers to Questions

Date: Wednesday, June 14, 2023

1. The requirement are requesting bidders to use weather heads to bring power down to our enclosures.
 - A) Would the winning bidder be required to use a metal weather head or can a PVC weather head be used?
 - B) If a metal weather head is required, can a PVC conduit pipe be used from the head to our enclosure?

According to the National Electric Code (NEC), the service raceways shall be equipped with a service head at the point of connection to service drop for overhead service conductors. The service head shall be listed for use in wet locations.

If there is no tension on it, either a metal or PVC weather head. If there is tension on it, a metal weather head and mast would be appropriate, as long it is listed for a wet location.