

ARLINGTON COUNTY, VIRGINIA

DEPARTMENT OF ENVIRONMENTAL SERVICES
DEVELOPMENT SERVICES BUREAU
703-228-3629

LAND DISTURBING ACTIVITY PERMIT

LDA PERMIT # LDA19039

DATE ISSUED 5/7/2020 EXPIRATION DATE 5/7/2021

INSPECTOR Diana Handy INSPECTOR PHONE 703-228-0772

This PERMIT has been duly issued for the hereinafter described Land Disturbing Activity (LDA) pursuant to: Arlington County Code, Chapter 57 - Erosion & Sediment Control.

ADDRESS 2400 N WAKEFIELD ST ARL

LDA DESCRIPTION Approximately 3450 LF of 24-inch Water Main
Installation and 276 LF of 8-inch Water Main

PROJECT MANAGER NAME ARLINGTON COUNTY DESIGN
ENGINEERS

PROJECT MANAGER PHONE 703-228-3639

RESPONSIBLE LAND DISTURBER (RLD) NILESH NAIKARE

RLD CERTIFICATION # 402049246

RLD PHONE 703-228-3632



ARLINGTON
VIRGINIA

APPROVED BY *[Signature]*
DEVELOPMENT SERVICES BUREAU CHIEF

THIS PERMIT ***MUST BE DISPLAYED*** IN A CONSPICUOUS LOCATION ON THE PREMISES WHERE IT IS PLAINLY VISIBLE FROM THE STREET. THE APPROVED EROSION AND SEDIMENT CONTROL PLAN MUST BE AVAILABLE ON THE PREMISES DURING ANY LAND-DISTURBING ACTIVITIES.

A pre-construction meeting must be scheduled prior to commencing land disturbing activity. To schedule pre-construction meeting and/or inspections contact Inspector above. (7am-4pm Monday-Friday)



COMMONWEALTH of VIRGINIA

DEPARTMENT OF HEALTH

OFFICE OF DRINKING WATER

Culpeper Field Office

M. Norman Oliver, MD, MA
State Health Commissioner

400 S. Main Street, 2nd Floor
Culpeper, VA 22701
Phone: 540-829-7340
Fax: 540-829-7337

WATERWORKS CONSTRUCTION PERMIT

Permit No.:	602519	Subject:	Arlington County
Effective Date:	September 30, 2019	Water:	Arlington County
Expiration Date:	September 30, 2024	PWSID:	6013010

Issued to:

Arlington County Water, Sewer and Streets Bureau
4200 28th St. S
Arlington, VA 22206

ATTN: Mr. Regan Carver, PE

Plans for the construction of modifications to the Arlington County community waterworks located in Arlington County, prepared by the Arlington County Department of Environmental Services, have been reviewed by this Office. The plans titled "Construction Drawing For: Gravity One – Phase II – 24-inch Water Main, From Lorcom Lane to 25th Street N" are dated January 9, 2019, and include sheets 1 of 28 through 28 of 28. The plans include Supplemental Specifications and refer to the Arlington County Construction Standards and Specifications approved by this office on June 10, 2015.

The project consists of the installation of approximately 3,450 ft of 24-inch diameter and 290 ft of 8-inch diameter ductile iron water main to serve as a backup for the Lee storage tanks and pump station.

The plans are technically adequate and are approved by this Office, in accordance with 12VAC5-590 of the Commonwealth of Virginia *Waterworks Regulations*. A copy of these documents is on file in the Culpeper Field Office.

This approval does not suspend, minimize, or otherwise alter the waterworks obligation to comply with federal, state, or local laws and regulations or permits.

Mr. Regan Carver
Waterworks Construction Permit No. 602519
September 30, 2019
Page 2

This Waterworks Construction Permit is issued in accordance with Title 32.1 of the *Code of Virginia*, and 12VAC5-590 *et seq.* of the *Waterworks Regulations*. This is your authorization from the State Health Commissioner to construct modifications to the subject waterworks in accordance with the approved documents. Any deviations from the approved documents affecting capacity, hydraulic conditions, operating units, the functioning of the treatment processes, or the water quality delivered, must be approved by this Office before any such changes are made. Revised plans and specifications shall be submitted to the Culpeper Field Office in time to permit review and approval before construction.

Upon completion of construction, the owner shall submit a statement signed by a professional engineer licensed in Virginia certifying that the work was completed in accordance with the approved documents.

Upon receipt of this statement and satisfactory results of the bacteriological analysis, the project may be put into service.

If we can be of additional assistance, please contact Kyle McCammon, District Engineer, in our Culpeper Field Office at 540-829-7340.

Sincerely,



Jeremy D. Hull, PE
Engineering Field Director

KAM

cc: Arlington County, Attn: Mr. Arjun Joshi and Mr. Nilesh Ram Maikare
Arlington County Health Department
Arlington County Administrator
Arlington County Building Official
ec: ODW – Central Office