

EMW Public Access CNG Station CNG Integration Package – ITB 2020-4 Moriarty, Torrance County, New Mexico Addendum Number 1

Date: October 8, 2020

Issued to: All Bid Document Holders of Record

This addendum forms a part of the bid package described above. The original Bid Documents and any prior addenda remain in full force and effect as modified by the following that shall take precedence over any contrary provisions in the prior documents.

Project Manual Clarifications & Revisions:

Section 00300B - Bid Items 3 and 4

1. Please note that these bid items for reconditioning and installation of a 3 pack of 24' long ASME Storage Tubes have been removed from this project.

Section 00300B - Bid Item 10

1. Please note that the quantity of ½" SS 0.065" wall tubing for storage manifold connections has been reduced to reflect the removal of ASME Storage Tubes from this installation.

Section 00300B - Alternate Bid Items A1 thru A6

1. Please note that the quantities for these alternate bid items have been increased to reflect the installation of 5 ASME Storage Spheres. Also, these additional ASME spheres that will be provided by EMW Gas Association will already have current PRV's (Pressure Relief Valves).

Please see attached revised Unit Bid Price Schedule Section 00300B which contains these updated bid quantities and bid item numbers.

Please see attached revised Plan Sheet 3 and replace it in the Construction Plan set. We have removed the use of ASME Tubes in the equipment enclosure and now will have all ASME storage spheres.





DA. Re		September 3, 2020	
John H. Bolte, P.E.	Date		
Project Engineer 26315 26315			

Each bidder shall acknowledge receipt of this addendum by affixing his signature below by noting this addendum on his bid form, and by attaching this addendum to his bid.

ACKNOWLEDGEMENT

The undersigned acknowledges receipt of this addendum and the Bid submitted in accordance with information, instructions and stipulations set forth herein.

Bidder:		
Signed By:	 	
Date:		