

PITTSBURGH STATE UNIV
300 E LINBURG

AUG 12, 2022 9:157 AM

TANK LEAK TEST HISTORY

T 312 HEATING OIL

LAST GROSS TEST PASSED:
AUG 7, 2022 1:00 AM
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:
AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

FULLEST ANNUAL TEST PASSED:
AUG 20, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4985
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

LAST PERIODIC TEST PASSED:
AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

FULLEST PERIODIC TEST PASSED EACH MONTH:

AUG 30, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

AUG 13, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4985
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

AUG 20, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4985
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

AUG 27, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

AUG 29, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4985
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

JUN 5, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4985
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

JUL 31, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

SEP 19, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

OCT 3, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

NOV 28, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4983
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

DEC 26, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4983
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

***** END *****

----- IN-TANK ALARM -----
T 2:2 HEATING OIL
HIGH PRODUCT ALARM
AUG 12, 2022 9:05 AM

----- IN-TANK ALARM -----
T 2:2 HEATING OIL
MAX PRODUCT ALARM
AUG 12, 2022 9:05 AM

----- IN-TANK ALARM -----
T 2:2 HEATING OIL
HIGH WATER WARNING
AUG 12, 2022 9:18 AM

PITTSBURGH STATE UNIV
300 E LINBURG

AUG 12, 2022 9:157 AM

TANK LEAK TEST HISTORY

T 312 HEATING OIL

LAST GROSS TEST PASSED:
AUG 7, 2022 1:00 AM
STARTING VOLUME= 8160
PERCENT VOLUME = 86.5
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:
AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8160
PERCENT VOLUME = 86.5
TEST TYPE = STANDARD

FULLEST ANNUAL TEST PASSED:
AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8160
PERCENT VOLUME = 86.5
TEST TYPE = STANDARD

LAST PERIODIC TEST PASSED:
AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8160
PERCENT VOLUME = 86.5
TEST TYPE = STANDARD

FULLEST PERIODIC TEST PASSED EACH MONTH:

JAN 9, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8156
PERCENT VOLUME = 86.4
TEST TYPE = STANDARD

FEB 20, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8157
PERCENT VOLUME = 86.4
TEST TYPE = STANDARD

MAR 20, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8158
PERCENT VOLUME = 86.4
TEST TYPE = STANDARD

APR 3, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8156
PERCENT VOLUME = 86.4
TEST TYPE = STANDARD

MAY 22, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8157
PERCENT VOLUME = 86.4
TEST TYPE = STANDARD

JUN 26, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8159
PERCENT VOLUME = 86.5
TEST TYPE = STANDARD

JUL 31, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8159
PERCENT VOLUME = 86.5
TEST TYPE = STANDARD

AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8160
PERCENT VOLUME = 86.5
TEST TYPE = STANDARD

SEP 5, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8159
PERCENT VOLUME = 86.5
TEST TYPE = STANDARD

OCT 3, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8158
PERCENT VOLUME = 86.4
TEST TYPE = STANDARD

NOV 7, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8157
PERCENT VOLUME = 86.4
TEST TYPE = STANDARD

DEC 5, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8156
PERCENT VOLUME = 86.4
TEST TYPE = STANDARD

***** END *****

----- IN-TANK ALARM -----
T 312 HEATING OIL
HIGH PRODUCT ALARM
AUG 12, 2022 9:05 AM

----- IN-TANK ALARM -----
T 3:2 HEATING OIL
MAX PRODUCT ALARM
AUG 12, 2022 9:03 AM

----- IN-TANK ALARM -----
T 3:2 HEATING OIL
HIGH WATER ALARM
AUG 12, 2022 9:07 AM

FITT STATE UNIV
300 E LINBURG

AUG 12. 2022 9:57 AM

TANK LEAK TEST HISTORY
4:2 HEATING OIL

LAST GROSS TEST PASSED:
AUG 7. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8047
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:
AUG 7. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8047
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

FULLEST ANNUAL TEST PASS
JUN 26. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8047
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

LAST PERIODIC TEST PASS:
AUG 7. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8047
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

AUG 30. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8045
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

AUG 27. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8046
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

AUG 27. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8046
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

AUG 24. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8046
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

AUG 22. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8047
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

JUN 26. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8047
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

JUL 3. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8047
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

AUG 7. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8047
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

SEP 5. 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8046
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

OCT 3. 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8046
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

NOV 21. 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8045
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

DEC 26. 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 8045
PERCENT VOLUME = 85.3
TEST TYPE = STANDARD

***** END *****

----- IN-TANK ALARM -----
T 4:2 HEATING OIL
MAX PRODUCT ALARM
AUG 12. 2022 9:02 AM

----- IN-TANK ALARM -----
T 4:2 HEATING OIL
HIGH WATER ALARM
AUG 12. 2022 9:05 AM

----- IN-TANK ALARM -----
T 4:2 HEATING OIL
HIGH WATER WARNING
AUG 12. 2022 9:05 AM

FITT STATE UNIV
300 E LINBURG

AUG 12. 2022 9:56 AM

TANK LEAK TEST HISTORY
T 1:2 HEATING OIL

LAST GROSS TEST PASSED:
AUG 7. 2022 1:00 AM
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:
AUG 7. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

FULLEST ANNUAL TEST PASS
MAR 20. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4985
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

LAST PERIODIC TEST PASS:
AUG 7. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

AUG 30. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

AUG 13. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4985
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

AUG 20. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4985
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

AUG 3. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

AUG 29. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4985
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

JUN 5. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4985
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

JUL 31. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

AUG 7. 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

SEP 19. 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

OCT 3. 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4984
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

NOV 28. 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4983
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

DEC 26. 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME= 4983
PERCENT VOLUME = 52.8
TEST TYPE = STANDARD

***** END *****

----- IN-TANK ALARM -----
T 1:2 HEATING OIL
HIGH PRODUCT ALARM
AUG 12. 2022 9:06 AM

----- IN-TANK ALARM -----
T 1:2 HEATING OIL
MAX PRODUCT ALARM
AUG 12. 2022 9:06 AM

----- IN-TANK ALARM -----
T 1:2 HEATING OIL
HIGH WATER ALARM
AUG 12. 2022 9:09 AM

PITT STATE UNIV
300 E LINBURG

AUG 12, 2022 9:57 AM

TANK LEAK TEST HISTORY

T 5:UNLEAD

LAST GROSS TEST PASSED:
AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1416
PERCENT VOLUME = 67.9
TEST TYPE = STANDARD

LAST ANNUAL TEST PASSED:
AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1416
PERCENT VOLUME = 67.9
TEST TYPE = STANDARD

FULLEST ANNUAL TEST PASS
JAN 30, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1806
PERCENT VOLUME = 86.6
TEST TYPE = STANDARD

LAST PERIODIC TEST PASS:
AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1416
PERCENT VOLUME = 67.9
TEST TYPE = STANDARD

FULLEST PERIODIC TEST
PASSED EACH MONTH:

JAN 30, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1806
PERCENT VOLUME = 86.6
TEST TYPE = STANDARD

FEB 5, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1624
PERCENT VOLUME = 77.9
TEST TYPE = STANDARD

MAR 13, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1743
PERCENT VOLUME = 83.6
TEST TYPE = STANDARD

APR 24, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1479
PERCENT VOLUME = 70.9
TEST TYPE = STANDARD

MAY 22, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1688
PERCENT VOLUME = 81.0
TEST TYPE = STANDARD

JUN 26, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1530
PERCENT VOLUME = 73.3
TEST TYPE = STANDARD

JUL 31, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1651
PERCENT VOLUME = 79.2
TEST TYPE = STANDARD

AUG 7, 2022 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1416
PERCENT VOLUME = 67.9
TEST TYPE = STANDARD

SEP 19, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1620
PERCENT VOLUME = 77.7
TEST TYPE = STANDARD

OCT 24, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1623
PERCENT VOLUME = 77.8
TEST TYPE = STANDARD

NOV 28, 2021 1:00 AM
TEST LENGTH 3 HOURS
STARTING VOLUME = 1818
PERCENT VOLUME = 87.2
TEST TYPE = STANDARD

DEC 5, 2021 1:00 AM
TEST LENGTH 4 HOURS
STARTING VOLUME = 1517
PERCENT VOLUME = 72.8
TEST TYPE = STANDARD

***** END *****

----- IN-TANK ALARM -----
T 5:UNLEAD
PROBE OUT
AUG 12, 2022 8:16 AM

----- IN-TANK ALARM -----
T 5:UNLEAD
HIGH WATER ALARM
AUG 12, 2022 8:20 AM

----- IN-TANK ALARM -----
T 5:UNLEAD
HIGH WATER WARNING
AUG 12, 2022 8:20 AM

PITT STATE UNIV
300 E LINBURG

AUG 12, 2022 9:54 AM

SYSTEM STATUS REPORT

ALL FUNCTIONS NORMAL