

**ADDENDUM NUMBER 2
BID NUMBER IFB 22-018**

Locker Replacement For Schlagle & Wyandotte

ISSUED: May 11, 2022

**PURCHASING DEPARTMENT
UNIFIED SCHOOL DISTRICT 500
2010 N. 59th STREET, ROOM 370
KANSAS CITY, KANSAS 66104
(913) 551-3200**

Note the following changes to the above-mentioned bid. This information is to be taken into consideration when responding to the original bid document.

1. Added: The following information has been added to go with locker drawings in Addendum 1.

Colors:

Wyandotte: Red

Schlagle: Blue

Wyandotte dimensions:

- Home lockers: 18"w
- Visitor lockers: 15"w

Construction clarification – both locations:

- Door frames only to be welded
- Doors and frames will be 14ga, body 16ga and backs 18ga.

Schlagle Girls locker room:

- Correction of quantity – Schlagle girls locker room has four (4) back-to-back islands and two (2) single runs, which total 120 frames. (Boys side has four (4) back-to-back islands and One (1) single run, for total of 108)

2. No Other Changes: No other changes or modification are intended by this Addendum. All other terms and conditions of the solicitation remain in effect.

WE HEREBY ACKNOWLEDGE AND UNDERSTAND THE ABOVE NOTED CHANGES TO THE ORIGINAL BID DOCUMENT AND AGREE TO FURNISH THE ITEMS ON WHICH PRICES ARE QUOTED IN ACCORDANCE WITH ALL TERMS AND CONDITIONS PREVIOUSLY LISTED AND ANY ATTACHED SPECIFICATIONS AND AMENDMENTS.

BY: _____ DATE: _____
TITLE: _____ PHONE: _____
FIRM _____