



ROOF PLAN - POWER & SIGNAL
SCALE: 1/8" = 1'-0"

GENERAL SHEET NOTES

- REFER TO MECHANICAL PLANS FOR EXACT LOCATION OF ALL MECHANICAL EQUIPMENT. VERIFY EXACT LOCATION AND CONNECTION REQUIREMENTS OF ALL MECHANICAL EQUIPMENT WITH MECHANICAL PRIOR TO ROUGH-IN. VERIFY EXACT REQUIREMENTS FOR VOLTAGE, PHASE, HORSEPOWER OR KVA RATINGS OF ALL MECHANICAL EQUIPMENT REQUIRING ELECTRICAL CONNECTIONS.
- EQUIPMENT OVERLOADS AND FUSES FOR ELEVATOR AND MECHANICAL EQUIPMENT SHALL BE PROVIDED AND INSTALLED AS PER NAME PLATE ON THE EQUIPMENT ACTUALLY PURCHASED OR ALREADY INSTALLED.
- ALL ELECTRICAL EQUIPMENT EXPOSED TO THE WEATHER SHALL BE LISTED FOR EXTERIOR USE.
- ALL EXTERIOR CONDUITS SHALL BE RIGID GALVANIZED STEEL WITH WATERTIGHT FITTINGS.
- DEDICATED NEUTRALS REQUIRED FOR ALL BRANCH CIRCUITS.
- ELECTRICAL DEVICES ON FIRE-RATED WALLS TO BE INSTALLED 24" APART MINIMUM.
- SEE MECHANICAL AND PLUMBING PLANS AND SPECIFICATIONS FOR ADDITIONAL ELECTRICAL SCOPE OF WORK.

NOTE:
ALL DISCONNECTS AND SWITCHES CONNECTED TO EMERGENCY GENERATOR SHALL BE PROVIDED WITH SCREWED ON ENGRAVED LABELS READING "EMERGENCY" IN RED LETTERING.

NUMBERED SHEET NOTES

- ALL EXTERIOR RECEPTACLES SHALL BE GFI WITH LOCKABLE THIN PROFILE WEATHERPROOF "IN-USE" COVERPLATES. VERIFY LOCATION WITH ARCHITECT PRIOR TO ROUGH-IN.
- PROVIDE AND INSTALL (2) 4" CONDUITS WITH PULLROPE FROM ROOF TO MAIN ELECTRICAL ROOM FOR FUTURE PV USE. TERMINATE CONDUITS IN WEATHER HEADS ON ROOF.

APPROVALS

NOLL & TAM
ARCHITECTS

729 Heinz Avenue
Berkeley, CA 94710
tel 510.542.2200
fax 510.542.2201

CAVAGNERO
MARK CAVAGNERO ASSOCIATES ARCHITECTS
1645 RAYBURN STREET, SUITE 200
SAN FRANCISCO, CALIFORNIA 94111
www.cavagnero.com

SEAL

P. [Signature]
REGISTERED PROFESSIONAL
ELECTRICIAN
STATE OF CALIFORNIA
9227/0203

OMAHONY & MYER
REGISTERED PROFESSIONAL ELECTRICAL ENGINEERS
4340 REDWOOD HWY, SUITE 245
SAN RAFAEL, CALIFORNIA 94903
(415) 492-0820/FAX (415) 479-9662
www.comconconsulting.com

PROJECT TITLE

**Peralta Community College District
Laney Library & Learning Resource Center
(Building 100 Replacement)**

900 Fallon Street, Oakland, CA 94607

ISSUE FOR BID

ISSUE DATE	3/31/23
W&L JOB NUMBER	21942
REVISIONS	
DATE	DESCRIPTION
05/16/2024	ADDENDUM NO. 03

DRAWN BY: [Blank] CHECKED BY: [Blank]

SHEET TITLE: **ROOF PLAN - POWER & SIGNAL**

SHEET NUMBER: **E3.35**