

- 4. MULTIPLE BRANCH CIRCUITS (3 MAX) INSTALLED IN COMMON RACEWAY SHALL HAVE SEPARATE NEUTRALS INSTALLED FOR EACH PHASE CONDUCTOR. THE UNGROUNDED AND GROUNDED CIRCUIT CONDUCTORS
- 5. FURNISH AND INSTALL ARC FLASH HAZARD WARNING LABELS PER NEC
- 6. SERVICE RATED EQUIPMENT PANELBOARD OR SERVICE DISCONNECTS SHALL BE FIELD MARKED PER NEC 110.24 WITH THE MAXIMUM AVAILABLE FAULT CURRENT AND DATE FAULT CURRENT CALCULATION
- 7. SERIES RATED CIRCUIT BREAKER COMBINATIONS ARE NOT ACCEPTABLE

	109 Park of Commerce Drive, Suite 6 Savannah, Georgia 31405 PHONE (912) 238-2400 FAX (912) 238-2412	This drawing and all prints of it are the property of Chatham Engineering Company, LLC Prints are to be returned to Chatham Engineering Company, LLC upon completion of use for which they were issued. Reproductions of this drawing without the written consent of Chatham Engineering Company, LLC is not permitted	
No. Date I			By
EFFINGHAM COUNTY REC COMPLEX LIGHTING			SPRINGFIELD GEORGIA
Stamp			
Job No. 2100 Drawn L. Checked W. Date 2/28/202	C. P.	neet No	E1