



Adjustment (plus or minus) for installing direct bore conduits from Transformers T1B to Manhole MHT1B instead of duct bank.       \$ \_\_\_\_\_

Adjustment (plus or minus) for installing direct bore conduits from Transformers T3 to Manhole MHT3 instead of duct bank.       \$ \_\_\_\_\_

The undersigned Bidder agrees to fully complete the work and the Front Street underground electrical system to be on-line and available for the City's operation and control \_\_\_\_\_ days after receipt of a notice to proceed from the City.

The undersigned Bidder agrees to fully complete the Work under this contract, including all site work and final clean-up, \_\_\_\_\_ days after receipt of a notice to proceed from the City.

The undersigned Bidder hereby certifies (a) that his Bid is genuine and is not made in the interest of, or in the behalf of, any undisclosed person, firm, or corporation, and is not submitted in conformity with any agreement or rules of any group, association, organization, or corporation; (b) that he has not directly or indirectly induced or solicited any other Bidder to put in a false or sham Bid; (c) that he has not solicited or induced any person, firm, or corporation to refrain from bidding; and (d) that he has not sought by collusion to obtain for himself any advantage over any other Bidder or over the City.

## 2.1 UNIT PRICES

Unit prices quoted and accepted shall apply throughout the life of the contract, except as otherwise specifically noted. Unit prices shall be applied, as appropriate, to compute the total value of changes in the scope of the work, all in accordance with the contract documents.

The unit adjustment prices will be a major consideration in the bid evaluations.

	Unit Adjustment Price
Conduit trenching, machine dug, per cubic yard	_____
Conduit trenching, hand dug, per cubic yard	_____
Rock excavation, per cubic yard	_____
Cut and replace asphalt pavement (furnish all materials), per square yard	_____
Cut and replace decorative concrete sidewalk (furnish all materials), per square yard	_____
Re-seed and mulch (furnish all materials), per square yard	_____
Re-sod (furnish all materials), per square yard	_____
Concrete for transformer pads, including reinforcing and formwork, per cubic yard	_____

	Unit Adjustment Price
Bore under roadway, including 4-inch conduit installation, per foot	
Setup for bore, including excavation and backfill of pit, each	
Repair lifting lug on existing pull box, each	
Conduit, including fittings and supports, installed, per foot:	
4 inch PVC schedule 40 direct buried	
1-1/2 inch rigid steel	
2 inch rigid steel	
2 inch flexible liquid-tight conduit	
Concrete encased duct bank, installed, per foot:	
4 - 4 inch Type DB conduits	
6 - 4 inch Type DB conduits	
8 - 4 inch Type DB conduits	
Furnish and install 5/8 inch by 10 foot ground rod, install, test resistance, and connect to equipment with copper conductor (furnish exothermic welded connections to ground rod), each	
Furnish and install 5/8 inch by 12 foot sectional ground rod, install, test resistance, and connect to equipment with copper conductor (furnish exothermic welded connections to ground rod), each	
No. 2/0 AWG bare copper ground wire, installed, per foot	
No. 2/0 AWG copper exothermic welded connection, each	
Three No. 1/0 AWG aluminum 15 kV URD cables in conduit, installed, per foot	
600 V cable in conduit, installed, per foot:	
Three 750 kcmil and one 350 kcmil copper	

Unit Adjustment Price

Three 750 kcmil and one 350 kcmil aluminum	
Four 500 kcmil and one 350 kcmil aluminum 600 V	
Three 500 kcmil and one 350 kcmil aluminum	
Two 500 kcmil and one 350 kcmil aluminum	
Three No. 4/0 AWG and one No. 1/0 AWG aluminum	
Two No. 4/0 AWG and one No. 1/0 AWG aluminum	
15 kV loadbreak elbow, installed, each	
15 kV cable splice, installed, each	
600 V submersible connector, six 2-hole NEMA pad outlets with insulating sleeves, installed, each	
600 V submersible connector, three 1-hole NEMA pad outlets with insulating sleeves, installed, each	
Dual adapter kits for 600 V submersible connectors	
600 V terminal lugs, installed, each:	
750 kcmil aluminum 2-hole NEMA	
500 kcmil aluminum 2-hole NEMA	
350 kcmil aluminum 2-hole NEMA	
No. 4/0 AWG aluminum 2-hole NEMA	
No. 1/0 AWG aluminum 2-hole NEMA	
No. 10 AWG aluminum 2-hole NEMA	
No. 12 AWG aluminum 2-hole NEMA	
500 kcmil aluminum 1-hole NEMA	
350 kcmil aluminum 1-hole NEMA	

	Unit Adjustment Price
No. 4/0 AWG aluminum 1-hole NEMA	
No. 1/0 AWG aluminum 1-hole NEMA	
No. 10 AWG aluminum 1-hole NEMA	
No. 12 AWG aluminum 1-hole NEMA	
Cable support bracket, stainless steel slotted channel, 18" long, 1-5/8" x 1-5/8", 12 GA, installed, each	
Cable clamp, 1-7/8", polymer, with stainless steel strap, installed, each	
Manhole wall support, stainless steel slotted channel, 72" long, 13/16" x 1-5/8", 12 GA, installed, each	
Pull box wall support, stainless steel slotted channel, 38" long, 13/16" x 1-5/8", 12 GA, installed, each	
Perform dc hipot cable test on completed single phase 15 kV cable section, each	
Perform dc hipot cable test on completed three phase 15 kV cable section, each	
Install 10 kVA single phase pad-mounted transformer, each	
Install 50 kVA single phase pad-mounted transformer, each	
Install 75 kVA single phase pad-mounted transformer, each	
Install 100 kVA single phase pad-mounted transformer	
Install 167 kVA single phase pad-mounted transformer	
Install 500 kVA three phase pad-mounted transformer	
Install 750 kVA three phase pad-mounted transformer	
Furnish and install fiberglass enclosure w/ lockable lid. Min inside width 70", min depth 16", min height 40", w/ stainless steel hardware	

## 2.2 RECEIPT OF ADDENDA

The undersigned Bidder acknowledges receipt of the following Addenda, which have been considered in preparation of this Bid:

No. \_\_\_\_\_ Dated \_\_\_\_\_.

No. \_\_\_\_\_ Dated \_\_\_\_\_.

No. \_\_\_\_\_ Dated \_\_\_\_\_.

Dated in \_\_\_\_\_,  
(Location)

This \_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_.

## 2.3 IDENTIFICATION OF BIDDER (Individual, Partnership, Corporation)

If an Individual: \_\_\_\_\_  
(name)

Doing business as: \_\_\_\_\_  
(name)

If a Partnership: \_\_\_\_\_  
(name)

by: \_\_\_\_\_  
Partner

If a Corporation: \_\_\_\_\_  
(NAME)

(a \_\_\_\_\_ Corporation)  
(STATE)

## 2.4 SIGNATURE OF BIDDER

By: \_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(Print name)

\_\_\_\_\_  
(Title)

Attest: \_\_\_\_\_  
(Signature)

\_\_\_\_\_  
(SEAL)

Business Address of Bidder: \_\_\_\_\_  
\_\_\_\_\_

Telephone Number: \_\_\_\_\_

South Carolina Contractor's

License No(s): \_\_\_\_\_