



St. Johns River

Water Management District

Ann B. Shortelle, Ph.D., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940
On the internet at www.sjrwmd.com.

DATE: March 4, 2019
TO: Prospective Respondents
FROM: Amy Lucey, Procurement Specialist
SUBJECT: Addendum #2 to IFB # 34208, S252B & C Walkway Replacement

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents.

Q1: On both walkways there is HP 8 x 36 pilings. The district did not specify a coating such as coal tar, or are they just using bare steel?

A1: Please see specification below:

**“PROTECTIVE COATING FOR STRUCTURAL STEEL SHALL BE AS MANUFACTURED BY SHERWIN-WILLIAMS, OR EQUAL, AS FOLLOWS:
FIRST COAT (PRIMER): DURA-PLATE 235, 4-8 MILS DFT
SECOND COAT: DURA-PLATE 235, 4-8 MILS DFT
THIRD (FINAL) COAT: DURA-PLATE 235, 4-8 MILS DFT
COLOR SHALL BE LIGHT GRAY. SURFACE PREPARATION AND APPLICATION SHALL BE IN ACCORDANCE WITH THE PAINT MANUFACTURER SPECIFICATIONS.”**

NOTE: The Bid Due Date remains 2:00 p.m., Thursday, March 14, 2019

Attachments:
Pre-bid Meeting Recording 2/28/19 -separate cover

Please acknowledge receipt of this Addendum on the BID FORM provided in the bid package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.