



## RFP 2208 Water Treatment Services for HVAC Systems

### ADDENDUM 1 February 15<sup>th</sup>, 2022

This addendum is to post the following updates:

1. What are the cooling tower models/capacities?
  - Rainbow Lake Middle – Marley MD5016 – Spec'd @ 960GPM
2. Are there bypass feeders at each facility?
  - All but 3, which the District will take care of (Hendrix Elementary, Mayo Elementary, Shoally Creek Elementary)
3. Background Checks for SC?
  - All checks go thru SC SLED
4. Appendix A and B have been added to the solicitation information