



**CITY OF CALLAWAY  
BERTHE AVENUE BRIDGE REPLACEMENT &  
ASSOCIATED INFRASTRUCTURE  
BID NO.: PW2022-15**


**ADDENDUM #1**

Date Issued: September 8, 2022

This addendum is being released to address the following questions:

1. Can 6" DR 18 Fusible PVC® pipe be utilized in lieu of HDPE pipe? Benefits include material consistency to direct bury pipe, standard fittings for reconnection and maintenance and resistance to oxidative degradation.

**A. We approve the switch from HDPE to 6" DR 18 FPVC as recommended in question 1 of the RFI.**



Janice L. Peters, City Clerk

This Addendum must be acknowledged and included with the bid packet submission.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date