

Board of County Commissioners

Okeechobee County
Parks & Recreation Department



1718 NW 9th Avenue
Okeechobee, Florida 34972
863-763-6950
Fax 863-763-0662

ADDENDUM NO. 1

Project Name: **Okeechobee County Alton Chandler Civic Center Glass & Window Replacement Bid 2017-02**

Date: **February 24, 2017**

This addendum forms part of the Bid documents dated December 28, 2016, for the subject project as prepared by Okeechobee County. Please acknowledge receipt of the addendum in the Bid Proposal Form.

ADDITIONS, MODIFICATIONS AND/OR CLARIFICATIONS TO THE PLANS AND SPECIFICATIONS

I. INSTRUCTIONS:

1. This Addendum shall be included as part of the original Contract Documents and the work required therein.
2. All work performed under this addendum shall be subject to the requirements of the Specifications and the Drawings for the work of this Project.
3. Submit written acknowledgement of receipt, understanding, and incorporation of all items of this addendum into the bid price along with the bid. **Bids submitted without this written acknowledgement statement will be considered incomplete and disqualified.**

II: ATTACHMENTS, AMENDMENTS AND/OR CLARIFICATIONS TO BID DOCUMENTS:

The following questions were submitted on February 22nd by Central Florida Glass & Mirror.

Q.) Has there been engineering done showing that removing the wood posts will not compromise the structural integrity of the steel header in the 4 recreation area/dining openings?

A.) All openings for the above specified location are concrete/masonry. The wood posts are not structural.

Q.) Provided we supply PGT Impact Windows for stationary and single hung openings, they will requires new wood bucks and Break metal for interior! Will you supply interior trim for perimeter?

A.) No. This shall be included in the bid.

Q.) Will we have to get Anchoring Inspections for each opening as we complete them with new materials?

A.) Yes. Inspections will be required.

The following *statement* was submitted by Smitty's Glass & Mirror.

The fixed openings have hollow boxes made of wood, which have become rotten, they are not structural. They have reinforced Header/Lintel. So the frame work alone for the fixed windows will be sufficient to pass wind load testing. The single windows in the kitchen are to have new window bucks up to code and shim space within code.

A.) No response.

END OF ADDENDUM NO. 1

This document must be signed by the bidder's authorized representative and permanently attached to the Bidder's Proposal (i.e. stapled) in its entirety. **Proposal submitted without Addendum and unsigned will be incomplete and will not be accepted.**

Name of Bidder : _____ Date: _____

By _____ Title: _____