



**ARLINGTON COUNTY, VIRGINIA
OFFICE OF THE PURCHASING AGENT**

INVITATION TO BID NO. 24-DES-ITB-532

ADDENDUM NO. 2

Arlington County Request for Proposals No. 24-DES-ITB-532 for Hazardous Material Storage Buildings received the following question:

Question 1. The dry chemical fire suppression system will be on 1 side and the exhaust and AC will be on the other side. You add 2' for overall dimensions on these because they stick off the building. Do I have to go down to a 26'W building to make this work?

Response: The container cannot exceed 30 feet (same answer we provided before), but any auxiliary equipment mounted on the exterior of the container may extend the final container size up to 34 feet.

The balance of the solicitation remains unchanged.

Arlington County, Virginia

Lucas Alexander, VCO, VCA
Procurement Officer

RETURN THIS PAGE, FULLY COMPLETED AND SIGNED, WITH YOUR BID:

BIDDER ACKNOWLEDGES RECEIPT OF ADDENDUM NUMBER 2.

FIRM NAME: _____

AUTHORIZED SIGNATURE: _____ **DATE:** _____