



St. Johns River Water Management District

Ann B. Shortelle, Ph.D., Executive Director

4049 Reid Street • P.O. Box 1429 • Palatka, FL 32178-1429 • 386-329-4500
On the internet at www.sjrwmd.com.

DATE: March 31, 2021
TO: Prospective Respondents
FROM: Gerald Cahalane, Assoc. Procurement Specialist
SUBJECT: Addendum #3 to Invitation for Bid #36618, Longleaf Pine Preserve Trail Road Improvements

This addendum is to answer pertinent questions posed by potential respondents.

The responses to this sealed Invitation for Bid are still due by no later than 2:00PM on, Wednesday, April 7, 2021. Please refer to the solicitation packet for submittal requirements.

Please see below for the questions and answers:

Question: *What grade of crushed concrete is preferred?*

Answer: Crushed concrete from 1 to 2½ inches.

Question: *What grade of Granite is preferred?*

Answer: Granite railroad ballast from 3 to 4 inches.