



City of Hanahan

1255 Yeamans Hall Road

Hanahan, SC 29410

Robyn Brown, Procurement and Project Coordinator
(843) 576-5254

TO: All Prospective Offerors
FROM: Procurement
RFQ #: COH# 9262023
RFQ TITLE: LED Lighting Mabeline Gym

ADDENDUM NUMBER 1 – October 6, 2023 – 1 PAGES

Acknowledge receipt of this addendum by inserting its number, date and signature in the space provided on the last page of the bid package, Proposal Transmittal and Agreement, for receipt of Addenda. Failure to do so may subject Proposer as non-responsive. This addendum should be attached to and become part of the Invitation for Bid.

Questions and Answers:

1. What is the wattage of existing fixtures? **400 Watts**
2. Can you provide an annual estimate of # of hours the lights are on? **10-12 hours per day.**
3. For the bid of the fixture replacement, would it be preferred the new LED fixture has an acrylic diffuser installed? **We prefer in the bid that the new LED lighting fixtures has an acrylic diffuser installed.**