



County of Georgetown, South Carolina

129 Screven Street, Suite 239 · Georgetown, SC 29440-3641
Post Office Box 421270, Georgetown, SC 29442-4200
(843)545-3083 · Fax (843)545-3500 · purch@gtcounty.org

ADDENDUM #1 TO BID #20-057

BID NUMBER: 20-057

ISSUE DATE: Friday, September 19, 2020

Bid Opening Location: Georgetown County Courthouse, Suite #239, (Purchasing Conference Room)

PROCUREMENT FOR: HVAC Improvements for Department of Social Services

This addendum will amend **BID # 20-057, HVAC Improvements for Department of Social Services** originally issued on Wednesday, September 2, 2020. This clarification is being provided to all known and registered correspondents in response to questions received. All addenda and original bid documents are also available online at: <http://www.gtcounty.org>, select Quick Links, “Bid Opportunities” and “Current Bids.”

Questions:

1. Who is responsible for concrete pad and fencing should we need more space for equipment outside?
The fencing would be taken down by the county if needed, refer to # 12 on the bid package.
2. Can we use console model indoor units like your existing units?
Yes we can use console models like our existing units.
3. Will remote condensate pumps be allowed for condensate removal?
We would prefer to use existing drains instead of condensate pumps.
4. Please confirm that you are requiring Heat Recovery Systems Not Heat Pumps Systems.
Yes we are requiring Heat Recovery Systems.
5. Will new HVAC System Controls need to connect to CMI Controls?
No
6. If you are not connecting to CMI please describe what you would like for your HVAC Controls.
We are not connecting to CMI at this time and would like hard wired thermostats for controls.



ADDENDUM ACKNOWLEDGEMENT
Bid # 20-057, HVAC Improvements for Department of Social Services
Mandatory Submittal Form

To be returned with the final proposal submission to Georgetown County.

COMPANY NAME: _____

- | | | |
|-------------------------------------|----------------------------------|---------------------|
| <input checked="" type="checkbox"/> | Addendum #1 Received Date: _____ | Initialed By: _____ |
| <input type="checkbox"/> | Addendum #2 Received Date: _____ | Initialed By: _____ |
| <input type="checkbox"/> | Addendum #3 Received Date: _____ | Initialed By: _____ |
| <input type="checkbox"/> | Addendum #4 Received Date: _____ | Initialed By: _____ |
| <input type="checkbox"/> | Addendum #5 Received Date: _____ | Initialed By: _____ |
| <input type="checkbox"/> | Addendum #6 Received Date: _____ | Initialed By: _____ |

If your Bid submission has already been mailed, acknowledgment may be provided by faxing this form to (843)545-3500, or attaching a digital scan and sending by e-mail.

[THE REMAINDER OF THIS PAGE IS INTENTIONALLY LEFT BLANK]