



**CITY OF CALLAWAY  
FIREGUARD FUEL TANK PURCHASE & INSTALLATION  
BID NO.: PW2021-14**

**ADDENDUM #1**

Date Issued: October 26, 2021

\*\*\*\*\*

This addendum is being released to provide for answers to the following:

1. **Correction of Bid deadline on Page 2 of the Bid Packet: The closing deadline for submission of bids is MONDAY, NOVEMBER 1, 2021.**
2. **A picture of the area of for the new tank is being provided and attached hereto.**
3. **Will existing conduit be used for the new fill rite pumps and will electrical need to be supplied?**  
**A. Final connection will be provided by a local Electrician using existing conduit. The new pumps wouldn't require any more power demands than our existing pumps.**
4. **How close is the Fuel Master to the dispensers?**  
**A. The Fuel Master System is located right next to the fence gate by the tank.**
5. **I'm assuming we are not supplying a slab and bollards, if required.**  
**A. Correct, to save on costs, City staff will be performing any site prep work needed.**

*Janice L. Peters*

Janice L. Peters, City Clerk

\*\*\*\*\*

This Addendum must be acknowledged and included with the bid packet submission.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date

