

Date 1/28/19



Front Street UG System Upgrade Project #1919
Pad-mounted Transformers
ADDENDUM I
Clarification of primary and secondary voltages.

Notice to bidders: the specifications have been revised per the following:

The primary system voltage is 12,470 V grounded wye / 7,200 V. There should be two H1 bushings for feed-thru application.

The secondary voltage should be 120 V / 240 V with three secondary bushings, IEEE Std C57.12.38 Type 2 arrangement.