

Date 1/30/19



Front Street UG System Upgrade Project #1919  
Pad-mounted Transformers  
ADDENDUM II  
Clarification of steel construction.

Notice to bidders: the specifications have been revised per the following:

Revise Section 5.1.6 to remove the mention of IEEE C57.12.29 as follows:

“Paint entire transformer assembly Munsell 7GY3.29/1.5 green. The Munsell color notation is specified in ASTM D 1535.”

Coastal Salt-Water construction is not required. The transformer should meet the requirements of IEEE C57.12.28 and IEEE C57.12.38.