



St. Johns River

Water Management District

Ann B. Shortelle, Ph.D., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940
On the internet at www.sjrwmd.com.

DATE: June 28, 2018
TO: Prospective Respondents
FROM: Amy Lucey, Contracts Administrator
SUBJECT: Addendum #1 to Invitation for Bids # 33320, Sawgrass Airboat Crossover Ramp

As a result of the Non-Mandatory Pre-Bid meeting held on June 28, 2018, the following clarifications/changes are provided for your information. Please make all appropriate changes to your bid documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

1. Marine Grade Pressure treated lumber needs to be 2.5 CCA
2. 16' tread boards are to be staggered.
3. Anchors for embedment boards are to be 1 every 2 feet
4. Anchors for tread boards are to be 2 per board every 2 feet
5. Page 34, Statement of Work, Task Identification, task 5 shall be modified as follows:
 - Install new 2"x 6"x 12' support timbers (approximate spacing 32-FT) using marine grade pressure treated lumber. Embed support timbers in concrete openings using 5/8"x 6" stainless steel concrete anchors with stainless washers. Anchors shall be countersunk into the lumber 1" inch in depth and void filled with wood grade neoprene/silicone sealant.

Additional Information:
Pre-bid Meeting Recording – separate file

NOTE: The Bid Opening remains 2:00 p.m., Thursday, July 12, 2018

Please acknowledge receipt of this Addendum on the **BID FORM** provided in the bid package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.

GOVERNING BOARD

John A. Miklos, CHAIRMAN
ORLANDO

Fred N. Roberts Jr., VICE CHAIRMAN
OCALA

Chuck Drake, SECRETARY
ORLANDO

Ron Howse, TREASURER
COCOA

Douglas C. Bournique
VERO BEACH

Douglas Burnett
ST. AUGUSTINE

Susan Dolan
SANFORD

Janet Price
FERNANDINA BEACH