



**ADDENDUM NO. 1  
SOUTH HILLS HIGH SCHOOL  
NORTH PARKING LOT ADA UPGRADE PROJECT RE-BID  
BID 22-23-102**

**November 2, 2022**

This Addendum forms a part of the Bid Documents and modifies the original Bid Documents. Acknowledge receipt of this Addendum in space provided on the Bid Proposal Form. Failure to acknowledge may subject Bidder to disqualification. Except as specifically modified by this Addendum, all other terms and conditions set forth in the Bid Documents remain in full force and effect.

**QUESTIONS AND CLARIFICATIONS:**

**Question:** Will the bidding contractor need to get a revised bid bond or will the one provided for the original bid suffice?

**Clarification:** The District requires a new bid bond.

**Question:** The plans call for optional railing in curb on two sides. Please inform the bidder if these are to be included in the base bid price or just bid the one side requestion railing?

**Clarification:** Include ALL noted railings in the base.

**Question:** Once the existing asphalt is removed is the contractor required to remove 12” of earth and recompact or just scarify the existing grade and compact then add base to new finish subgrade?

**Clarification:** Removal of 12” of dirt not required. Scarify existing grade, compact, add base over and compact to 95% to new finish grade.

**Question:** The last bid had no plan for measuring regarding the alternate, please provide qty of asphalt to be resealed also a linear total for crack fill. The last bid was a guessing game for the limits of work. Please advise?

**Clarification:** The re-bid stated for the contractor to field verify.

END OF ADDENDUM