



NOTES:

1. PROVIDE BREAKS IN REVEAL AS SHOWN ON PLANS TO ALLOW FOR SIDEWALK RUNOFF INTO STORMWATER MANAGEMENT FACILITY.
2. CONCRETE SHALL BE CLASS E; FINISH ALL EXPOSED CONCRETE SURFACES
3. HATCHED AREA MAY BE FILLED WITH CONCRETE OR STONE. IF FILLED WITH CONCRETE THEN BASE MAY BE REDUCED TO 15".
4. EXPANSION JOINTS SHALL BE PLACED AT MAXIMUM 90 FOOT INTERVAL. CONTRACTION JOINTS SHALL BE FORMED OR SAWED AT 30' MAXIMUM INTERVAL BETWEEN EXPANSION JOINTS. WHERE ADJACENT TO CURB, SIDEWALK OR CONCRETE PAVEMENT, JOINTS SHALL LINE UP.

EDGEWALL WITH RAISED CURB
(FOR BIORETENTION)