



Whitfield County Schools

1306 South Thornton Avenue, Dalton, Georgia 30721

wcsga.net • (706) 217-6780

tradition • purpose • excellence

Invitation to Bid

For

Orion Power Systems UPS

For The

Whitfield County Schools Purchasing Department

**1030 Hill Road
Dalton, GA 30721**

BID # WCS-IT-BD-2019-030

November 7, 2019

BID # WCS-PR-2019-XXX

INVITATION TO BID

Whitfield County Schools District invites sealed bids for the following:

Orion Power Systems UPS forVPM

(See Exhibit A for additional specifications)

Direct any questions regarding this bid to Tim Shaver, Director of Technology via email tim.shaver@wcsga.net no later than 2:00pm on December 2, 2019.

The Purchasing Department must receive the bids by **2:00pm on December 4, 2019**.

**Whitfield County School District
Purchasing Department
1030 Hill Road, Building A
Dalton, GA 30721**

Bids must be sealed and clearly marked as "**Bid Response WCS-IT-BD-2019-030**". Include 1 original and 2 copies.

Bids will be opened at **10:00 am December 6, 2019** at the same location.

Jim Fugate
Procurement Officer
Whitfield County School District

BID # WCS-PR-2019-XXX

BID SUBMISSION
Orion Power System UPS

Having also examined/understood the Products / Services specifications and requirements, the Undersigned hereby proposes to furnish all products, labor, equipment, tools, transportation, services, licenses, fees, permits, etc., required by said document to complete all divisions of the Products / Services stipulated above for the sum included below.

Respectfully submitted:

Contractor/Vendor (Company Name)

Representative (Name and title)

Telephone Number

Email Address

Signature

Business Address

Federal I.D. Number

_____ (Dollars) for Products / Services rendered.

Whitfield County Schools understands billing will be due for the full amount of the Products / Services upon delivery, completion, and signed off on by **Technology Director**.

EXHIBIT A
Additional Work/Product Specifications
Orion Power Systems

- -(1) 30U enclosure
- -(1) Rear 3 breaker maintenance bypass switch intact to enclosure
- -(2) 20Kva power modules to provide N+1 redundancy.
- -(8) batter modules/ each module consisting of (10) 12V9AH CSB lead acid batteries total of (80) 12V9AH CSB lead acid batteries
- SNMP card for network monitoring Compatible for MSR20K, MSR40K, or MSR60K Part #OPS-SNMP4
- Onsite Startup service for the MSR Series (provided by trained factory service contractor) Part #OPS-OSS-MSR
- - 5.7 inch LCD display
- -Modular design to allows fast and easy repair and maintenance.
- -+/- 1% voltage regulation with Pure Sine Wave Output
- -12 Month Warranty included standard
- One-year service contract including one annual major preventive maintenance visit performed.(price for both) 8x5 & 24x7 (provided by trained factory service contractor) Part #OPS-OAC-24x7, OPS-OAC-5x8
- Two (2) Year On-Site Gold Plan Part #OPS-2YROAC-MSR