

OFFICE OF THE SULLIVAN COUNTY PURCHASING AGENT
3411 HIGHWAY 126 – SUITE 201
BLOUNTVILLE, TN 37617-0569

KRISTINIA DAVIS
PURCHASING AGENT

PHONE 423/323-6400

FAX 423/323-7249

Kris.davis@sullivancountytn.gov

ADDENDUM-1

RFP: 2014802(KD)

Re: Sullivan South High Parking Lot Replacement Lighting

February 14, 2020

This Addendum is part of the RFP Documents for the above referenced project and modifies the original documents. It is issued to answer questions that have been submitted as of 2/13/2020.

1. No Mfr. Cat # is identified.
2. Lights to be based on level III, 5000k minimum, 200w, preference of 5 foot candles. The current lights are HPS, 150 watt.
3. Poles are square tapered approximately 3” at the top and approximately 35’ in height. One pole has a single head and the remaining are double. All are located on paved areas, none are located on public roads.
4. Completion of Work: Dependent when bid is awarded and successful bidder can secure materials, school will be closed the week of March 16 for spring break. Completion to be done by May 10 for graduation. School department can make provisions to allow work any day.
5. One (1) photo cell controls all lights.
6. Applied voltage to the existing fixtures is 480.
7. No CAD drawings are available, current lighting is 40 years old, original to the property and cannot verify if poles were placed according to original drawings.

END OF ADDENDUM #1