



ADDENDUM NO. 1

FEBRUARY 9, 2021

PROJECT: HVAC Project at Various Locations
20-21-114

The clarifications, modifications, changes, additions, and/or deletions contained herein shall be incorporated within the construction documents for the project. Such information shall take precedence over that previously published.

QUESTIONS AND CLARIFICATIONS:

Question: The equipment brand and model numbers were specified for each installation. Is this specification firm or can we use other brand units equal to the ones you have specified?

Clarification: Per the bid documents and the job walk handout, "Substitution requests must be turned in with the bid on the form provided in the bid documents. Contractor must be willing to move forward with materials specified in the bid documents if the substitution request is denied". If Substitution Request Form is not submitted, then NO Substitutions will be allowed after the bids are opened.

Question: We need clarification concerning the Las Palmas Middle School AC replacement at room 17. The specification states to replace the 5-ton bard with a 4-ton bard. Just need to know if this is the case or an error.

Clarification: This is not an error. We want to replace the 5-ton Bard with a 4-ton Bard at Las Palmas Middle School room 17.

END OF DOCUMENT