

TECHNICAL SPECIFICATIONS

The technical specifications for this project include the City of Aztec Construction Standards, available at <http://www.aztecnm.gov/construction/standards.html>, as well as any project specifications included on the drawings and in this Technical Specifications section. In the event of conflict between the requirements, the more stringent shall apply.



TABLE OF CONTENTS

I. Technical Specifications

1. Section 01 00 00 – Basic Requirements
2. Section 03 05 00 – Basic Concrete Materials and Methods
3. Section 31 10 00 – Site Clearing
4. Section 31 22 13 – Rough Grading
5. Section 31 23 17 – Trenching
6. Section 31 23 18 – Rock Removal
7. Section 31 23 23 – Backfill
8. Section 33 01 32 – Sewer and Manhole Testing
9. Section 33 05 23.16 – Trenchless Utility Installation
10. Section 33 31 00 – Sanitary Sewer Systems
11. Section 33 39 13 – Precast Concrete Manholes

II. Exhibits

- A. Terracon Consultants, Inc., “Aztec Arterial Route 550 South Project”, August 28, 2008.
- B. New Mexico Division of Transportation Application for Permit to Install Utility Facilities Within Public Right of Way.

SECTION 01 00 00
BASIC REQUIREMENTS

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Summary:
 - 1.2: Contract description.
 - 1.3: Special considerations.
 - 1.4: Work by Owner.
 - 1.5: Contractor's use of premises.
 - 1.6: Specification conventions.
 - 1.7: Minimum wage rate determination.

- B. Price and Payment Procedures:
 - 1.8: Testing and inspection allowances.
 - 1.9: Schedule of values.
 - 1.10: Applications for payment.
 - 1.11: Change procedures.
 - 1.12: Unit prices.
 - 1.13: Alternates.

- C. Administrative Requirements:
 - 1.14: Coordination.
 - 1.15: Suspension of Work.
 - 1.16: Field engineering.
 - 1.17: Pre-Construction Conference.
 - 1.18: Progress meetings.
 - 1.19: Cutting and patching.

- D. Submittals:
 - 1.20: Submittal procedures.
 - 1.21: Construction progress schedules.
 - 1.22: Proposed products list.
 - 1.23: Product data.
 - 1.24: Shop drawings.
 - 1.25: Test reports.
 - 1.26: Manufacturer's instructions and certificates.

- E. Quality Requirements:
 - 1.27: Quality control.
 - 1.28: Tolerances.
 - 1.29: References.
 - 1.30: Manufacturer's field services and reports.
 - 1.31: Examination.

- F. Temporary Facilities and Controls:
 - 1.32: Temporary services.
 - 1.33: Access roads.
 - 1.34: Progress cleaning and waste removal.
 - 1.35: Project identification.
 - 1.36: Barriers and fencing.
 - 1.37: Protection of installed work.
 - 1.38: Security.
 - 1.39: Water control.
 - 1.40: Pollution and environmental control.
 - 1.41: Removal of utilities, facilities, and controls.

- G. Product Requirements:
 - 1.42: Products.
 - 1.43: Delivery, handling, storage, and protection.
 - 1.44: Substitutions.

- H. Execution Requirements:
 - 1.45: Closeout procedures.
 - 1.46: Final cleaning.
 - 1.47: Starting of systems.
 - 1.48: Demonstration and instructions.
 - 1.49: Testing, adjusting and balancing.
 - 1.50: Protecting installed construction.
 - 1.51: Project record documents.
 - 1.52: Operation and maintenance data.
 - 1.53: Spare parts and maintenance materials.
 - 1.54: Warranties.

1.2 CONTRACT DESCRIPTION

- A. Work of the Project includes connecting two sanitary sewer collection lines in Aztec, NM. The work includes installation of approximately 321 feet of 12” sewer pipe with 160 feet of the pipe installed within a 24” steel casing bored under US Highway 550. One new 4’ diameter manhole will be installed and two existing 4’ diameter manholes will be tapped. Traffic and erosion control will be required.

- B. Perform Work of Contract under a stipulated price basis with Owner in accordance with Conditions of Contract.

1.3 SPECIAL CONSIDERATIONS

- A. Contractor is advised that the Arterial Route Geotechnical Report (Terracon Consultants, Inc., “Aztec Arterial Route 550 South Project”, August 28, 2008) indicates the presence of sandstone rock near the Project. See Exhibit A.

- B. Ground surfaces shall be restored to their original condition by grading and seeding with native plant species.

- C. Should nesting of a species protected under the Migratory Bird Treaty Act be identified in the construction zone, construction will be limited to a time of year outside the general migratory bird nesting season of March through August, avoided until nesting is complete, or the nest will be relocated by a properly trained and authorized expert.
- D. The length of trench left open overnight will be minimized and, should a trench be left open, a ramp will be maintained to allow the escape of trapped animals. Any excavation within the highway right-of-way left open overnight must be protected per NMDOT permit requirements.
- E. Contractor is advised that some tree clearing may be required to install piping. No additional pay item is included. Contractor will include this in the cost of pipeline installation.
- F. Contractor must provide water for construction at the Contractor's expense.
- G. Prior to beginning construction activities, the Contractor must furnish full-coverage video documentation of the entire construction site. The video must include coverage of all areas and adjacent features that may potentially be impacted by the impending construction work. Contractor must submit two (2) copies of the video documentation on DVD format as part of the submittal process.
- H. Contractor shall prepare record drawing information under the direction of a Licensed Professional Surveyor. Refer to Article 1.51 Project Record Documents below and General Notes on the Drawings for specific requirements related to As-Built Drawings.
- I. Contractor shall coordinate with Owner for tie-in to existing sanitary sewer system. Contractor shall notify Owner prior to performing the respective activities.
- J. Contractor must maintain a full set of Drawings and Technical Specifications at the construction site at all times throughout the construction process. All subcontractors must possess at least all Drawings and Technical Specifications pertaining to their portion of the work while on the construction site at all times.

1.4 WORK BY OWNER

Not Used.

1.5 CONTRACTOR'S USE OF PREMISES

- A. No work shall be done before 7:00 A.M. or after 7:00 P.M. local time on a working day, on Sundays, or on legal holidays, except as necessary for the proper care and protection of work already performed, or during emergencies.
- B. The Contractor shall make every effort to minimize noise caused by his operations. Equipment shall be equipped with silencers or mufflers designed to operate with the least possible noise.

- C. The Contractor shall restrict his operations as nearly as possible to the immediate site. Unnecessary cutting of vegetation adjacent to the site is prohibited. Every effort shall be made to minimize erosion during and after construction and the site shall be returned to its original condition, except where improvements are indicated or required.
- D. The Contractor shall take affirmative action to prevent the misuse of the natural environment, wasting of natural resources, or destruction of natural values.
- E. The Contractor shall conform to all requirements set forth in the latest edition of the New Mexico Standard Specifications for Public Works Construction with latest revision, and Occupational Safety and Health Administration Regulations for trenching, shoring and excavation, and all other activities where such regulations apply. The Contractor and all subcontractors shall conduct all activities in conformance with federal and state laws and regulations relating to occupational health and safety. Authorized inspectors from NMED's Occupational Health and Safety Bureau shall have unobstructed access to project sites and shall not be impeded in any way from performance of their duties.

1.6 SPECIFICATION CONVENTIONS

- A. These specifications are written in imperative mood and streamlined form. This imperative language is directed to the Contractor, unless specifically noted otherwise. The words "shall be" are included by inference where a colon (:) is used within sentences or phrases.
- B. The Contractor shall furnish all materials, labor, plant and equipment necessary to complete the contract work as called for by the Technical Specifications and as indicated on the Drawings. Material and work, either expressed or implied, necessary for the satisfactory completion of the contract work shall be considered an integral part thereof.

- C. All standards incorporated herein by reference shall be the latest edition, unless otherwise specified. The abbreviations and applicable standards are described below:

AASHTO	American Association of State Highway and Transportation Officials
ACI	American Concrete Institute
AIA	American Institute of Architects
ANSI	American National Standards Institute, Inc.
ASTM	American Society for Testing and Materials
AWS	American Welding Society
AWWA	American Water Works Association
CID	Construction Industries Division of the NM Regulation and Licensing Department
EJCDC	Engineers Joint Contract Documents Committee
EPA	Environmental Protection Agency
IBC	International Building Code
ISO	International Organization for Standardization
MSJC	Masonry Standards Joint Committee
NACE	National Association of Corrosion Engineers
NMDOT	New Mexico Department of Transportation
NMED	New Mexico Department of Environment
NMSSPWC	New Mexico Standard Specifications for Public Works Construction
NSF	National Sanitation Foundation
OSHA	Occupational Safety and Health Administration
SAE	Society of Automotive Engineers
SSPC	Steel Structure Painting Council
UL	Underwriters Laboratories, Inc.

1.7 MINIMUM WAGE RATE DETERMINATION

- A. Article 13-4-11, NMSA, 1978, requires that prevailing local wages be determined by labor category, and that this prevailing wage be the minimum acceptable pay rate. The Public Works Minimum Wage Act covers all public works construction, alteration, demolition, or repair projects when the project cost is \$60,000 or more, and when the state or any political subdivision is a party. The wage rate determination provided by the New Mexico Department of Workforce Solutions for the present project can be found in an appendix to the Contract Documents.
- B. The Contractor warrants and agrees that he and all subcontractors shall comply with all applicable provisions of the New Mexico Public Works Minimum Wage Act and other statutes pertaining to public works in New Mexico; and the Federal Wage Rate Determination. The Minimum Wage Rate Determinations can be found in an appendix to the Contract Documents.
- C. Applicable federal and state regulations require that the higher of the federal or the state wage rate for each classification must be paid.

1.8 TESTING AND INSPECTION ALLOWANCES

- A. No allowances. Testing and inspection shall be included in Contractor prices.

1.9 SCHEDULE OF VALUES

- A. Submit schedule of values on the Construction Progress sheet within the Application for Payment forms provided in the Construction Contract Documents Progress Estimate sheet within the Application for Payment forms (EJCDC Form C-620 (2013 Edition)), or on other form acceptable to the Owner. Contractor's standard form or electronic media printout will be considered.
- B. Base structure of Schedule of Values on Bid Schedule with identical item numbering, quantities, and values.
- C. Submit Schedule of Values in duplicate at least 15 days prior to first Progress Meeting.

1.10 APPLICATIONS FOR PAYMENT

- A. Application for Payment is synonymous with Partial Payment Estimate.
- B. Submit four [4] copies of each application on the Partial Payment Estimate form provided in the Contract Documents, together with updated Schedule of Values identifying fully the list of items in the Application for Payment.
- C. The Partial Payment Estimate forms consist of four sections: Cover Sheet, Construction Progress spreadsheet, Materials-On-Hand form, and Monthly Construction Progress

Certificate. The purpose of the Monthly Construction Progress Certificate is to provide a complete account of all change orders/claims for the corresponding contract period, and all outstanding change orders/claims from previous contract periods and waives any rights to further adjustments in contract times or price for any change orders/claims that originated in the current contract period.

- D. Payment Period: Monthly, however payment may not be made until 45 days after receipt of the bill for portions of the Work to be paid for with State funding.

1.11 CHANGE PROCEDURES

- A. All Change Orders shall be prepared on the form provided in these Contract Documents.
- B. Unit Price Change Order: For pre-determined unit prices and quantities, Change Order will be executed on fixed unit price basis. For unit costs or quantities of units of work not pre-determined, refer to Article 12 - Change of Contract Price; Change of Contract Times, of the Standard General Conditions (EJCDC C-700 Standard General Conditions of the Construction Contract).
- B. The Contract Price may only be changed by a Change Order. Any Claim for an adjustment in the Contract Price shall be based on written notice submitted by the party making the Claim to the Owner and the other party to the Contract.
- C. The value of any Work covered by a Change Order or of any Claim for an adjustment in the Contract Price will be determined as follows:
 - 1. where the Work involved is covered by unit prices contained in the Contract Documents, by application of such unit prices to the quantities of the items involved; or
 - 2. where the Work involved is not covered by unit prices contained in the Contract Documents, by a mutually agreed lump sum (which may include an allowance for overhead and profit not necessarily in accordance with Article 1.11.D.2); or
 - 3. where the Work involved is not covered by unit prices contained in the Contract Documents and agreement to a lump sum is not reached under Article 1.11.C.2, on the basis of the Cost of the Work plus a Contractor's fee for overhead and profit (determined as provided in Article 1.11.D).
- D. Contractor's Fee: The Contractor's fee for overhead and profit shall be determined as follows:
 - 1. a mutually acceptable fixed fee; or
 - 2. if a fixed fee is not agreed upon, then a fee based on the following percentages of the various portions of the Cost of the Work:
 - a. for actual and accountable costs incurred, the Contractor's fee shall be 15 percent;
 - b. for subcontractor costs, the Contractor's fee shall be five percent;
 - c. where one or more tiers of subcontracts are on the basis of Cost of the Work plus a fee and no fixed fee is agreed upon, the intent of Article 1.11.D.2.a is that the Subcontractor who actually performs the Work, at whatever tier, will be paid a fee of 15 percent of the actual and accountable costs incurred by such Subcontractor and that any higher tier

- Subcontractor and Contractor will each be paid a fee of five percent of the amount paid to the next lower tier Subcontractor;
- d. the amount of credit to be allowed by Contractor to Owner for any change which results in a net decrease in cost will be the amount of the actual net decrease in cost plus a deduction in Contractor's fee by an amount equal to five percent of such net decrease; and
 - e. when both additions and credits are involved in any one change, the adjustment in Contractor's fee shall be computed on the basis of the net change in accordance with Articles 1.11.D.2.a through 1.11.D.2.d, inclusive.

1.12 UNIT PRICES

- A. Owner will take measurements and compute quantities accordingly. The Contractor will assist in taking of measurements and determination of work completed prior to preparation of corresponding Application for Payment.

1.13 ALTERNATES

- A. Alternates quoted on Bid Forms will be reviewed and accepted or rejected at Owner's option.

1.14 COORDINATION

- A. Coordinate scheduling, submittals, and Work of various sections of specifications to ensure efficient and orderly sequence of installation of interdependent construction elements.
- B. Verify utility requirement characteristics of operating equipment are compatible with building utilities.
- C. A Traffic Control Plan (TCP) has been submitted to NMDOT. If Contractor elects to provide an alternative TCP, Contractor must submit the TCP to Owner and NMDOT for approval before continuing with the project.
 - 1. All existing signs, markers, delineators, etc. within the construction limits shall be removed, stored, and reset.
 - 2. Subject to the approved TCP, at least one lane shall be open to traffic at all times. Provide proper signage to maintain the traffic lane in such a manner as to assure proper safety to the traveling public on all affected roads. Provide access to all private and public property at all times except when grading, excavation and backfill operations are being conducted immediately in front of the property, in which case access will not be denied for more than 4 hours without approval from the Owner.
 - 3. Traffic lanes provided during construction shall be maintained in such a condition under all weather conditions, so as to permit the reasonable passage of passenger vehicles, and shall be kept graded and smooth and watered several times daily, as needed, to control dust.

- D. Obtain all applicable permits from the NMDOT before boring under any roadways or working along or across NMDOT rights-of-way, unless the permits have already been obtained by the Owner. The Contractor is also responsible for obtaining all applicable local, county and state building and development permits not previously obtained by Owner. This includes permits from the Construction Industries Division of the Regulation and Licensing Department of the State of New Mexico, and any other regulatory agency having jurisdiction.
- E. Contractor is responsible for timely scheduling of any pertinent inspections with local, county and state agencies with jurisdiction, and as required by the permits.
- F. Coordinate space requirements and installation of mechanical and electrical work indicated diagrammatically on Drawings. Follow routing shown for pipes, ducts, and conduit, as closely as practicable.
- G. All notices, demands, requests, instructions, approvals, proposals and claims must be in writing.
 - 1. Any notice to or demand upon the Contractor shall be sufficiently given if delivered at the office of the Contractor stated on the signature page of the Agreement.
 - 2. All papers required to be delivered to the Owner shall, unless otherwise specified in writing to the Contractor, be delivered to the Owner at the address stated on the signature page of the Agreement.
 - 3. Any such notice shall be deemed to have been given as of the time of actual delivery, in the case of mailing, when the same should have been received in due course of post, or in the case of telegrams, certified mail, or telephone facsimiles, at the time of actual receipt as the case may be.

1.15 SUSPENSION OF WORK

- A. The Owner may order suspension of work due to seasonal or other conditions unsuitable for construction work.
- B. Maintenance during suspension: Prior to suspension for any cause, the Contractor shall take necessary precautions to protect the work during the period of suspension from any factors which would contribute to its deterioration.
- C. Time elapsed during suspension of the work shall not count as contract time. The Contractor shall make no claim for damages due to delay, additional mobilization charges, nor any additional costs that may be incurred solely due to suspension of work.
- D. Requests for additional time to be added after the “contract completion date” due to delays or extra work shall be made to the Owner in writing by the Contractor within ten (10) days after the time of the occurrence of the delay or receipt of a Change Order for extra work. Such requests shall set forth the justification for the additional time.
- E. Upon approval, the additional contract time shall then be in full force and effect, the same as though it were the original date for completion, and will be shown as the completion date plus an amount of additional working days. Any time required to complete the work

beyond the contract time or additional contract time will result in the assessment of liquidated damages, as specified in the Contract Documents. Failure to make such requests within the above limits will be considered as a waiver on the part of the Contractor as to the need for additional contract time.

1.16 FIELD ENGINEERING

- A. Establish elevations, lines, and levels and certify and confirm elevations and locations of the Work, conforming with the Contract Documents, with the Owner prior to performing any excavation.
- B. Verify field measurements are as indicated on shop drawings or as instructed by manufacturer.
- C. From the information provided by the Owner, the Contractor shall develop and make all detail surveys needed for construction such as slope stakes, batter boards, easement alignments, stakes for pipe locations and other working points, lines, elevations and cut sheets.

1.17 PRE-CONSTRUCTION CONFERENCE

- A. Owner will schedule Pre-Construction Conference after Notice of Award for affected parties.
- B. The Contractor, or his duly authorized representative, and subcontractor representatives will attend the meeting.

1.18 PROGRESS MEETINGS

- A. Schedule in coordination with the Owner at maximum monthly intervals and attend all Progress Meetings throughout progress of the Work.
- B. The purpose of the meetings will be to review the following:
 - 1. Work progress since previous meetings.
 - 2. Field observations, problems, conflicts.
 - 3. Problems which impede construction schedule.
 - 4. Corrective measures and procedures to regain projected schedule.
 - 5. Revisions to construction schedule.
 - 6. Plan progress and schedule during succeeding work period.
 - 7. Coordination of schedules.
 - 8. Off-site fabrication and delivery schedules.
 - 9. Maintenance of quality standards.
 - 10. Proposed changes, construction schedule and completion date.
 - 11. Coordination of separate contracts.
 - 12. Record or "as-built" drawings of completed work.
 - 13. Other business as required.
 - 14. Regulatory requirements including OSHA, New Mexico Board of Labor, and others as applicable.

- 15. Funding requirements including RUS, NMED, NMFA, DFA, USEPA and others as applicable.
- C. During each meeting, the Contractor is required to present any issues which may impact his Work, with a plan to resolve these issues expeditiously.
- D. Together with each payment application, Contractor must present the current as-built drawings reflecting all work performed to date.

1.19 CUTTING AND PATCHING

- A. Employ skilled and experienced installer to perform cutting and patching new Work; restore Work with new Products.
- B. Execute cutting, fitting, and patching, including excavation and fill, to complete Work, and to:
 - 1. Uncover Work to install or correct ill-timed Work.
 - 2. Remove and replace defective and non-conforming Work.
 - 3. Remove samples of installed Work for testing.
 - 4. Provide openings in elements of Work for penetration of mechanical and electrical Work.
- C. Cut masonry and concrete materials using masonry saw or core drill. Restore Work with new Products in accordance with requirements of Contract Documents.
- D. Fit Work tight to adjacent elements. Maintain integrity of wall, ceiling, or floor construction; completely seal voids.
- E. Refinish surfaces to match adjacent finishes.

1.20 SUBMITTAL PROCEDURES

- A. Identify Project, Contractor, subcontractor and supplier; pertinent drawing and detail number, and specification section number, appropriate to submittal.
- B. Apply Contractor's stamp, signed or initialed, certifying that review, verification of Products required, field dimensions and elevations, adjacent construction Work, and coordination of information is in accordance with requirements of the Work and Contract Documents.
- C. Identify variations from Contract Documents and Product or system limitations which may be detrimental to successful performance of completed Work.
- D. Revise and resubmit submittals as required by the Owner; identify changes made since previous submittal.
- E. Submit number of copies Contractor requires, plus two copies Owner will retain, at a minimum, unless otherwise indicated at the Pre-Construction Conference.

- F. Transmit each submittal with Owner accepted form.
- G. Distribute copies of reviewed submittals as appropriate. Instruct parties to promptly report inability to comply with requirements.
- H. Prior to commencing construction activities, Contractor must submit a safety plan for approval by Owner.

1.21 CONSTRUCTION PROGRESS SCHEDULES

- A. Submit initial progress schedule in duplicate within fifteen [15] days after date of Owner-Contractor Agreement for Owner review.
- B. Submit revised schedules with each Application for Payment, identifying changes since previous version. Indicate estimated percentage of completion for each item of Work at each submission.
- C. Distribute copies of reviewed schedules to Project site file, subcontractors, suppliers, and other concerned parties.
- D. Show complete sequence of construction by activity, identifying Work of separate stages and other logically grouped activities. Indicate early and late start, early and late finish, float dates, and duration.
- E. Indicate delivery dates for Owner furnished products and products identified under Allowances.

1.22 PROPOSED PRODUCTS LIST

- A. Unless required as an attachment to Bid, within 15 days after date of Owner-Contractor Agreement, submit list of major products proposed for use, with name of manufacturer, trade name, and model number of each product.
- B. For products specified only by reference standards, give manufacturer, trade name, model or catalog designation, and reference standards.

1.23 PRODUCT DATA

- A. Product Data: Submit to Owner for review for limited purpose of checking for conformance with information given and design concept expressed in Contract Documents.
- B. Submit copies and distribute in accordance with Submittal Procedures article.
- C. Mark each copy to identify applicable products, models, options, and other data. Supplement manufacturers' standard data to provide information specific to this Project.
- D. Indicate product utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.

1.24 SHOP DRAWINGS

- A. Shop Drawings:
 - 1. Submitted to Owner for review for limited purpose of checking for conformance with information given and design concept expressed in Contract Documents.
 - 2. Include detail design calculations, shop drawings, fabrication, and installation drawings, erection drawings, list, graphs, catalog sheets, data sheets, and similar items.
 - 3. Design calculations shall bear the signature and seal of an engineer registered in the appropriate branch and in the state wherein the project is to be built, unless otherwise directed.
 - 4. After review, provide copies and distribute in accordance with Submittal Procedures article and for record documents purposes as specified.
 - 5. Except as may otherwise be indicated herein, the Owner will return copies of each submittal to the Contractor with comments noted thereon, within 30 calendar days following their receipt by the Owner.
- B. Indicate special utility and electrical characteristics, utility connection requirements, and location of utility outlets for service for functional equipment and appliances.
- C. Submit number of opaque reproductions Contractor requires, plus two copies Owner will retain.

1.25 TEST REPORTS

- A. Submit for Owner's knowledge as contract administrator or for Owner.
- B. Submit test reports for information for limited purpose of assessing conformance with information given and design concept expressed in Contract Documents.

1.26 MANUFACTURER'S INSTRUCTIONS AND CERTIFICATES

- A. When specified in individual specification sections, submit manufacturer printed instructions for delivery, storage, assembly, installation, start-up, adjusting, and finishing, to Owner in quantities specified for Product Data.
- B. Indicate special procedures, perimeter conditions requiring special attention, and special environmental criteria required for application or installation.
- C. When specified in individual specifications sections, submit certifications by manufacturer to Owner, in quantities specified for Product Data.
- D. Indicate material or Product conforms to or exceeds specified requirements. Submit supporting reference data, affidavits, and certifications as appropriate.
- E. Certificates may be recent or previous test results on material or Product, but must be acceptable to Owner.

1.27 QUALITY CONTROL

- A. Monitor quality control over suppliers, manufacturers, products, services, site conditions, and workmanship, to produce Work of specified quality.
- B. Comply with manufacturer's instructions.
- C. Comply with specified standards as minimum quality for the Work except when more stringent tolerances, codes, or specified requirements indicate higher standards or more precise workmanship.

1.28 TOLERANCES

- A. Horizontal and vertical deviations for pipe installation shall be limited by requirements for meeting all testing requirements in Section 33 01 32 – Sewer and Manhole Testing. Pipe must be installed at inverts designated in Drawings.
- B. Minimum Vertical Clearance from Other Utilities: 24 inches unless specified otherwise in Drawings.
- C. Where sewer and water must cross, pipes shall cross perpendicularly. Where sewer and water must cross with less than 24" clearance OR where water crosses below sewer, sewer pipe shall be encased per Drawings for 10 feet in both directions. Minimum vertical clearance between water and sewer shall be 12".
- D. Minimum Horizontal Clearance from Other Utilities: 10 feet unless specified otherwise in Drawings.
- E. Where sewer must be installed less than 10 feet horizontally from water and sewer is not at least 24" below water, sewer pipe shall be encased per Drawings.
- F. Monitor fabrication and installation tolerance control of installed products over suppliers, manufacturers, products, site conditions, and workmanship, to produce acceptable Work. Do not permit tolerances to accumulate.
- G. Comply fully with manufacturer's tolerances.

1.29 REFERENCES

- A. Geotechnical Report
 - 1. Terracon Consultants, Inc., "Aztec Arterial Route 550 South Project", August 28, 2008. See Exhibit A.
- B. Conform to reference standards by date of issue current as of date of Contract Documents.
- C. When specified reference standard conflict with Contract Documents, request clarification from Owner before proceeding.

1.30 MANUFACTURER'S FIELD SERVICES AND REPORTS

- A. When specified in individual specification sections, require material or product suppliers or manufacturers to furnish qualified staff personnel to observe site conditions and to initiate instructions when necessary.
- B. Report observations and site decisions or instructions that are supplemental or contrary to manufacturer's written instructions.

1.31 EXAMINATION

- A. Verify existing site conditions and substrate surfaces are acceptable for subsequent Work. Beginning new Work means acceptance of existing conditions.
- B. Verify utility services are available, of correct characteristics, and in correct location.
- C. Contractor is solely responsible for utility location, protection and verification. Contractor must notify New Mexico One Call System Inc., at 811, and all local utility providers, three (3) days before starting utility line construction.
- D. It shall be the responsibility of the Contractor to become acquainted with the location of all underground structures which may be encountered or which may affect the Work hereunder.

1.32 TEMPORARY SERVICES

- A. Provide, maintain and pay for suitable quality water service as required.
- B. Maintain uninterrupted water, sewer, and electric service to all properties adjoining the Work, except where specifically approved by the authority having jurisdiction. Services damaged by the Contractor shall be immediately and permanently repaired or replaced at the expense of the Contractor. Give a minimum of 48-hour advance notice to occupants of adjacent properties before interrupting any service. Any interruption of service shall be kept to the minimum length of time possible.
- C. Until final inspection and approval of the Work and issuance of the Certificate of Substantial Completion, the Contractor is responsible for all Work directly or indirectly affected by the Contractor's activities. Such responsibility continues for all Work detailed on the punch list that may accompany the Certificate of Substantial Completion, until satisfactorily completed by the Contractor and approved by the Owner.
- D. Furnish, install and maintain any temporary water storage structures, electrical connections, meters, wiring, outlets, switches, lamps, etc., as necessary for the work. The Contractor shall provide such temporary heat as may be necessary for the prevention of injury to the work or material through dampness or cold. All temporary connections, installations, facilities and supplies furnished or installed as specified in this paragraph, shall be removed prior to the completion of the Contract, and the premises left perfectly clean and satisfactory to the Owner.

- E. Maintain ambient temperature above freezing in enclosed/occupied areas where construction is in progress, unless indicated otherwise in specifications.
- F. Provide temporary electricity and power outlets for construction operations, connections, branch wiring, distribution boxes, and flexible power cords as required. Do not disrupt Owner's need for continuous service.
- G. Provide and maintain required sanitary facilities and enclosures in clean and sanitary condition.

1.33 ACCESS ROADS

- A. Construct and maintain temporary roads accessing public thoroughfares to serve construction area.
- B. Existing on-site roads, designated by the Owner, may be used for construction traffic.

1.34 PROGRESS CLEANING AND WASTE REMOVAL

- A. Collect and maintain areas free of waste materials, debris, and rubbish. Maintain site in clean and orderly condition.
- B. Remove waste and surplus materials, rubbish, and construction facilities from site. Restore all job sites and adjoining areas, including roads and driveways, to a condition equal to or better than the original status. Special attention will be made to not disturb unimproved roads by placing any excavated material to the sides of these roads when water lines are located along the right-of-way.
- C. Brush and trees shall be felled parallel to the right-of-way to minimize damage to trees and structures on adjacent property. All brush, tree tops, stumps and other debris shall be removed from the right-of-way and disposed of by the Contractor, subject to and in conformity with the special provisions applying to the tract of land involved (if any). The Contractor shall not destroy nor remove any trees, shrubbery, nor any other improvements, without permission of the Owner.
- D. The Contractor shall not dispose of debris, refuse or sanitary wastes in an open dump or in a natural watercourse, whether on public or private property, or in such places that undesirable wastes can eventually be exposed or carried to a natural watercourse.

1.35 PROJECT IDENTIFICATION

Not used.

1.36 BARRIERS AND FENCING

- A. Provide barriers or fencing to prevent unauthorized entry to construction areas and to protect existing facilities and adjacent properties from damage.

1.37 PROTECTION OF INSTALLED WORK

- A. Protect installed Work and provide special protection where specified in individual specification sections.

1.38 SECURITY

- A. Provide security and facilities to protect Work and existing facilities, and Owner's operations from unauthorized entry, vandalism, or theft.

1.39 WATER CONTROL

- A. Provide erosion control.
- B. Maintain excavations free of water. Provide, operate, and maintain pumping equipment.
- C. In the event that one acre of earth or more is disturbed, the Contractor shall submit to the Owner's Representative a Storm Water Pollution Prevention Plan (SWPPP) that will address all construction phases and the proposed pollution prevention and sediment control measures. This shall be done in accordance with the National Pollution Discharge Elimination System (NPDES) general permit requirements for all construction activities, and shall include all required reporting. If the Bid Form does not include an item for preparation and implementation of the SWPPP, the cost thereof will be considered incidental to related work.
- D. The Contractor shall conduct his operations to minimize damage to natural watercourses, and shall not permit petroleum products, volatile fluid wastes, or any other wastes which are prohibited by local ordinances, or excessive amounts of silt, clay, or mud to enter any drainage system. The bed of natural watercourses or man-made irrigation ditches shall be restored to normal gradient and cross-section after being disturbed.

1.40 POLLUTION AND ENVIRONMENTAL CONTROL

- A. Provide methods, means, and facilities to prevent contamination of soil, water, and atmosphere from discharge of noxious, toxic substances, and pollutants produced by construction operations.
- B. Provide dust control, erosion and sediment control, noise control, pest control and rodent control to allow for proper execution of the Work. Short term effects of dust produced by equipment will be mitigated by sprinkling traffic areas with water. Motor equipment shall be kept in repair and equipped with anti-pollution devices, if possible, to cut down on exhaust emissions. Burning as a method of cleaning or disposal will not be permitted without approval of the proper authorities.
- C. Comply with all applicable standards, orders, or regulations issued pursuant to the Clean Air Act of 1970 (42 U.S.C. 1251 et seq.) as amended. Violations shall be reported to the New Mexico Environment Department.

- D. The Contractor shall be responsible for the reporting and the cleanup of spills associated with project construction and shall report and respond to spills of hazardous materials such as gasoline, diesel, motor oil, solvents, chemicals, toxic and corrosive substances, and other materials which may be a threat to the public health or the environment. The Contractor shall be responsible for reporting past spills encountered during construction and of current spills not associated with construction. Reports shall be made to the New Mexico Environment Department Emergency Response Team at (505) 827-4308 or (505) 470-3657 and to the Owner's Representative. The Contractor shall clean up any unreported spills associated with project construction identified after construction.

1.41 REMOVAL OF UTILITIES, FACILITIES, AND CONTROLS

- A. Remove temporary utilities, equipment, facilities, and materials, prior to Substantial Completion review.
- B. Clean and repair damage caused by installation or use of temporary work.
- C. Restore existing facilities used during construction to original condition. Restore permanent facilities used during construction to specified condition.

1.42 PRODUCTS

- A. Products: Means new material, machinery, components, equipment, fixtures, and systems forming the Work, but does not include machinery and equipment used for preparation, fabrication, conveying and erection of the Work. Products may also include existing materials or components specifically identified for reuse.
- B. Do not use materials and equipment removed from existing premises, except as specifically identified or allowed by the Contract Documents.
- C. Provide interchangeable components of same manufacturer for components being replaced.

1.43 DELIVERY, HANDLING, STORAGE, AND PROTECTION

- A. Deliver, handle, store, and protect Products in accordance with manufacturer's instructions.

1.44 SUBSTITUTIONS

- A. Substitutions will only be considered when Product becomes unavailable through no fault of Contractor, or where an "approved equal" is specifically allowed elsewhere in the Technical Specifications or noted on the Drawings.
- B. Specific manufacturers may be required for certain items in order to maintain consistency with the Owner's existing inventory. In such cases, substitutions will not be allowed as indicated in each specification section where applicable.

- C. Document each request with complete data substantiating compliance of proposed Substitution with Contract Documents.
- D. Submit three [3] copies of request for Substitution to the Owner for consideration. Limit each request to one proposed Substitution.

1.45 CLOSEOUT PROCEDURES

- A. Submit written certification Contract Documents have been reviewed, Work has been inspected, and Work is complete in accordance with Contract Documents and ready for Owner's inspection.
- B. Submit final Application for Payment identifying total adjusted Contract Price, previous payments, and amount remaining due.
- C. Among required closeout submittals include: Release of Liens, Consent of Surety, and Certification of Labor Standards.

1.46 FINAL CLEANING

- A. Execute final cleaning prior to final inspection.
- B. Upon completion of the work under this contract, thoroughly clean and make any needed repairs caused by damage during construction to any existing utilities or other structures on the site.
- C. Notify the Owner in writing once final cleaning is complete. The final estimate will not be prepared until the Contractor has complied with all requirements set forth and the Owner has made his final inspection of the entire work and is satisfied that it is properly constructed and the site properly cleaned.

1.47 STARTING OF SYSTEMS

- A. Provide seven [7] days notification prior to start-up of each item.
- B. Ensure each piece of equipment or system is ready for operation.
- C. Execute start-up under supervision of responsible persons in accordance with manufacturer's instructions.
- D. Submit written report stating equipment or system has been properly installed and is functioning correctly.

1.48 DEMONSTRATION AND INSTRUCTIONS

- A. Demonstrate operation and maintenance of Products to Owner's personnel two weeks prior to date of Substantial Completion.

- B. For equipment or systems requiring seasonal operation, perform demonstration for other season within six [6] months.
- C. Demonstrate start-up, operation, control, adjustment, trouble-shooting, servicing, maintenance, and shutdown of each item of equipment at agreed-upon times, at designated location.

1.49 TESTING, ADJUSTING, AND BALANCING

- A. Adjust operating products and equipment to ensure smooth and unhindered operation.
- B. Owner retains the right to appoint, employ, and pay for services of independent firm to perform testing, adjusting, and balancing. Reports will be submitted by independent firm to Owner indicating observations and results of tests and indicating compliance or non-compliance with specified requirements and with requirements of Contract Documents.
- C. Contractor will cooperate with independent firm; furnish assistance as requested.
- D. Re-testing required because of non-conformance to specified requirements will be charged to Contractor.

1.50 PROTECTING INSTALLED CONSTRUCTION

- A. Provide temporary and removable protection for installed products. Control activity in immediate work area to prevent damage.
- B. Protect finished floors, stairs, and other surfaces from traffic, dirt, wear, damage, or movement of heavy objects, by protecting with durable sheet materials.
- C. Prohibit traffic or storage upon waterproofed or roofed surfaces. When traffic or activity is necessary, obtain recommendations for protection from waterproofing or roofing material manufacturer.
- D. Prohibit traffic from landscaped areas.

1.51 PROJECT RECORD DOCUMENTS

- A. Maintain on site one set of Contract Documents to be utilized for record documents.
- B. Record actual revisions to the Work. Record information concurrent with construction progress.
- C. Specifications: Legibly mark and record at each Product section description of actual Products installed.
- D. Record Documents and Shop Drawings (As-Built Drawings): Legibly mark each item to record actual construction. Deliver two (2) sets of As-Built Drawings with redlines to the Owner upon completion of the Project. The As-Built Drawings will be submitted to the Owner prior to processing of final payment to the Contractor.

- E. Contractor shall prepare record drawing information under the direction of a Licensed Professional Surveyor. As-Built Record Drawings shall include pipe invert and northing and easting at all manholes, transitions, appurtenances, and casing/encasement beginnings and endings and shall also include finished grade elevations at same and at the manhole rim. Drawings shall include northing and easting of utility crossing locations, elevation of top of both sewer pipe and utility, elevation of finished grade, vertical separation distance, and utility type, material, and diameter, if applicable. Drawings shall include the top of utility elevation and northing and easting at all field-located utilities at intervals not to exceed 100 feet. Ties to surface features for triangulation purposes in the field shall also be included. Final As-Built Record Drawings shall be stamped by a Licensed Professional Surveyor, tied to established control monuments and other reference points (including D.O.T. monuments and mile markers if available) on the New Mexico State Plane Coordinate System, Western Zone, NAD83/NAVD88 datum, stating combined ground-to-grid scale factor used, equipment used and date of completion of survey.
- F. Submit documents to Owner together with claim for final Application for Payment.

1.52 OPERATION AND MAINTENANCE DATA

- A. Submit 3 sets prior to final inspection, bound in 8-1/2 x 11 inch text pages, three D side ring binders with durable plastic covers.
- B. Prepare binder cover with printed title "OPERATION AND MAINTENANCE INSTRUCTIONS" and title of project.
- C. Internally subdivide binder contents with permanent page dividers, logically organized.
- D. Contents:
 - 1. Part 1: Directory
 - a. List names, addresses, and telephone numbers of Owner, Contractor, subcontractors, and major equipment suppliers.
 - 2. Part 2: Operation and maintenance instructions, arranged by system:
 - a. Equipment summary, operational procedures, preventive maintenance procedures and schedules, parts list, shop drawings, safety issues.
 - 3. Part 3: Project documents and certificates.
 - a. All equipment warranties, affidavits, and certifications required by the Technical Specifications shall be placed in this part.

1.53 SPARE PARTS AND MAINTENANCE MATERIALS

- A. Provide products, spare parts, maintenance and extra materials in quantities specified in individual specification sections.
- B. Deliver to project site and place in location as directed by Owner; obtain receipt prior to final payment.

1.54 WARRANTIES

- A. Execute and assemble transferable warranty documents from subcontractors, suppliers, and manufacturers for all products with extended warranties beyond one (1) year.
- B. Submit prior to final Application for Payment.

PART 2 PRODUCTS

Not Used.

PART 3 EXECUTION

Not Used.

END OF SECTION

SECTION 03 05 00

BASIC CONCRETE MATERIALS AND METHODS

PART 1 GENERAL

1.1 SUMMARY

- A. Section includes formwork, reinforcement, accessories, cast-in-place concrete, transporting, placing, finishing, curing, and other pertinent items of construction.
- B. Concrete and Standards - Except as noted or modified in this section, all concrete materials, transporting, placing, finishing, curing, and sealing shall conform to requirements as follows:
 - 1. American Institute of Concrete (ACI)
 - a. 301 - Specifications for Structural Concrete.
 - b. 302.1R - Guide to Concrete Floor and Slab Construction.
 - c. 304R - Guide for Measuring, Mixing, Transporting and Placing Concrete.
 - d. 305.1 - Specification for Hot Weather Concreting.
 - e. 306.1 - Standard Specification for Cold Weather Concreting.
 - f. 308.1 - Standard Specification for Curing Concrete.
 - g. 318 - Building Code Requirements for Structural Concrete.
 - h. 347R - Guide to Formwork for Concrete.
 - i. SP-66 - ACI Detailing Manual.
 - 2. ASTM International (ASTM)
 - a. ASTM A615 - Standard Specification for Deformed and Plain Carbon-Steel Bars for Concrete Reinforcement.
 - b. ASTM A1064 - Standard Specification for Carbon-Steel Wire and Welded Wire Reinforcement, Plain and Deformed, for Concrete.
 - c. ASTM C31 - Standard Practice for Making and Curing Concrete Test Specimens in the Field.
 - d. ASTM C33 - Specifications for Concrete Aggregates.
 - e. ASTM C39 - Standard Test Method for Compressive Strength of Cylindrical Concrete Specimens.
 - f. ASTM C40 - Standard Test Method for Organic Impurities in Fine Aggregates for Concrete.
 - g. ASTM C42 - Standard Test Method for Obtaining and Testing Drilled Cores and Sawed Beams of Concrete.
 - h. ASTM C94 - Specification for Ready-Mixed Concrete.
 - i. ASTM C138 - Standard Test Method for Density (Unit Weight), Yield, and Air Content (Gravimetric) of Concrete.
 - j. ASTM C143 - Standard Test Method for Slump of Hydraulic Cement Concrete.
 - k. ASTM C150 - Standard Specification for Portland Cement.
 - l. ASTM C156 - Standard Test Method for Water Loss [from a Mortar Specimen] Through Liquid Membrane-Forming Curing Compounds for Concrete.
 - m. ASTM C172 - Standard Practice for Sampling Freshly Mixed Concrete.

- n. ASTM C173 - Standard Test Method for Air Content of Freshly Mixed Concrete by the Volumetric Method.
 - o. ASTM C231 - Standard Test Method for Air Content of Freshly Mixed Concrete by the Pressure Method.
 - p. ASTM C260 - Standard Specification for Air-Entraining Admixtures for Concrete.
 - q. ASTM C494 - Standard Specification for Chemical Admixtures for Concrete.
 - r. ASTM C618 - Standard Specification for Coal Fly Ash and Raw or Calcined Natural Pozzolan for Use in Concrete.
 - s. ASTM C989 - Standard Specification for Slag Cement for Use in Concrete and Mortars.
 - t. ASTM C1064 - Standard Test Method for Temperature of Freshly Mixed Hydraulic-Cement Concrete.
 - u. ASTM C1116 - Standard Specification for Fiber-Reinforced Concrete.
 - v. ASTM C1240 - Standard Specification for Silica Fume Used in Cementitious Mixtures.
 - w. ASTM C1260 - Standard Test Method for Potential Alkali Reactivity of Aggregates (Mortar-Bar Method).
 - x. ASTM C1550 - Standard Test Method for Flexural Toughness of Fiber Reinforced Concrete (Using Centrally Loaded Round Panel).
 - y. ASTM C1567 - Standard Test Method for Determining the Potential Alkali-Silica Reactivity of Combinations of Cementitious Materials and Aggregate (Accelerated Mortar-Bar Method).
 - z. ASTM C1602/C1602M - Standard Specification for Mixing Water Used in the Production of Hydraulic Cement Concrete.
 - aa. ASTM C1609 - Standard Test Method for Flexural Performance of Fiber-Reinforced Concrete (Using Beam with Third-Point Loading).
 - bb. ASTM C1778 - Standard Guide for Reducing the Risk of Deleterious Alkali-Aggregate Reaction in Concrete.
3. American Association of State Highway & Transportation Officials (AASHTO):
- a. PP 65 - Standard Practice for Determining the Reactivity of Concrete Aggregates and Selecting Appropriate Measures for Preventing Deleterious Expansion in New Concrete Construction.

1.2 QUALITY ASSURANCE

- A. Inform Owner at least 48 hours in advance of time at which Contractor intends to place concrete.
- B. When required by any applicable permits, such as CID permits, Contractor shall have reinforcement inspected by the agency with jurisdiction prior to placement of concrete.
- C. Construct and erect concrete formwork in accordance with ACI 301 and ACI 347R.
- D. Concrete tests shall be in accordance with requirements of ACI 301, except as noted or modified in this Section.
 - 1. Strength test:

- a. Mold and cure 5 cylinders from each sample.
- b. Test one at 7 days and one at 14 days for information and two at 28 days for acceptance.

E. Samples:

- 1. Collect the following minimum samples for each 28-day strength concrete used in the work for each days placing:

<u>Quantity</u>	<u>Number of Samples</u>
50 cubic yards or less	1
50 to 100 cubic yards	2
100 cubic yards or more	2 plus 1 sample for each additional 100 cubic yards

- 2. Sampling should be in accordance with ASTM C172.
- 3. Forming cylinders in accordance with ASTM C31.
- 4. No sample shall be required for thrust blocks nor fence posts.
- 5. Hold fifth cylinder for future considerations. Deliver to Owner upon determination of substantial completion and prior to final payment.
- 6. Sample marking.
 - a. Mark or tag each sample of compression test cylinders with date and time of day cylinders were made.
 - b. Identify location in work where concrete represented by cylinders was placed.
 - c. Identify delivery truck or batch number, air content and slump.
- 7. Slump test:
 - a. Conduct test for each strength test sample and whenever consistency of concrete appears to vary, in accordance with ASTM C143.
- 8. Air content:
 - a. Conduct test from 1 of first 3 batches mixed each day and for each strength test sample, in accordance with ASTM C231, 138 or 173.
- 9. Temperature:
 - a. Conduct test in accordance with ASTM C1064.

F. Coordinate concrete placement with the Owner to ensure proper testing in compliance with the Drawings and Specifications.

G. The Contractor is free to take additional specimens for his own information, at his own expense.

H. Acceptance of Concrete: Strength level of concrete will be considered satisfactory so long as average of all sets of 3 consecutive strength test results equal or exceeds specified 28-day strength and no individual strength test result falls below specified strength (f_c') by more than 500 psi when specified compressive strength is 5000 psi or less; or by more than **0.10 f_c'** when specified compressive strength is more than 5000 psi.

I. Failure of Test Cylinder Results: Upon failure of test cylinder results, Owner may require Contractor, at his expense, to test remaining cylinder after curing for a period of time specified by Owner. If strength level of this cylinder is not greater than specified 28-day

strength, Owner may require Contractor to obtain and test at least three 2-inch diameter cored samples from an area in question.

1. Conform to ASTM C42.
2. Concrete will be considered adequate if average of 3 cores is at least 85 percent of, and if no single core is less than 75 percent of, specified 28-day strength.
3. Upon failure of core test results, Owner may require Contractor, at his expense, to perform load tests as specified in ACI 318.
4. Fill all core holes as specified for repairing defective concrete.

J. Completed Work

1. Completed concrete work which fails to meet 1 or more requirements, but which has been repaired to bring it into compliance, will be accepted without qualification.
2. Completed concrete work which fails to meet 1 or more requirements and which cannot be brought into compliance shall be rejected as provided in these Contract Documents. In this event, modifications shall be required to assure that concrete work complies with requirements. Modifications, as directed by Owner, to be made at no additional cost to Owner.

K. Perform concrete reinforcing and cast-in-place concrete work in accordance with ACI 301.

L. The maximum deviation of the top surface of curb and gutter shall not exceed 1/8" in 10' nor shall the inside face deviate more than 1/4" in 10' from a straight line. Prior to or during final inspection, curb and gutter shall be water flow tested as directed by the Owner. All areas with standing water will be rejected.

PART 2 PRODUCTS

2.1 FORM MATERIALS AND ACCESSORIES

- A. Steel Forms: Symons "Steel-Ply", Simplex "Industrial Steel Frame Forms", Universal "Uniform". Forms shall be clean, straight and true, without surface defects.
- B. Plywood Forms: Product standard PS-1, waterproof, resin-bonded exterior type Douglas Fir or Larch. Forms shall be clean, straight and true, without surface defects.
- C. Lumber: Douglas Fir or Larch, straight, uniform width and thickness, clean and free from offsets, holes, dents and other surface defects.
- D. Chamfer Strips: Clean white pine, surface against concrete planed.
- E. Form Release Agent: Colorless mineral oil not capable of staining concrete or impairing natural bonding characteristics of coating intended for use on concrete.

2.2 REINFORCEMENT MATERIALS

- A. Reinforcing Steel: ASTM A615, deformed. Reinforcement bar, size and spacing as indicated on the Drawings.

- B. Welded wire fabric reinforcement shall conform to the requirements of ASTM A1064 and the details shown; provided, that welded wire fabric with longitudinal wire of W4 size wire and smaller shall be either furnished in flat sheets or in rolls with a core diameter of not less than 10 inches; and provided further, that welded wire fabric with longitudinal wires larger than W4 size shall be furnished in flat sheets only.
- C. Chairs, Bolsters, Bar Supports, Spacers: Sized and shaped for support of reinforcing; plastic tipped or non-corroding for supports in slabs where supports are exposed to weather.
- D. Concrete blocks used to support and position reinforcement steel, shall have the same or higher compressive strength as specified for the concrete in which it is located. Wire ties shall be embedded in concrete block bar supports.
- E. Fabricate concrete reinforcing in accordance with ACI SP-66.

2.3 CONCRETE MATERIALS

- A. Cementitious Materials:
 - 1. Portland Cement: ASTM C150 Type I.
 - 2. Fly Ash: ASTM C618, Class F or C.
 - 3. Slag Cement: ASTM C989, Grade 100 or 120.
 - 4. Silica Fume: ASTM C1240.
 - 5. Metakaolin: ASTM C618, Class N.
- B. Fine and Coarse Aggregates: ASTM C33.
- C. Water: ASTM C1602/C1602M, Clean and not detrimental to concrete.
- D. Chemical Admixtures (when applicable): Compatible with each other and free of intentionally-added chlorides.
 - 1. Air Entraining Admixture: ASTM C260.
 - 2. Water-Reducing Admixture: ASTM C494, Type A.
 - 3. Mid-Range Water-Reducing Admixture: ASTM C494, Type A.
 - 4. High-Range Water-Reducing Admixture: ASTM C494, Type F.
 - 5. Accelerating Admixture: ASTM C494, Type C or E.
 - 6. Retarding Admixture: ASTM C494, Type B or D.
 - 7. Workability-Retaining Admixture: ASTM C 494, Type S.
 - a. Shall retain concrete workability without affecting time of setting or early-age strength development.
 - 8. Alkali-Silica Reaction Inhibiting Admixture: ASTM C494, Type S
 - a. Shall contain a nominal lithium nitrate content of 30 percent.

2.4 CONCRETE MIX

- A. Mix and deliver concrete in accordance with ASTM C94.
- B. Re-tempering of prepared concrete will not be permitted.
- C. Furnish concrete of the following strength:

Type of Work	Min. 28-Day Compressive Strength (psi)	Max. Size Aggregate (in.)	Min. Cement W/C per CY (94# sacks)	Maximum w/cm (by wt.)
Slabs on grade, footings floor slabs, and all other concrete items not specified elsewhere.	4,000	1	6.0	0.50
Site work concrete such as fence posts, thrust blocks, valve collars, etc.	3,000	1	5.0	0.50

- D. Proportioning:
1. Proportion ingredients to produce a well-graded mix of high-density maximum workability consistent with approved mix design.
 2. Entrained air - all concrete exposed to freeze-thaw cycles under saturated conditions:
 - a. Five (5) percent, plus or minus one (1) percent, for concrete in the forms. Concrete samples for air content tests shall be taken at the end of the concrete truck chute or the output of the concrete pump, whichever applies. A reduction in air content of pumped concrete should be expected. Contractor shall be responsible to coordinate with the concrete supplier to provide the specified air content of the in-place concrete.
 - b. Refer to ACI 301 for further requirements.
 3. Fly ash, silica fume, and slag cement:
 - a. Fly ash: The mineral admixture Class F fly ash shall be proportioned by weight of cement to provide a fly ash to portland cement ratio not less than 1:4 and not less than 25 per cent of the total cementitious material. Portland cement concrete submitted under this specification shall be proportioned with Class F fly ash, unless a variance is authorized by the Owner. Alternatively, lithium-based admixture can be used in lieu of Class F fly ash to mitigate ASR. The Contractor shall provide the Owner with chemical and physical analysis of the fly ash.
 - b. Silica fume: Silica fume may be added to the mix and shall be proportioned by weight of cement to provide a silica fume to Portland cement ratio not less than 1:25 and no greater than 1:7. Portland cement concrete using silica fume shall follow ASTM C1240 standards.
 - c. Slag cement: Slag cement may be added to the mix and shall be proportioned by weight of cement to provide a slag cement to Portland cement ratio of no greater than 80 percent. Slag cement can consist of Grade 100 or grade 120. Portland cement concrete using slag cement shall follow ASTM C989 standards.
 4. Aggregates supplied under this Specification shall be assumed to be "alkali-silica reactive", ASR. Mitigation measures, such as the use of supplementary cementitious materials or lithium nitrate based admixtures or the combination of both, shall be utilized in the concrete mixtures to mitigate alkali-silica reaction, when the aggregates are known to be alkali-silica reactive. Replacement levels of

supplementary cementitious materials and the dosage of lithium nitrate based admixtures shall be determined in accordance with the performance-based approach provided in ASTM C1778. Variance from this position for a particular aggregate source may be authorized by the Owner. Application for a variance may be made to the Owner.

- a. Portland cement concrete design mixes using non alkali-silica reactive aggregates will not be required to be proportioned with Class F fly ash.
- E. Batching and Mixing Equipment: Conform to ACI 304R.
 - F. Slump:
 1. Keep as low as possible consistent with proper handling and thorough compaction.
 2. Shall not exceed 4 inches unless otherwise authorized by Owner.

2.5 CEMENT GROUT

- A. Portland Cement: ASTM C150, Type I and II.
- B. Water:
 1. Potable; containing no impurities, suspended particles, algae or dissolved natural salts.
- C. Fine Aggregate:
 1. Washed natural sand.
 2. Gradation in accordance with ASTM C33 and represented by smooth granulometric curve within required limits.
 3. Free from injurious amounts of organic impurities as determined by ASTM C40.
- D. Mix:
 1. Portland cement, sand and water. Do not use ferrous aggregate or staining ingredients in grout mixes.
 2. Water content shall be such that the grout can be readily spread, yet not wet enough to cause trouble with surface water or laitance, or failure to stay in place after screeding. All grout mixes and mixing procedures shall be submitted in accordance with submittal requirements and shall be subject to review and approval by the Owner prior to commencing the grouting operations.
- E. The minimum compressive strength at 28 days shall be 4000 psi.

PART 3 EXECUTION

3.1 FORMWORK ERECTION

- A. Erect formwork, shoring and bracing to achieve design requirements.

- B. Erect forms substantially and sufficiently tight to prevent leakage of mortar and braced or tied to maintain desired position, shape and alignment before, during, and after concrete placement.
- C. Carefully remove forms only after concrete is able to support all dead and live loads and curing requirements are met. Apply curing compound to all formed surfaces immediately after form removal.
- D. Camber slabs and framing to achieve ACI 301 tolerances.
- E. Provide bracing to ensure stability of formwork.
- F. Clean forms as erection proceeds, to remove foreign matter.

3.2 INSERTS, EMBEDDED COMPONENTS, AND OPENINGS

- A. Provide formed openings where required for work to be embedded in and passing through concrete members.
- B. Coordinate work of other sections in forming and setting openings, slots, recesses, chases, sleeves, bolts, anchors, and other inserts.
- C. Install concrete accessories straight, level, and plumb.
- D. Install water stops continuous without displacing reinforcement.

3.3 REINFORCEMENT PLACEMENT

- A. Place reinforcement, supported and secured against displacement.
- B. Ensure reinforcing is clean, free of loose scale, dirt, or other foreign coatings.

3.4 PLACING CONCRETE

- A. Do not place concrete during rain, sleet, or snow unless adequate protection is provided and Construction Observer approval is obtained. Do not allow rainwater to increase mixing water or damage surface finish.
- B. Prepare previously placed concrete by cleaning with steel brush and applying bonding agent.
- C. Convey concrete from mixer to final position as rapidly as practicable without segregation or loss of material. Limit chute length to less than 20 feet with maximum slope of 1 vertical to 2 horizontal.
- D. Maximum height of concrete free fall is 4 feet.
- E. Place concrete continuously between predetermined expansion, control and construction joints. Do not break or interrupt successive pours creating cold joints.

- F. On large volume pours, concrete shall be placed with the aid of approved mechanical vibrators. Vibration shall be supplemented by manual forking or spading adjacent to the forms on exposed faces in order to secure smooth dense surfaces. The concrete shall be thoroughly consolidated around reinforcement, pipes or other shapes built into the work.
- G. Where new concrete is doweled to existing work, drill holes in existing concrete, insert steel dowels and pack with non-shrink grout.
- H. Screed slabs-on-grade and concrete base for toppings level.

3.5 FORM REMOVAL

- A. Do not remove forms or bracing until concrete has gained sufficient strength to carry its own weight and imposed loads.
- B. Remove formwork progressively and in accordance with code requirements.

3.6 FLOOR FINISHING

- A. Finish concrete floor surfaces in accordance with ACI 301 and ACI 302.1R.
- B. Uniformly spread, screed, and float concrete.
- C. In areas with floor drains, maintain floor level at walls and slope surfaces uniformly to drains.
- D. Provide surface conforming to proper elevation and contour with all aggregates completely embedded in mortar by screening.
- E. Provide an initial float as soon as concrete has stiffened sufficiently for proper working.
- F. Provide a second floating at time of initial set.
- G. Apply a broom finish.

3.7 CURING

- A. Immediately after placement, protect concrete from premature drying.
- B. Maintain concrete with minimal moisture loss at relatively constant temperature for period necessary for hydration of cement and hardening of concrete, for not less than ten (10) days in warm to hot weather (per ACI 305.1), and fourteen (14) days in cold weather (per ACI 306.1) after placing, unless otherwise indicated by the Owner, in accordance with the methods specified herein for the different parts of the Work.
 - 1. Cold weather is defined as when the temperature reaches or goes below 35 degrees F for one (1) hour during any 24-hour period during the curing period.

- C. Use a pre-approved concrete curing method. Acceptable curing methods, as detailed in ACI 308.1, are as follows:
 - 1. Water Curing Methods:
 - a. Ponding/Immersion.
 - b. Fogging/Sprinkler.
 - c. Burlap/Cotton Mats/Absorbent Material.
 - d. Wet Sand Curing.
 - e. Straw/Hay.
 - f. Plastic Film.
 - g. Reinforced Paper.
 - 2. Liquid Membrane-Forming Compounds.
- D. The covering used, if applicable, must be overlapped adequately to ensure 100% coverage, and must not be allowed to become dry at any point during the curing period. Place and anchor covers, mats, and/or sheeting to ensure continuous contact with the concrete surfaces.
- E. When using one of the water curing methods, keep the concrete structures thoroughly and continuously moist and covered during the entire curing period.

3.8 FIELD QUALITY CONTROL

- A. Three (3) Concrete Test Cylinders: Taken for every 75 or less cubic yards of each class of concrete placed.
- B. One (1) Additional Test Cylinder: Taken during cold weather concreting, and cured on job site under same conditions as concrete incorporated into the Work.
- C. One (1) Slump Test: Taken for each set of test cylinders taken and whenever consistency of concrete appears to vary.
- D. One (1) Air Content Test: Taken for each set of test cylinders taken.
- E. One (1) Concrete Temperature Measurement: Taken for each set of test cylinders taken.
- F. One (1) Ambient Air Temperature Measurement: Taken for each set of test cylinders taken and at the beginning of each day that concrete is being placed.

3.9 DEFECTIVE CONCRETE

- A. Modify or replace concrete not conforming to required lines, details and elevations, as directed by Owner.

END OF SECTION

SECTION 31 10 00

SITE CLEARING

PART 1 GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Removing surface debris.
 - 2. Removing designated paving, curbs, and other obstructions.
 - 3. Removing designated trees, shrubs, and other plant life.
 - 4. Removing abandoned utilities.
 - 5. Excavating topsoil.
- B. Related Sections:
 - 1. Section 31 22 13 - Rough Grading.
 - 2. Section 31 23 18 - Rock Removal.

1.2 QUALITY ASSURANCE

- A. Perform Work in accordance with the most recent edition of the New Mexico Standard Specifications for Public Works Construction, with latest revisions.
- B. Perform Work in accordance with the most recent edition of the NMDOT Standard Specifications for Road and Bridge Construction, with latest revisions.
- C. Conform to applicable State of New Mexico code for environmental requirements, disposal of debris, burning debris on site, use of herbicides.

PART 2 PRODUCTS

Not Used.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Section 01 00 00 - Quality Requirements: Examination of existing conditions before starting work.
- B. Verify existing plant life designated to remain is tagged or identified.
- C. Identify waste area and/or salvage area for placing removed materials.

3.2 PREPARATION

- A. Call New Mexico “One Call” at 811 and local utility companies at least three (3) days before performing Work.
 - 1. Request that underground utilities be located and marked within and surrounding construction areas.
- B. Notify Owner at least five (5) working days prior to commencing work within 100 feet of any designated culturally sensitive area, as shown on Plans. Do not commence work unless barricades are in place and/or archaeological monitor is present, as required. Refer to Section 01 00 00 for site-specific requirements.

3.3 PROTECTION

- A. Locate, identify, and protect utilities indicated to remain, from damage.
- B. Protect trees, plant growth, and features designated to remain, as final landscaping.
- C. Protect benchmarks, survey control points, and existing structures from damage or displacement.

3.4 CLEARING

- A. Clear areas required for access to site and execution of Work.
- B. Remove trees and shrubs within indicated areas. Remove stumps and surface rock.
- C. Clear undergrowth and deadwood, without disturbing subsoil.
- D. Apply herbicide to remaining stumps to inhibit growth.

3.5 REMOVAL

- A. Remove debris, rock, and extracted plant life from site.
- B. Partially remove paving, curbs, and other obstructions as indicated on Drawings. Neatly saw cut edges at right angle to surface.
- C. Remove abandoned utilities as directed by Owner. Indicate removal termination point for underground utilities on Record Documents.
- D. Continuously clean up and remove waste materials from site. Do not allow materials to accumulate on site.
- E. The Owner will indicate to the Contractor which obstructions are to be removed, disposed of, or salvaged, and will require special documentation.
- F. All existing fences crossed by the Work, or are within the construction area, are to be removed and rebuilt to original condition or better. Fence materials resulting from such

removal are to be stored or disposed of as directed by the Owner. Fence materials suitable for reuse or salvage that are damaged, lost or destroyed due to the Contractor's negligence or carelessness are to be replaced at the Contractor's expense.

G. Do not burn or bury materials on site. Leave site in clean condition.

3.6 TOPSOIL EXCAVATION

A. Excavate topsoil from areas to be further excavated, relandscaped, or regraded, without mixing with foreign materials for use in finish grading.

B. Do not excavate wet topsoil.

C. Stockpile in area designated on site to depth not exceeding 8 feet and protect from erosion. Stockpile material on impervious material and cover over with same material, until disposal.

D. Remove excess topsoil not intended for reuse, from site.

E. All equipment shall be properly maintained and with proper safety devices.

F. Contractor must maintain control of dust and minimize blowing debris.

END OF SECTION

SECTION 31 22 13

ROUGH GRADING

PART 1 GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Excavating subsoil.
 - 2. Cutting, grading, filling, rough contouring, and compacting site for site structures and building pads.
- B. Related Sections:
 - 1. Section 31 10 00 - Site Clearing
 - 2. Section 31 23 17 - Trenching
 - 3. Section 31 23 23 - Backfill
 - 4. Section 31 23 18 – Rock Removal

1.2 UNIT PRICE - MEASUREMENT AND PAYMENT

- A. The following payment concepts only apply when a corresponding item is included in the Bid Schedule. If no specific item is provided, then this work shall be considered incidental to those items which require grading.
- B. Topsoil Fill:
 - 1. Basis of Payment: Includes excavating existing soil, supplying soil materials, stockpiling, scarifying substrate surface, placing where required, and compacting.
- C. Subsoil Fill:
 - 1. Basis of Payment: Includes excavating existing subsoil, supplying subsoil materials, stockpiling, scarifying substrate surface, placing where required, and compacting.
- D. Structural Fill:
 - 1. Basis of Payment: Includes excavating existing subsoil, supplying structural fill materials, stockpiling, scarifying substrate surface, placing where required, and compacting.

1.3 REFERENCES

- A. Geotechnical Report
 - 1. Terracon Consultants, Inc., “Aztec Arterial Route 550 South Project”, August 28, 2008. See Exhibit A.
- B. American Association of State Highway and Transportation Officials (AASHTO):
 - 1. AASHTO T180 - Standard Specification for Moisture-Density Relations of Soils Using a 10-lb Rammer and an 18-in. Drop.

- C. American Society for Testing and Materials International (ASTM):
1. ASTM C136 - Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates.
 2. ASTM D422 - Particle -Size Analysis of Soils.
 3. ASTM D653 - Terminology Relating to Soil, Rock, and Contained Fluids.
 4. ASTM D698 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Standard Effort 12,400 ft-lbf/ft³.
 5. ASTM D1140 - Amount of Material in Soils Finer than the No. 200 Sieve.
 6. ASTM D1556 - Standard Test Method for Density of Soil in Place by the Sand-Cone Method.
 7. ASTM D1557 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Modified Effort 56,000 ft-lbf/ft³.
 8. ASTM D1633 - Test Method for Compressive Strength of Molded Soil - Cement Cylinders.
 9. ASTM D2167 - Standard Test Method for Density and Unit Weight of Soil in Place by the Rubber Balloon Method.
 10. ASTM D2216 - Laboratory Determination of Water (Moisture) Content of Soil and Rock by Mass.
 11. ASTM D2419 - Standard Test Method for Sand Equivalent Value of Soils and Fine Aggregate.
 12. ASTM D2434 - Standard Test Method for Permeability of Granular Soils Constant Head.
 13. ASTM D2487 - Classifications of Soils for Engineering Purposes (Unified Soil Classification System).
 14. ASTM D2488 - Description and Identification of Soils (Visual-Manual Procedure).
 15. ASTM D2774 - Standard Practice for Underground Installation of Thermoplastic Pressure Piping.
 16. ASTM D2901 - Test Method for Cement Content of Freshly Mixed Soil Cement.
 17. ASTM D2922 - Standard Test Method for Density of Soil and Soil-Aggregate in Place by Nuclear Methods Shallow Depth.
 18. ASTM D3017 - Standard Test Method for Water Content of Soil and Rock in Place by Nuclear Methods Shallow Depth.
 19. ASTM D4253 - Standard Test Methods for Maximum Index Density and Unit Weight of Soils Using a Vibratory Table.
 20. ASTM D4254 - Minimum Index Density and Unit Weight of Soils and Calculation of Relative Density.
 21. ASTM D4318 - Liquid Limit, Plastic Limit, and Plasticity Index of Soils.
 22. ASTM D4564 - Density of Soil in Place by the Sleeve Method.
 23. ASTM D4643 - Determination of Water (Moisture) Content of Soil by the Microwave Oven Heating.
 24. ASTM D4718 - Correction of Unit Weight and Water Content for Soils Containing Oversize Particles.
 25. ASTM D4832 - Compressive Strength of Controlled Low Strength Material.
 26. ASTM D4914 - Density of Soil and Rock in Place by the Sand Replacement Method in a Test Pit.
 27. ASTM D4959 - Determination of Water (Moisture) Content of Soil by Direct Heating.

28. ASTM D5030 - Density of Soil and Rock in Place by the Water Replacement Method in a Test Pit.
29. ASTM D5080 - Rapid Determination of Percent Compaction.
30. ASTM D6938 - Standard Test Method for In-Place Density and Water Content of Soil and Soil-Aggregate by Nuclear Methods (Shallow Depth).

1.4 SUBMITTALS

- A. Section 01 00 00 - Submittal Procedures.
- B. Samples: Submit, in airtight containers, 10 lb sample of each type of fill to testing laboratory.
- C. Materials Source: Submit name of imported materials suppliers.
- D. Manufacturer's Certificate: Certify Products meet or exceed specified requirements.

1.5 CLOSEOUT SUBMITTALS

- A. Project Record Documents: Accurately record actual locations of utilities remaining by horizontal dimensions, elevations or inverts, and slope gradients.

1.6 QUALITY ASSURANCE

- A. Perform Work in accordance with ASTM C136, ASTM D2419, and ASTM D2434.
- B. Perform Work in accordance with applicable New Mexico State Standards.

PART 2 PRODUCTS

2.1 MATERIALS

Not Used.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Section 01 00 00 - Quality Requirements: Examination of existing conditions before starting work.
- B. Verify survey benchmark and intended elevations for the Work are as indicated on Drawings.

3.2 PREPARATION

- A. Call New Mexico “One Call” at 811 and local utility companies at least three (3) days before performing Work.
 - 1. Request underground utilities to be located and marked within and surrounding construction areas.
- B. Notify Owner at least five (5) working days prior to commencing work within 100 feet of any designated culturally sensitive area, as shown on Plans. Do not commence work unless barricades are in place and/or archaeological monitor is present, as required. Refer to Section 01 00 00 for site-specific requirements.
- C. Identify required lines, levels, contours, and datum.
- D. Notify utility company to remove and relocate utilities.
- E. Protect remaining utilities from damage.
- F. Protect plant life, lawns, and other features remaining as portion of final landscaping.
- G. Protect benchmarks, survey control point, existing structures, fences, sidewalks, paving, and curbs from excavating equipment and vehicular traffic.

3.3 SUBSOIL EXCAVATION

- A. Excavate subsoil from areas to be further excavated, relandscaped, or regraded.
- B. Do not excavate wet subsoil or excavate and process wet material to obtain optimum moisture content.
- C. When excavating through roots, perform Work by hand and cut roots with sharp axe.
- D. Remove excess subsoil not intended for reuse, from site.
- E. Benching Slopes: Horizontally bench existing slopes greater than 1: 4 to key placed fill material to slope to provide firm bearing.
- F. Stability: Replace damaged or displaced subsoil as specified for fill.
- G. Notify Owner of any utility damage at once so emergency measures can be taken. The Contractor will pay for any required repairs.
- H. Intercept and divert surface drainage and precipitation away from excavation through use of dikes, curb walls, ditches, pipes, or other means.
- I. Remove and exclude water, including storm water, groundwater, irrigation water, and/or other waters, from all excavations. Dewatering wells, well-points, sump pumps, or other means shall be used to remove water and continuously maintain groundwater at a level

below the bottom of excavations. Water shall be removed and excluded until backfilling is complete and all field soils testing have been completed.

- J. Comply with New Mexico state standards and requirements for dewatering to any watercourse, prevention of stream degradation, and erosion and sediment control.
- K. Excavation below Fills and Embankments: The subgrade areas beneath embankments shall be excavated to remove not less than the top 1 foot of native material and, where such sub-grade is sloped, the native material shall be benched. After the required excavation or over-excavation has been completed, the top 12 inches of material shall be scarified and moisture added or material dried to optimum moisture and the exposed surface shall be proof rolled.
- L. Excavation under areas to be paved shall extend to the bottom of the sub-base. After the required excavation has been completed, the area shall be scarified a minimum of 12 inches below the subgrade surface and recompact prior to the placement of the sub-base aggregate and/or base course aggregate. The finished sub-grade shall be even, self-draining, and in conformance with the slope of the finished pavement. Areas that could accumulate standing water shall be regraded to provide a self-draining subgrade.
- M. Material beyond prescribed lines which is loosened by the Contractor's operations shall be removed, replaced and/or compacted, as directed by the Owner, at no additional cost to the Owner.

3.4 FILLING

- A. See Section 31 23 23 - Backfill.

3.5 DISPOSAL OF EXCAVATED MATERIALS

- A. Excess excavated material or excavated material not suitable for backfill may be disposed of on-site, provided that:
 - 1. The finished grade substantially conforms with the Drawings, or any deviation therefrom is approved by the Owner.
 - a. Blend with natural terrain.
 - b. Minimum slope: 2%.
 - c. Maximum slope: 4:1.
 - 2. All excess excavated material spread on the right-of-way is compacted to the same specifications as final backfill, as set for in Section 31 23 23 - Backfill and the Drawings, and
 - 3. All on-site disposal of material is approved by the Owner.
- B. Do not dispose of waste material by dumping from tops of slopes.
- C. Do not dispose of excess material within 15 feet of any wash, drainage or waterway.
- D. Scarify or disc and reseed (May 1st through August 31st only) all areas that are disturbed or denuded of vegetation according to 17NMAC 4.2 Section 12.5.

3.6 TOLERANCES

- A. Section 01 00 00 - Quality Requirements: Tolerances.
- B. Top Surface of Subgrade: Plus or minus 1/10 foot from required elevation.

3.7 FIELD QUALITY CONTROL

- A. Section 01 00 00 - Execution Requirements: Testing, adjusting, and balancing.
- B. Perform laboratory material tests in accordance with ASTM D1557, ASTM D698, AASHTO T180.
- C. Perform in place compaction tests in accordance with the following:
 - 1. Density Tests: ASTM D2922.
 - 2. Moisture Tests: ASTM D3017.
- D. When tests indicate Work does not meet specified requirements, remove Work, replace and retest.
- E. Compaction testing shall be done to the extent such that the Owner can be reasonably assured that the backfill has been placed in accordance with the requirements of the Contract Documents or in accordance with the NMDOT Standard Specifications for Road and Bridge Construction, whichever is the more stringent. When a testing allowance is established on the Bid Form, the Owner will determine the testing frequency to be used throughout the project. If no allowance is included, the frequency of testing shall be at least once every 100 linear feet of trenching, or at least once every 200 square feet below structures, including manholes.

3.8 SCHEDULES

- A. See 31 23 23 - Backfill
- B. Structural Fill:
 - 1. Fill Type G or H: To subgrade elevation.
 - 2. Compact uniformly to minimum 95 percent of maximum density.
- C. Subsoil Fill:
 - 1. Fill Type G: To subgrade elevation.
 - 2. Compact uniformly to minimum 90 percent of maximum density or density of surrounding undisturbed soils, whichever is greater.
- D. Topsoil Fill:
 - 1. Fill Type M or uniform mix of Types A - H: To subgrade elevation.
 - 2. Compact uniformly to minimum 90 percent of maximum density or density of surrounding undisturbed soils, whichever is greater.

END OF SECTION

SECTION 31 23 17

TRENCHING

PART 1 GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Excavating trenches for utilities.
 - 2. Compacted fill from top of utility bedding to finished grade.
 - 3. Backfilling and compaction.
- B. Related Sections:
 - 1. Section 03 05 00 - Basic Concrete Materials and Methods
 - 2. Section 31 22 13 - Rough Grading
 - 3. Section 31 23 18 - Rock Removal
 - 4. Section 31 23 23 - Backfill
 - 5. Section 33 31 00 - Sanitary Sewer Systems

1.2 REFERENCES

- A. Geotechnical Report:
 - 1. Terracon Consultants, Inc., "Aztec Arterial Route 550 South Project", August 28, 2008. See Exhibit A.
- B. New Mexico Standard Specifications for Public Works Construction (NMSSPWC):
 - 1. NMSSPWC Sections 701, 801 & 802 "Trenching, Excavation and Backfill".
- C. American Association of State Highway and Transportation Officials (AASHTO):
 - 1. AASHTO T180 - Standard Specification for Moisture-Density Relations of Soils Using a 10-lb Rammer and an 18-in. Drop.
- D. American Society for Testing and Materials International (ASTM):
 - 1. ASTM C136 - Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates.
 - 2. ASTM D422 - Particle -Size Analysis of Soils.
 - 3. ASTM D653 - Terminology Relating to Soil, Rock, and Contained Fluids.
 - 4. ASTM D698 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft³).
 - 5. ASTM D1140 - Amount of Material in Soils Finer than the No. 200 Sieve.
 - 6. ASTM D1556 - Standard Test Method for Density of Soil in Place by the Sand-Cone Method.
 - 7. ASTM D1557 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Modified Effort (6,000 ft-lbf/ft³).
 - 8. ASTM D1633 - Test Method for Compressive Strength of Molded Soil - Cement Cylinders.
 - 9. ASTM D2167 - Standard Test Method for Density and Unit Weight of Soil in Place by the Rubber Balloon Method.

10. ASTM D2216 - Laboratory Determination of Water (Moisture) Content of Soil and Rock by Mass.
11. ASTM D2487 - Classifications of Soils for Engineering Purposes (Unified Soil Classification System).
12. ASTM D2488 - Description and Identification of Soils (Visual-Manual Procedure).
13. ASTM D2774 - Standard Practice for Underground Installation of Thermoplastic Pressure Piping.
14. ASTM D2901 - Test Method for Cement Content of Freshly Mixed Soil Cement.
15. ASTM D2922 - Standard Test Method for Density of Soil and Soil-Aggregate in Place by Nuclear Methods (Shallow Depth).
16. ASTM D3017 - Standard Test Method for Water Content of Soil and Rock in Place by Nuclear Methods (Shallow Depth).
17. ASTM D4253 - Standard Test Methods for Maximum Index Density and Unit Weight of Soils Using a Vibratory Table.
18. ASTM D4254 - Minimum Index Density and Unit Weight of Soils and Calculation of Relative Density.
19. ASTM D4318 - Liquid Limit, Plastic Limit, and Plasticity Index of Soils.
20. ASTM D4564 - Density of Soil in Place by the Sleeve Method.
21. ASTM D4643 - Determination of Water (Moisture) Content of Soil by the Microwave Oven Heating.
22. ASTM D4718 - Correction of Unit Weight and Water Content for Soils Containing Oversize Particles.
23. ASTM D4832 - Compressive Strength of Controlled Low Strength Material.
24. ASTM D4914 - Density of Soil and Rock in Place by the Sand Replacement Method in a Test Pit.
25. ASTM D4959 - Determination of Water (Moisture) Content of Soil by Direct Heating.
26. ASTM D5030 - Density of Soil and Rock in Place by the Water Replacement Method in a Test Pit.
27. ASTM D5080 - Rapid Determination of Percent Compaction.
28. ASTM D6938 - Standard Test Method for In-Place Density and Water Content of Soil and Soil-Aggregate by Nuclear Methods (Shallow Depth).

1.3 SUBMITTALS

- A. Section 01 00 00 - Submittal Procedures: Requirements for submittals.
- B. Materials Source: Submit name of imported fill materials suppliers.
- C. Manufacturer's Certificate: Certify Products meet or exceed specified requirements.

1.4 QUALITY ASSURANCE

- A. Perform Work in accordance with applicable New Mexico state standards and specifications of the utility provider.
- B. Perform Work in accordance with applicable OSHA trench safety standards.

1.5 FIELD MEASUREMENTS

- A. Verify field measurements prior to fabrication.

1.6 COORDINATION

- A. Section 01 00 00 - Administrative Requirements: Coordination and project conditions.
- B. Verify Work associated with lower elevation utilities is complete before placing higher elevation utilities.

PART 2 PRODUCTS

2.1 FILL MATERIALS

- A. Pipe Bedding and Embedment: As specified in Section 31 23 23.
- B. Pipe Backfill: As specified in Section 31 23 23.
- C. Structural Fill: As specified in Section 31 23 23.
- D. Granular Fill: As specified in Section 31 23 23.

PART 3 EXECUTION

3.1 LINES AND GRADES

- A. Lay pipes to lines and grades indicated on Drawings.
 - 1. Owner reserves right to make changes in lines, grades, and depths of utilities when changes are required for Project conditions.

3.2 PREPARATION

- A. Call New Mexico “One Call” at 811 and local utilities not less than three working days before performing Work.
 - 1. Request underground utilities to be located and marked within and surrounding construction areas.
- B. Notify Owner at least five (5) working days prior to commencing work within 100 feet of any designated culturally sensitive area, as shown on Plans. Do not commence work unless barricades are in place and/or archaeological monitor is present, as required. Refer to Section 01 00 00 for site-specific requirements.
- C. Identify required lines, levels, contours, and datum locations.
- D. Protect plant life, lawns and other features remaining as portion of final landscaping.
- E. Protect benchmarks, existing structures, fences, sidewalks, paving, and curbs from excavating equipment and vehicular traffic.
- F. Maintain and protect above and below grade utilities indicated to remain.

- G. Establish temporary traffic control and detours when trenching is performed in public right-of-way. Relocate controls and reroute traffic as required during progress of Work.

3.3 LINES, GRADES AND DIMENSIONS

- A. Excavate trench to lines and grades indicated on Drawings.
 - 1. Owner reserves right to make changes in lines, grades, and depths of utilities when changes are required based on field conditions.
 - 2. When bottom of trench is rocky, over-excavate and fill as specified in Section 31 23 23.
- B. Excavate trench to minimum width as indicated on Drawings.
 - 1. Cut trenches to width indicated on Drawings, providing at least 6 inches of clear space between the trench face and the outside diameter of the pipe. The maximum permissible width of the trench shall be the outside diameter of the pipe (or distance between pipes plus pipe diameters in the event that two pipes are buried in the same trench) plus 24 inches, unless otherwise indicated on the Drawings. Permission in writing to use a greater width shall be obtained from the Owner.
 - 2. Increase trench width as required to meet required clearances between pipe and trench wall, to avoid voids in the haunch areas of the pipe and to meet embedment compaction requirements or minimum soil cement slurry layer thickness. Increased trench width, if needed to meet these requirements, shall be provided at no additional cost to the Owner.

3.4 TRENCHING

- A. Excavate subsoil required for utilities.
- B. Remove lumped subsoil, boulders, and rock up to the size that would require special equipment beyond conventional machinery used for trenching, in which case the Owner should be notified immediately.
- C. Allowable Open Trench: Trenches may be opened in advance of pipe placement and backfill operations under the following conditions:
 - 1. In developed areas and along traveled roadways, no more than 100 feet of trench shall be opened in advance of pipe laying operations. This distance may be reduced due to traffic control considerations. Backfilling shall begin as soon as pipe is laid and inspected and shall keep pace with the pipe laying. In undeveloped areas outside of roadway rights-of-way and away from any vehicular or pedestrian traffic, open trench shall not be advanced more than 500 feet ahead of installed pipe. Whenever local, county, state or federal regulations impose stricter limitations, such regulations will take precedence.
 - 2. All trenches shall be fully backfilled at the end of each day or, in lieu thereof, shall be covered by traffic weight steel plates adequately braced and capable of supporting vehicular traffic in those locations where it is impractical to backfill at the end of each day. The above requirements for backfilling or use of steel plates may be waived in undeveloped areas, such as where the trench is located further than 100 feet from any traveled roadway or occupied structure. In such cases,

- however, barricades and warning lights, or escape ramps and earthen trench plugs for wildlife, shall be provided and maintained to meet applicable safety requirements. In no case shall more than 100 feet of trench be left open at end of working day.
3. Do not block vehicular traffic or impede access to homes or businesses.
 4. Protect open trench to protect the public, livestock, wildlife and the environment.
 - a. Comply with all stipulations set forth by the NM Department of Transportation and other land-controlling agencies. These stipulations are provided in Appendix B.
 - b. The Owner or land-controlling agencies, at their sole discretion, may require temporary fencing to protect livestock, wildlife and local residents and land users from open trenches. Such fences shall be required in all trenches left open in active livestock grazing areas. Contractor shall provide such fencing, if required, at no additional cost to the Owner.
 - c. Provide animal escape ramps in accordance with stipulations provided in Section 3.5.
 5. Contractor is solely responsible for safety of all open trenches and bears sole liability for any incidents or accidents arising from open trenches.
 6. The Owner may restrict the amount of open trench as needed due to safety, land use or environmental considerations.
- D. Intercept and divert surface drainage and precipitation away from excavation through use of dikes, curb walls, ditches, pipes, or other means.
- E. Dewater and maintain substantially dry subgrade during pipe installation.
 1. Remove groundwater by pumping to keep excavations dry.
 2. Comply with New Mexico state standards and requirements for dewatering to any watercourse, prevention of stream degradation, and erosion and sediment control.
 3. If a separate bid item is not included on the Bid Form for dewatering, the cost thereof will be considered incidental to the cost of trenching and utility installation.
- F. Excavate trenches to depth indicated on Drawings. Provide uniform and continuous bearing and support for bedding material and pipe.
- G. Do not interfere with 45 degree bearing splay of foundations. Any excavation in this area shall be backfilled and compacted using the same materials and methods as structural fill for new buildings. Refer to Section 31 23 23.
- H. Slope or shore trench as needed to meet safety requirements. When sidewalls cannot be sloped, provide sheeting and shoring to protect excavation as specified in this section.
- I. When subsurface materials at bottom of trench are loose or soft, excavate to greater depth as directed by Owner until suitable material is encountered. Backfill and compact to reach specified or directed line and grade. Refer to specifications for overexcavation backfill, as set forth in Section 31 23 23.

- J. Cut out soft areas of subgrade not capable of compaction in place. Backfill and compact to specified or directed line and grade. Refer to specifications for overexcavation backfill, as set forth in Section 31 23 23.
- K. Trim excavation. Hand trim for bell and spigot pipe joints. Remove loose matter.
- L. Correct over excavated areas with compacted backfill as specified for authorized excavation or replace with fill concrete as directed by Owner.
- M. Remove excess subsoil not intended for reuse, from site.
- N. Protect open trench at all times to prevent danger to the public and to wildlife. Any safety requirements imposed by agencies or entities with jurisdiction must be met.

3.5 SPECIAL TRENCHING GUIDELINES FOR WORK IN NMDOT ROW

- A. The New Mexico Department of Game and Fish has issued the following guidelines which will apply to all work within NMDOT right-of-way, above and beyond all other requirements of this section.
- B. Open trenches and ditches can trap small mammals, amphibians and reptiles and can cause injury to large mammals. Periods of highest activity for many of these species include night time, summer months and wet weather. Loss of wildlife can be minimized by implementing the following recommendations.
 - 1. To minimize the amount of open trenches at any given time, keep trenching and backfilling crews close together.
 - 2. Trench during the cooler months (October - March). However, there may be exceptions (e.g., critical wintering areas) which need to be assessed on a site-specific basis.
 - 3. Avoid leaving trenches open overnight. Where trenches cannot be backfilled immediately, escape ramps should be constructed at least every 250 feet. Escape ramps can be short lateral trenches sloping to the surface or wooden planks extending to the surface. The slope should be less than 45 degrees (100%). Trenches that have been left open overnight, especially where endangered species occur, should be inspected and animals removed prior to backfilling.

3.6 SHEETING AND SHORING

- A. Sheet, shore, and brace excavations to prevent danger to persons, structures and adjacent properties and to prevent caving, erosion, and loss of surrounding subsoil.
- B. Support trenches more than 5 feet deep excavated through unstable, loose, or soft material. Provide sheeting, shoring, bracing, or other protection to maintain stability of excavation.
- C. Design sheeting and shoring to be removed at completion of excavation work. If the Owner orders the sheeting to be left in place for the protection of the work, a payment will be allowed only for the actual cost of the timber left in place.

- D. Repair damage caused by failure of the sheeting, shoring, or bracing and for settlement of filled excavations or adjacent soil.
- E. Repair damage to new and existing Work from settlement, water or earth pressure or other causes resulting from inadequate sheeting, shoring, or bracing.

3.7 BACKFILLING OF TRENCHES

- A. See Section 31 23 23 - Backfill, Articles 3.3 and 3.4 for general backfill requirements, as well as trench backfill and bedding requirements around pipelines.

3.8 DISPOSAL OF EXCAVATED MATERIALS

- A. Excess excavated material or excavated material not suitable for backfill may be disposed of on-site, provided that:
 - 1. The finished grade substantially conforms with the Drawings, or any deviation therefrom is approved by the Owner.
 - a. Blend with natural terrain.
 - b. Minimum slope: 2%.
 - c. Maximum slope: 4:1.
 - 2. All excess excavated material spread on the right-of-way is compacted to the same specifications as final backfill, as set forth in Section 31 23 23 - Backfill and the Drawings, and
 - 3. All on-site disposal of material is approved by the Owner.
- B. Do not dispose of waste material by dumping from tops of slopes.
- C. Do not dispose of excess material within 15 feet of any wash, drainage or waterway.
- D. Reseed according to Section 31 22 13.

3.9 TOLERANCES

- A. Section 01 00 00 - Quality Requirements: Tolerances.
- B. Top Surface of Backfilling Under Paved Areas: Plus or minus 1 inch from required elevations.

3.10 FIELD QUALITY CONTROL

- A. Section 01 00 00 - Execution Requirements: Testing, adjusting, and balancing.
- B. Determine compaction characteristics of materials in accordance with ASTM D698.
- C. Classify soils in accordance with ASTM D2487.
- D. Perform laboratory material tests in accordance with ASTM D1557.
- E. Refer to compaction testing requirements in Section 31 22 13 - Rough Grading and/or Section 31 23 23 - Backfill, Field Quality Control, as applicable.

3.11 PROTECTION OF FINISHED WORK

- A. Section 01 00 00 - Execution Requirements: Protecting installed construction.
- B. Reshape and re-compact fills subjected to vehicular traffic during construction.

END OF SECTION

SECTION 31 23 18

ROCK REMOVAL

PART 1 GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Removing identified and discovered rock during excavation.
 - 2. Expansive tools and/or Explosives to assist rock removal.
- B. Related Sections:
 - 1. Section 31 22 13 - Rough Grading
 - 2. Section 31 23 17 - Trenching
 - 3. Section 31 23 23 - Backfill

1.2 UNIT PRICE - MEASUREMENT AND PAYMENT

- A. Site Rock Removal:
 - 1. Basis of Measurement: By cubic yard measured after disintegration.
 - 2. Basis of Payment: Includes preparation of rock for removal, mechanical disintegration of rock, removal from position, loading and removing from site. For over excavation, payment will not be made for over excavated work nor for replacement materials.
 - 3. Contractor shall notify Owner prior to commencement of rock removal work when rock is encountered, and specialized equipment will be required and await approval from Owner before proceeding.
 - 4. Contractor and Owner must agree on rock quantity at the end of each day that such work was completed, and both parties must sign off on the quantity on the corresponding daily field report. Contractor shall notify Owner of estimated extents prior to commencement of rock removal work
- B. Trench Rock Removal:
 - 1. Basis of Measurement: By vertical linear foot (VLF) of trench excavation. Each VLF is measured as horizontal linear foot of trench multiplied by the depth of excavated rock. The depth of the excavated rock may be less than the total trench depth. The width of trench is not a factor in the VLF calculation.
 - 2. Basis of Payment: Includes preparation of rock for removal, mechanical disintegration of rock, removal from position, loading and removing from trench.
 - a. Payment will not be made for over-excavated work beyond the required bedding depth below invert elevation of pipe as shown on Drawings, nor for replacement materials.
 - b. If native trench rock is processed and used as pipe bedding or backfill material, the cost of such processing will be considered incidental to the cost of trench rock removal.
 - c. If trench rock is hauled away from site and replaced with imported material, the costs of rock hauling and disposal, as well as the costs of

obtaining and hauling imported fill material will be considered incidental to the cost of trench rock removal.

- d. The cost of placing and compacting embedment and backfill material, regardless of whether it is native or imported, will be considered incidental to pipeline installation.
3. Contractor shall notify Owner prior to commencement of rock removal work when rock is encountered and specialized equipment will be required. Contractor shall provide estimated extent of rock removal to Owner and await approval from Owner before proceeding
4. Contractor and Owner must agree on rock quantity at the end of each day that such work was completed, and both parties must sign off on the quantity on the corresponding daily field report.
5. Where trench rock removal is required, additional pipe bedding material will be needed, as stipulated in Article 3.4 of Section 31 23 23 - Backfill.

1.3 REFERENCES

- A. Geotechnical Report
 1. Terracon Consultants, Inc., "Aztec Arterial Route 550 South Project", August 28, 2008. See Exhibit A.
- B. National Fire Protection Association (NFPA):
 1. NFPA 495 - Explosive Materials Code.

1.4 DEFINITIONS

- A. Rock: Solid mineral material of size that cannot be removed with conventional equipment.
- B. For general excavation, a D-9N Caterpillar tractor with a single shank ripper, or equivalent equipment, is considered conventional equipment, if it can rip at a production rate of at least 300 bank cubic yards per hour.
- C. For trench excavation, a 235C Caterpillar excavator with a medium stick and a rock ripping bucket, or equivalent equipment, is considered conventional equipment, if it can excavate at a production rate of at least 30 bank cubic yards per hour.
- D. If material cannot be excavated by conventional equipment, the Owner must be immediately notified. The Contractor shall provide performance tests of the specified conventional or equivalent equipment. If the Owner confirms in writing that the specified conventional equipment cannot perform at the production rates specified, the excavation shall be considered rock excavation.

1.5 SUBMITTALS

- A. Section 01 00 00 - Submittals: Submittal procedures.
- B. Submit type of equipment to be used for rock removal and/or processing.

- C. If processed native rock is to be used for embedment and backfill, submit sieve analyses and other geotechnical data on the processed material, as required in field by Owner.
 - 1. Laboratory costs associated with such testing shall be reimbursable under project testing allowance. Other costs, such as sample collection and transport, are not covered under the allowance.
- D. Survey Report: Submit survey report on conditions of buildings near locations of rock removal.

1.6 QUALITY ASSURANCE

Not used.

1.7 PROJECT CONDITIONS

Not used.

1.8 SCHEDULING

- A. Schedule Work to avoid disruption to occupied buildings nearby.
- B. Section 01 00 00 - Administrative Requirements: Coordination.

PART 2 PRODUCTS

2.1 MATERIALS

Not used.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Section 01 00 00 - Administrative Requirements: Coordination.
- B. Verify site conditions and note subsurface irregularities affecting Work of this section.

3.2 PREPARATION

- A. Identify required lines, levels, contours, and datum.

3.3 ROCK REMOVAL BY MECHANICAL METHOD

- A. Excavate and remove rock by mechanical method.
- B. Cut away rock at bottom of excavation to form level bearing.

- C. Remove shaled layers to provide sound and unshattered base for footings.
- D. For utility trenches, excavate to below invert elevation of pipe as shown on Drawings to ensure adequate bedding below pipe, and provide trench width as shown on Drawings to allow for proper embedment compaction or soil cement placement on sides of pipe. Exceptions to minimum trench width will be considered by Engineer if Contractor can demonstrate proper bedding and compaction are provided.
- E. Remove excavated materials from site.

3.4 **ROCK REMOVAL BY EXPLOSIVE METHODS**

Not used.

3.5 **FIELD QUALITY CONTROL**

- A. Section 01 00 00 - Execution Requirements: Testing, adjusting, and balancing.
- B. Request visual inspection of foundation bearing surfaces by Owner before installing subsequent work.

END OF SECTION

SECTION 31 23 23

BACKFILL

PART 1 GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Backfilling building perimeter to subgrade elevations.
 - 2. Backfilling site structures to subgrade elevations.
 - 3. Fill under slabs-on-grade.
 - 4. Fill under paving.
 - 5. Fill for over-excavation.
 - 6. Pipe bedding material.

- B. Related Sections:
 - 1. Section 03 05 00 - Basic Concrete Materials and Methods
 - 2. Section 31 22 13 - Rough Grading
 - 3. Section 31 23 17 - Trenching
 - 4. Section 31 23 18 - Rock Removal
 - 5. Section 33 31 00 - Sanitary Sewer Systems

1.2 REFERENCES

- A. Geotechnical Report
 - 1. Terracon Consultants, Inc., "Aztec Arterial Route 550 South Project", August 28, 2008. See Exhibit A.
 - 2. Refer to geotechnical data regarding any issues not specifically addressed in these technical specifications. In the event of any discrepancies or differences in requirements between the geotechnical report and the technical specifications, the more stringent requirement shall apply.

- B. New Mexico Standard Specifications for Public Works Construction (NMSSPWC):
 - 1. NMSSPWC Sections 701, 801 & 802 "Trenching, Excavation and Backfill".

- C. American Association of State Highway and Transportation Officials (AASHTO):
 - 1. AASHTO T99 - Standard Method of Test for Moisture-Density Relations of Soils Using a 2.5-kg (5.5-lb) Rammer and a 3050mm (12-in.) Drop.
 - 2. AASHTO T180 - Standard Specification for Moisture-Density Relations of Soils Using a 4.54-kg (10-lb) Rammer and a 457-mm (18-in.) Drop.

- D. American Society for Testing and Materials International (ASTM):
 - 1. ASTM C136 - Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates.
 - 2. ASTM D422 - Particle -Size Analysis of Soils.
 - 3. ASTM D653 - Terminology Relating to Soil, Rock, and Contained Fluids.

4. ASTM D698 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft³ (600 kN-m/m³)).
5. ASTM D1140 - Amount of Material in Soils Finer than the No. 200 Sieve.
6. ASTM D1556 - Standard Test Method for Density of Soil in Place by the Sand-Cone Method.
7. ASTM D1557 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft³, 2,700 kN-m/m³).
8. ASTM D1633 - Test Method for Compressive Strength of Molded Soil - Cement Cylinders.
9. ASTM D2167 - Standard Test Method for Density and Unit Weight of Soil in Place by the Rubber Balloon Method.
10. ASTM D2216 - Laboratory Determination of Water (Moisture) Content of Soil and Rock by Mass.
11. ASTM D2487 - Classifications of Soils for Engineering Purposes (Unified Soil Classification System).
12. ASTM D2488 - Description and Identification of Soils (Visual-Manual Procedure).
13. ASTM D2774 - Standard Practice for Underground Installation of Thermoplastic Pressure Piping.
14. ASTM D2901 - Test Method for Cement Content of Freshly Mixed Soil Cement.
15. ASTM D2922 - Standard Test Method for Density of Soil and Soil-Aggregate in Place by Nuclear Methods (Shallow Depth).
16. ASTM D3017 - Standard Test Method for Water Content of Soil and Rock in Place by Nuclear Methods (Shallow Depth).
17. ASTM D4253 - Standard Test Methods for Maximum Index Density and Unit Weight of Soils Using a Vibratory Table.
18. ASTM D4254 - Minimum Index Density and Unit Weight of Soils and Calculation of Relative Density.
19. ASTM D4318 - Liquid Limit, Plastic Limit, and Plasticity Index of Soils.
20. ASTM D4564 - Density of Soil in Place by the Sleeve Method.
21. ASTM D4643 - Determination of Water (Moisture) Content of Soil by the Microwave Oven Heating.
22. ASTM D4718 - Correction of Unit Weight and Water Content for Soils Containing Oversize Particles.
23. ASTM D4832 - Compressive Strength of Controlled Low Strength Material.
24. ASTM D4914 - Density of Soil and Rock in Place by the Sand Replacement Method in a Test Pit.
25. ASTM D4959 - Determination of Water (Moisture) Content of Soil by Direct Heating.
26. ASTM D5030 - Density of Soil and Rock in Place by the Water Replacement Method in a Test Pit.
27. ASTM D5080 - Rapid Determination of Percent Compaction.
28. ASTM D6938 - Standard Test Method for In-Place Density and Water Content of Soil and Soil-Aggregate by Nuclear Methods (Shallow Depth).

1.3 DEFINITIONS

- A. Percentage Compaction: Ratio, expressed as percentage, of actual density of material compared with maximum dry density based on Modified Proctor (ASTM D1557).
- B. Optimum Moisture Content: Based on Modified Proctor (ASTM D1557).
- C. Unified Soil Classification System: Based on ASTM D2487.

1.4 SUBMITTALS

- A. Section 01 00 00 - Submittal Procedures.
- B. Submit samples and certified test documentation of all materials to be used.
- C. Materials Source: Submit name of imported fill materials suppliers.
- D. Manufacturer's Certificate: Certify Products meet or exceed specified requirements.
- E. Submit field soil test on material in place as backfill and pipe bedding material.
- F. Submit construction drawings with compaction test locations marked and labeled with station, date, test number, depth of test below ground surface, and test result.

PART 2 PRODUCTS

2.1 FILL MATERIALS

- A. Suitable materials may be processed on-site, or may be imported. If imported materials are required to meet the quantity requirements of the project, it will be provided at no additional expense to the Owner, unless a unit price item is included for imported materials on the Bid Form. The following types of materials are defined as suitable where scheduled:

- 1. Type A (three-quarter inch minus aggregate backfill): Crushed rock or gravel, and sand with the gradation requirements below.

<u>Sieve Size</u>	<u>Percentage Passing</u>
3/4-inch	100
No. 4	30 – 50
No.200	0 – 12

- 2. Type B (Class I crushed stone): Manufactured angular, crushed stone, crushed rock, or crushed slag with the following gradation requirements. The material shall have a minimum sand equivalent value of 75.

<u>Sieve Size</u>	<u>Percentage Passing</u>
3/4-inch	100
No. 4	30 – 50
No. 200	0 - 5

3. Type C (sand backfill): Sand with 100 percent passing a 3/8-inch sieve, at least 90 percent passing a No. 4 sieve, and a sand equivalent value not less than 30.
a. This material to be used only when approved by Owner.

4. Type D: (pipe bedding material): Crushed rock or gravel with 100 percent passing a 1/2-inch sieve and not more than 3 to 5 percent passing a No. 10 sieve and 1 to 2 percent passing a No. 200 sieve.

5. Type E (pea gravel backfill): Crushed rock or gravel with 100 percent passing a 1/2-inch sieve and not more than 10 percent passing a No. 4 sieve.

6. Type F (coarse drain rock): Crushed rock or gravel meeting the following gradation requirements:

<u>Sieve Size</u>	<u>Percentage Passing</u>
2-inch	100
1-1/2-inch	90- 100
1-inch	20 – 55
3/4-inch	0 – 15
No. 200	0 – 3

7. Type G (aggregate base, base course) as follows:

<u>Sieve Size</u>	<u>Percentage Passing</u>
1-inch	100
3/4 inch	80-100
No.4	30-60
No.10	20-45
No. 200	3-10

8. Type H (graded drain rock): Drain rock shall be crushed rock or gravel, durable and free from slaking or decomposition under the action of alternate wetting or drying. The material shall be uniformly graded and shall meet the following gradation requirements:

<u>Sieve Size</u>	<u>Percentage Passing</u>
1-inch	100
3/4-inch	90 - 100
3/8-inch	40 - 100
No. 4	25 – 40
No. 8	18 – 33
No. 30	5 – 15
No. 50	0 – 7
No. 200	0 – 3

9. Type I: Not Used

10. Type J (cement-treated backfill): Material which consists of Type H material, or any mixture of Types B, C, G, and H materials which has been cement-treated so that the cement content of the material is not less than 5 percent by weight when tested in accordance with ASTM D2901 - Test Method for Cement Content of

Freshly Mixed Soil Cement. The ultimate compressive strength at 28 days shall be not less than 400 psi when tested in accordance with ASTM D1633 - Test Method for Compressive Strength of Molded Soil - Cement Cylinders.

11. Type K (topsoil): Stockpiled topsoil material which has been obtained at the site by removing soil to a depth not exceeding 2 feet. Removal of the topsoil shall be done after the area has been stripped of vegetation and debris.
12. Type L (controlled low strength material): Controlled low strength material, also referred to as 'soil cement slurry' or 'flowable fill' shall meet the following requirements:
 - a. Slurry shall have a 7-day compressive strength of not less than 50 psi and not more than 150 psi. The compressive strength shall be determined in accordance with ASTM D4832.
 - b. Typical cement content: 3 to 10 percent by dry weight of soil to obtain specified compressive strength.
 - c. The water-cement ratio of the mix shall not exceed 3.5:1. The water content shall not exceed that required to provide a mix that will flow and can be pumped.
 - d. The consistency of the slurry shall be such that the slurry flows easily into all openings between the pipe and the lower portion of the trench.

13. Type M (aggregate sub-base, structural fill): Well-graded crushed rock or natural gravel meeting the following gradation requirements:

<u>Sieve Size</u>	<u>Percentage Passing</u>
4-inch	100
3-inch	95 100
No. 200	3 - 15

- B. Where these Specifications conflict with the requirements of any local agency having jurisdiction or with the requirements of a pipe material manufacturer, the Owner shall be immediately notified. In case of conflict between types of pipe embedment backfills, the Contractor is to use the agency-specified backfill material if that material provides a greater degree of structural support to the pipe, as determined by the Owner. In case of conflict between types of trench or final backfill types, the Contractor shall use the agency-specified backfill material if that material provides the greater in-place density after compaction.
- C. Fill and backfill types, including use of native soil, shall be used in accordance with the following provisions. Native soil used for fill and backfill must meet the requirements of the type of material specified below and as shown for the corresponding type of material shown in 2.1.A above.
 1. Embankment fills shall be constructed of Type M material, as defined herein, or other material approved by the Owner. Drainage structures embankments shall be backfilled with materials used in original construction.
 2. Pipe zone backfill shall consist of the following materials for each pipe material listed below. All pipe bedding material shall receive prior approval by the Owner before use.

- a. Concrete pipe shall be provided Type A or B pipe bedding and embedment backfill material, or native material that meets the criteria described below, and is acceptable to the Owner.
 - b. Plastic pipe shall be provided Type D bedding and embedment zone material, or native material that meets the criteria described below, and is acceptable to the Owner.
 - 1) In trenches where dewatering is required, the pipe bedding material and embankment backfill shall be Type A or B as directed by the Owner.
 - c. Excavated native material will be allowed, provided that it is free draining and contains no organic materials, no rocks larger than 1/2-inch, clods or frozen lumps. A proctor of this material shall be submitted to the Owner for review and approval before use. If native backfill material is approved, on-site screening may be required by Owner to remove any rock material larger than 1/2-inch at no additional expense to the Owner. The location of such sites must be coordinated with the Owner.
3. Trench zone backfill for pipelines shall be any of Types A through H backfill materials or any mixture thereof.
 4. Final backfill material for pipelines under paved areas shall be Type G backfill material.
 5. Final backfill under areas not paved shall be the same material as that used for trench backfill, unless otherwise indicated.
 6. Trench backfill and final backfill for pipelines under structures shall be the same material as used in the pipe zone, except where concrete encasement is required by the Contract Documents.
 7. Aggregate base materials under pavements, curb and gutter, and sidewalk shall be Type G material constructed to the thickness indicated.
 8. Aggregate sub-base shall be Type M material.
 9. Backfill around structures shall be Types A through Type H materials, or any mixture thereof.
 10. Under structures where groundwater must be removed to allow placement of concrete, Type F material shall be used. Before the Type F material is placed, filter fabric shall be placed over the exposed foundation. Filter fabric shall be Mirafi 140 N, Mirafi 700X, or equal.
 11. Under all other structures, Type G or H material shall be used.
 12. Backfill used to replace pipeline trench over-excavation shall be a layer of Type F material with a 6-inch top filter layer of Type E material or filter fabric to prevent migration of fines for wet trench conditions or the same material as used for the pipe zone backfill if the trench conditions are not wet.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Section 01 00 00 - Administrative Requirements: Coordination and project conditions.
- B. Verify subdrainage, dampproofing, or waterproofing installation has been inspected.

- C. Verify underground tanks are anchored to their own foundations to avoid flotation after backfilling.
- D. Verify structural ability of unsupported walls to support loads imposed by fill.

3.2 PREPARATION

- A. Compact subgrade to density requirements for subsequent backfill materials.
- B. Cut out soft areas of subgrade not capable of compaction in place. Backfill with structural fill and compact to density equal to or greater than requirements for subsequent fill material.
- C. Scarify subgrade surface to depth of 8 inches.
- D. Proof roll to identify soft spots; fill and compact to density equal to or greater than requirements for subsequent fill material.

3.3 BACKFILLING FOR STRUCTURES, SITE WORK AND APPURTENANCES

- A. Backfill areas to contours and elevations with unfrozen materials as indicated on the Drawings.
- B. Systematically backfill to allow maximum time for natural settlement. Do not backfill over porous, wet, frozen or spongy subgrade surfaces.
- C. Each layer shall be thoroughly mixed as necessary to promote uniformity of material in each layer.
- D. Place material in continuous layers as follows:
 - 1. Subsoil Fill: Maximum 8 inches compacted depth.
 - 2. Structural Fill: Maximum 6 inches compacted depth.
 - 3. Granular Fill: Maximum 6 inches compacted depth.
- E. Employ placement method that does not disturb or damage other work.
- F. Maintain optimum moisture content of backfill materials to attain required compaction density.
- G. Slope grade away from building minimum 6 inches in 10 ft, unless noted otherwise.
- H. Make gradual grade changes. Blend slope into level areas.
- I. Shape and drain embankments and excavations, maintain ditches and drains to provide drainage at all times. Protect graded areas against action of elements prior to acceptance of work, and reestablish grade where settlement or erosion occurs.

- J. Bench hillside slopes or fills to key the embankment. Remove and re-compact a minimum of 12 inches normal to the slope of the hillside or fill as the embankment or fill is brought up in layers.
- K. Under surfaced or paved roads, driveways or parking areas, apply base course at uppermost layer of backfill to same thickness as existing driving surface, or 6 inches, whichever is greater. If paved, apply pavement patch to thickness equal to or greater than existing pavement.
- L. Remove surplus backfill materials from site.
- M. Leave fill material stockpile areas free of excess fill materials.
- N. Repair or replace remaining items damaged by excavation or filling.

3.4 BACKFILLING OF TRENCHES

- A. Place a minimum of 4 inches of bedding material in pipe trenches to lines and grades indicated on Drawings and compact before pipe is laid. Grade bedding material parallel to bottom of pipe.
- B. Do not place material when either the material or the surface upon which it is to be placed is frozen.
- C. Pipe zone backfill materials shall be manually spread around the pipe so that, when compacted, the pipe zone backfill will provide uniform bearing and side support.
 - 1. Exercise care not to damage pipe or appurtenances when placing embedment material.
 - 2. Maintain optimum moisture content of fill materials to attain required compaction density.
 - 3. Ensure material is placed to equal height on both sides of pipe to avoid unequal loading and possible lateral displacement of the pipe. Elevation difference of embedment between each side of pipe shall not exceed 6 inches.
 - 4. Place material in uniform layers.
 - 5. Work material into pipe haunches to prevent voids and achieve specified compaction under the haunches.
 - 6. No backfilling by machine methods permitted until a minimum of one foot of material has been placed by hand over the top of the pipe.
 - 7. Place material to a compacted depth of 12 inches over the top of the pipe, 15 inches of compacted depth over the top of the pipe in paved or traffic areas, and compacted by hand held compacting tools before other backfilling is done.
- D. If pipe laying operations are interrupted for more than 24 hours, cover pipe laid in the trench with backfill.
- E. When the bottom of the trench is unstable, an additional 4 inches shall be over-excavated and filled with bedding material before pipe is laid.

- F. Where rock is present and where there is concern that settling rocks in the surrounding material may rupture the pipeline, the amount of bedding material below and above the pipe shall be increased. In these cases there will be 8 inches of bedding material below the pipe and 15 inches above, as directed by the Owner.
- G. When using free-draining crushed rock or gravel for embedment on stretches longer than 300 feet, install trench plugs composed of silty, non-plastic material at 300 foot intervals to impede flow of trench water through the embedment.
- H. Under surfaced or paved roads, driveways or parking areas, apply base course at uppermost layer of backfill to same thickness as existing driving surface, or 6 inches, whichever is greater. If paved, apply pavement patch to thickness equal to or greater than existing pavement.

3.5 COMPACTION

- A. Do not place and compact soil under the following conditions:
 - 1. Ambient air temperature below freezing.
 - 2. Rain that creates puddles in clayey or silty materials.
 - 3. Ice or snow pockets visible in material being placed.
- B. Surface Preparation:
 - 1. Prepare surface so that first compacted lift will be placed on firm, stable base. Compact surface to specified percent compaction, if necessary.
 - 2. For water-retaining compacted fill, scarify and moisten surface to provide satisfactory bonding surface before placing first layer of material to be compacted.
 - 3. Do not place material to be compacted on frozen surface.
- C. Compact material in trenches in layers having approximately the same top elevation on both sides of the pipeline to avoid unequal loading and displacement of the pipe.
- D. Placement:
 - 1. Place soil to be compacted in horizontal layers.
 - 2. Blend materials as needed to ensure compacted fill is homogenous and free from lenses, pockets, streaks, voids, laminations and other imperfections.
- E. Compaction Procedures:
 - 1. Silty or Clayey Material:
 - a. Compact with mechanical impact tampers, tamping rollers, vibrating pad foot rollers, rubber tire rollers or other suitable compaction equipment.
 - b. Uniformly distribute equipment passes.
 - c. Compact in horizontal layers to compacted thickness of 6 inches or less.
 - 2. Cohesionless Free-Draining Material: Compact in horizontal layers to maximum compacted thickness of:
 - a. Tampers and rollers: 6 inches
 - b. Crawler-type tractors, vibrating drum rollers, surface vibrators or similar equipment: 12 inches
 - c. Saturation and internal vibration: Penetrating depth of vibrator.

3. When compacting pipe embedment material, exercise care not to damage the pipe or appurtenances with compaction equipment. Do not apply compaction equipment directly above the pipe.
 4. Demonstration: Lift thicknesses may vary depending on equipment and methods. Field adjustments to the specified lift thicknesses may be allowed or required. Contractor shall demonstrate that proposed equipment and methods will meet required compaction for the proposed lift thickness.
 5. Flooding and jetting is not allowed unless specifically approved by the Owner.
- F. Moisture Content:
1. Optimum moisture content for each soil type, whether native soil or imported material, shall be determined by the Modified Proctor method, ASTM D1557.
 2. Moisture content during compaction shall be no more than 2 percentage points wet or dry of optimum moisture content.
 3. Moisten or aerate material, as necessary, to provide specified moisture content. Add water to soil in increments that will permit moisture content to be uniform and homogenous through each layer after mixing.
 4. Add no more than 2 percent water to fill by sprinkling just prior to compaction when fill is clayey and contains dry clods of clay.
 - a. If clayey soil is more than 2 percent below optimum moisture, pre-conditioning and curing may be required to obtain uniform and homogenous distribution of moisture in clods.
 - b. Use of disks, harrows or rakes may be required to blend moisture prior to placement and compaction.
 5. For cohesionless soils, add water as necessary during compaction, as these soils are free-draining.
- G. Minimum Percent Compaction:
1. Note that all Percent Compaction values in these Technical Specifications and Drawings are based on Modified Proctor, ASTM D1557, unless otherwise noted.
 2. Over-excavation: Backfill of over-excavation to specified or directed lines shall be compacted to same percent compaction as embedment material or undisturbed foundation material, whichever is greater. If the in-place compaction of the undisturbed foundation material is greater than 95%, the over-excavation backfill may be compacted to 95%.
 3. Pipe Bedding Material: Place and compact pipe bedding material as indicated on Drawings for given soil classification, pipe wall thickness, and depth of cover. If native material meets grading requirements and is used, compact to 95%.
 4. Initial and Final Backfill: For trenches outside of roads, driveways, parking areas or wash crossings, compact to 90%, or to a density equal to that of the adjacent undisturbed soil, as directed by the Owner. For trenches within the driving surfaces of roads, driveways or parking areas (both paved and unpaved) or within wash crossings, compact to 95%.
 5. Embankments: Compact to same requirements as Final Backfill.
 6. Under buildings, tanks, slabs and other structures: Compact in accordance with Geotechnical report provided in Exhibit A.

3.6 TOLERANCES

- A. Section 01 00 00 - Quality Requirements: Tolerances.
- B. Top Surface of Backfilling within Building Areas: Plus or minus 1 inch from required elevations.
- C. Top Surface of Backfilling under Paved Areas: Plus or minus 1 inch from required elevations.
- D. Top Surface of General Backfilling: Plus or minus 1 inch from required elevations.
- E. Percent Compaction: Shall meet minimum required compaction as set forth in these specifications
- F. Moisture Content: As set forth in these specifications.

3.7 FIELD QUALITY CONTROL

- A. Section 01 00 00 - Execution Requirements: Testing, Adjusting, and Balancing.
- B. Perform laboratory material tests in accordance with ASTM D1557.
- C. Perform in place compaction tests in accordance with the following:
 - 1. Density Tests: ASTM D1556, ASTM D2167, or ASTM D2922.
 - 2. Moisture Tests: ASTM D3017.
- D. When tests indicate Work does not meet specified requirements, remove material, replace, compact, and retest.
- E. Provide test trenches and excavations including excavation, trench support, and groundwater removal for the soils testing operations, at the locations and depths required. The cost of all work associated with accessing, preparing, or time delays for testing to be included in the unit price of the applicable pay item being tested.
- F. Compaction testing shall be done to the extent such that the Owner can be reasonably assured that the backfill has been placed in accordance with the requirements of the Contract Documents, or as required by the utility for which the trenching is being provided, whichever is the more stringent. When a testing allowance is established on the Bid Form, the Owner will determine the testing frequency to be used throughout the project. If no allowance is included, the frequency of testing shall be at least once every 100 linear feet of trenching, or at least once every 200 square feet below structures, including manholes.
- G. Correction of Substandard Work: All fill and backfill represented by tests that fail to meet compaction, moisture content, soil classification or other specifications shall be uncovered as needed, replaced as needed, re-compacted and re-tested until all specifications are met, at no additional expense to the Owner.
 - 1. Elevations, lines and grades of replaced material, as well as of pipe and other structures resting against such material, shall be re-surveyed at the direction of

the Owner. Contractor shall correct elevations, lines and grades as needed, at no additional expense to the Owner.

3.8 PROTECTION OF FINISHED WORK

- A. Section 01 00 00 - Execution Requirements: Protecting Installed Construction.
- B. Reshape and re-compact fills subjected to vehicular traffic.

3.9 SCHEDULE

- A. Trenches:
 - 1. Pipe Bedding: Fill type D or native material described in Section 2.1.C
 - 2. Trench Zone Backfill: Fill Type A – H or any mixture thereof, to subgrade elevation. 6 inches thick, each lift, compact uniformly to 90 percent of maximum density or density of surrounding undisturbed soils, whichever is greater.
 - 3. Final Backfill Under Areas Not to be Paved: Fill Type A – H or any mixture thereof, to finish grade. 6 inches thick, each lift, compact uniformly to 90 percent of maximum density or density of surrounding undisturbed soils, whichever is greater.
 - 4. Final Backfill Under Areas to be Paved: Not Used
- B. Manholes:
 - 1. Backfill Under Manholes: Minimum 12” of fill Type G material to finish grade, 6 inches thick, each lift, compact uniformly to 95 percent of maximum density.
 - 2. Backfill Around Manholes: Fill Type A – H or any mixture thereof, to subgrade elevation. 6 inches thick, each lift, compact uniformly to 90 percent of maximum density or density of surrounding undisturbed soils, whichever is greater.
- C. Bore Pit:
 - 1. Annular Space Outside of Casing: See Section 33 05 23.16, Trenchless Utility Installation.
 - 2. Trench Zone Backfill: Fill Type A – H or any mixture thereof, to subgrade elevation. 6 inches thick, each lift, compact uniformly to 90 percent of maximum density or density of surrounding undisturbed soils, whichever is greater.
 - 3. Final Backfill Under Areas Not to be Paved: Fill Type A – H or any mixture thereof, to finish grade. 6 inches thick, each lift, compact uniformly to 90 percent of maximum density or density of surrounding undisturbed soils, whichever is greater.
 - 4. Final Backfill Under Areas to be Paved: Not Used.

END OF SECTION

SECTION 33 01 32

SEWER AND MANHOLE TESTING

PART 1 GENERAL

1.1 SUMMARY

- A. The Contractor shall perform all gravity pipe and manhole flushing and testing, as specified herein and in accordance with the requirements of the Contract Documents. The method used for testing must be approved by the Owner during the submittal process, as indicated below.
- B. The Contractor shall be responsible for conveying test water from the Owner-designated source to the point of usage and also for disposal, as required, of water used in the testing operations.
- C. Related Sections:
 - 1. Section 31 23 17 - Trenching.
 - 2. Section 33 05 23.16 – Trenchless Utility Installation.
 - 3. Section 33 31 00 - Sanitary Sewer Systems.
 - 4. Section 33 39 13 - Precast Concrete Manholes.

1.2 REFERENCES

- A. New Mexico Standard Specifications for Public Works Construction (NMSSPWC), produced by the "American Public Works Association" (APWA) - New Mexico Chapter.
 - 1. NMSSPWC Section 901 – Sanitary Sewer Collector and Interceptor Facilities.
- B. American National Standards Institute (ANSI) and American Society for Testing and Materials (ASTM)
 - 1. ANSI/ASTM C828 - Low-Pressure Air Test of Pipe Lines.

1.3 SUBMITTALS

- A. The Contractor's proposed plans for testing and inspection, and for water conveyance, control, and disposal, shall be submitted in writing. The Contractor shall also submit minimum 48-hour advance written notice of its proposed testing and inspection schedule for review and concurrence of the Owner.

PART 2 PRODUCTS

2.1 MATERIALS REQUIREMENTS

- A. Temporary valves, plugs, bulkheads, and other air pressure testing and water control equipment and materials shall be provided by the Contractor subject to the Owner's review. No materials shall be used which would be injurious to pipeline structure and

future function. Air test gages shall be laboratory-calibrated test gages and shall be recalibrated by a certified laboratory at the Contractor's expense prior to the leakage test, if required by the Owner.

PART 3 EXECUTION

3.1 GENERAL

- A. Unless otherwise specified, water for testing will be furnished by the Owner. However, the Contractor shall make all necessary provisions for conveying the water from the Owner-designated source to the points of use.
- B. Release of water from pipelines, after testing has been completed, shall be performed as reviewed by the Owner.
- C. All testing and inspection operations shall be performed in the presence of the Owner.

3.2 TESTING OF PIPING

- A. All gravity pipes shall be tested for exfiltration and/or infiltration and deflection, as specified. All pipe shall be backfilled prior to testing. All leakage tests shall be completed and approved prior to placing of permanent resurfacing. When leakage or infiltration exceeds the allowable amount, the Contractor at its expense, shall locate the leaks and make the necessary repairs or replacements in accordance with the Specifications to reduce the leakage or infiltration to the specified limits. Any individually detectable leaks shall be repaired, regardless of the results of the tests.
- B. Leakage Tests: All gravity sewer pipes shall be tested for leakage by one of the following three test methods as directed by the Owner and following the specific procedures outlined in the referenced sections of the New Mexico Standard Specifications for Public Works Construction, produced by the "American Public Works Association" (APWA) - New Mexico Chapter:
 - 1. Water Infiltration Test - Section 901.7.2
 - 2. Water Exfiltration Test - Section 901.7.3
 - 3. Air Pressure Test - Section 901.7.4
- C. All flexible and semi-rigid main line pipe shall be tested for deflection, joint displacement, or other obstruction by passing a rigid mandrel through the pipe by hand, not less than 30 days after completion of the trench backfill, but prior to permanent resurfacing. The mandrel shall be a full circle, solid cylinder, or a rigid, non-adjustable, odd-numbered leg (9 leg minimum) steel cylinder, approved by the Owner as to design and manufacture. The circular cross section of the mandrel shall have a diameter of at least 94 percent of the specified average inside pipe diameter of the pipe and the minimum length of the circular portion of the mandrel shall be equal to the nominal diameter of the pipe. Obstructions encountered by the mandrel shall be corrected by the Contractor.

- D. CCTV Inspection: The Contractor shall, after the sewer is completely installed, perform an internal inspection with a television camera and videotape. The finished tape shall be continuous over the entire length of the sewer between two manholes, or as specified by the Owner.
1. The newly installed pipe shall be visibly free of defects which may affect the integrity or strength of the pipe. If, in the opinion of the Owner, such defects exist, the pipe shall be repaired or replaced at the Contractor's expense.
 2. Any section of the pipe with a gash, blister, abrasion, nick, scar, or other deleterious fault greater in depth than ten percent (10%) of the wall thickness shall not be used and must be removed from the site.
 3. The Contractor shall perform post installation internal television inspections as required by the Owner. Each reach of sewer shall have audio description with appropriate stationing of services indicated. The data and stations are to be on the video. All such inspections shall be performed by personnel trained in locating breaks, obstacles and service connections by closed circuit color television.
 4. Post construction videos are to be submitted to the Owner for review prior to final payment. Should any portions of the inspection tapes be of inadequate quality or coverage, as determined by the Owner, the Contractor will have that portion filmed at no additional expense to the Owner. All original videos remain property of the Owner. The Contractor may, at the discretion of the Owner, retain a second copy.
 5. The camera shall not be moved through the pipe greater than 15 ft/minute.

3.3 TESTING OF MANHOLES

- A. All sewer manholes shall be hydrostatically or vacuum tested for leakage after installation, but prior to being backfilled. Prior to hydrostatic testing, all manholes shall be visually inspected for leaks. All leaks or cracks shall be repaired by the Contractor, prior to hydrostatic testing, to the satisfaction of the Owner. All pipes entering the manhole shall be sealed at a point outside the manhole walls so as to include testing of the pipe/manhole joints. The manhole shall be filled with water to a level 2 inches below the top of the frame. Safety lines shall be secured to all plugs utilized. After a period of at least one hour to allow the water level to stabilize, the manhole shall be refilled, and the water level shall be checked. The water level shall again be checked after a period of 4 hours. If the water level is reduced by more than 1/4-inch per foot of depth of the manhole, the leakage shall be considered excessive, and the Contractor shall be required to make all necessary repairs and retest the manhole. The exterior of the manhole shall be inspected during this period for visible evidence of leakage. Visible moisture, sweating, or beads of water on the exterior of the manhole shall not be considered leakage, but any water running across the surface will be considered leakage and shall be repaired to the satisfaction of the Owner regardless of the volume of water lost.
- B. Vacuum testing of sewer manholes is also acceptable. Vacuum testing shall be according to ASTM C1244. Procedure for vacuum testing shall be as follows:
1. Temporarily plug all pipes entering the manhole.
 2. The test head shall be placed inside the rim of the cast iron frame at the top of the manhole and inflated, in accordance with the manufacturer's recommendations.

3. A vacuum of at least ten inches of mercury (10" Hg) shall be drawn on the manhole. Shut the valve on the vacuum line to the manhole.
4. The pressure gauge shall be liquid filled, having a 3.5-inch diameter face with a reading from zero to thirty inches of mercury.
5. Manhole shall be considered to pass the vacuum test if the vacuum reading does not drop more than 1" Hg (i.e. from 10" Hg to 9" Hg) during the following minimum test times.

Minimum Test Times for Various Manhole Diameters			
MH Depth (feet)	4' Diameter MH	5' Diameter MH	6' Diameter MH
15 Feet or less	50 sec.	1 min. 5 sec.	1 min. 20 sec.
15.01 to 30 Feet	1 min. 20 sec.	1 min. 45 sec.	2 min. 10 sec.

END OF SECTION

SECTION 33 05 23.16

TRENCHLESS UTILITY INSTALLATION

PART 1 GENERAL

1.1 SUMMARY

- A. Section Includes:
 - 1. Excavation for approach trenches and pits.
 - 2. Casing pipe.
 - 3. Carrier pipe.
- B. Related Sections:
 - 1. Section 01 00 00 – Basic Requirements.
 - 2. Section 31 23 17 - Trenching.
 - 3. Section 31 23 23 - Backfill.
 - 4. Section 33 31 00 – Sanitary Sewer Systems.

1.2 UNIT PRICE - MEASUREMENT AND PAYMENT

- A. Jacked Pipe:
 - 1. Basis of Measurement: By linear foot measured on invert of jacked pipe from face to face of jacked pipe.
 - 2. Basis of Payment: Includes excavation, jacked pipe, carrier pipe, grout, spacers, accessories, tests, and backfill.

1.3 REFERENCES

- A. American Association of State Highway and Transportation Officials:
 - 1. AASHTO M133 - Standard Specification for Preservatives and Pressure Treatment Processes for Timber.
 - 2. AASHTO T180 - Standard Specification for Moisture-Density Relations of Soils Using a 4.54-kg (10-lb) Rammer and a 457-mm (18-in.) Drop.
- B. American Railway Engineering and Maintenance-of-Way Association:
 - 1. AREMA - Manual for Railway Engineering.
- C. ASTM International:
 - 1. ASTM A36/A36M - Standard Specification for Carbon Structural Steel.
 - 2. ASTM A53/A53M - Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless.
 - 3. ASTM A307 - Standard Specification for Carbon Steel Bolts and Studs, 60,000 psi Tensile Strength.
 - 4. ASTM A449 - Specification for Hex Cap Screws, Bolts and Studs, Steel, Heat Treated 120/105/90 ksi minimum tensile strength General Use.

5. ASTM A1011/A1011M - Standard Specification for Steel, Sheet and Strip, Hot-Rolled, Carbon, Structural, High-Strength Low-Alloy and High-Strength Low-Alloy with Improved Formability.
 6. ASTM C33 - Standard Specification for Concrete Aggregates.
 7. ASTM C150 - Standard Specification for Portland Cement.
 8. ASTM C404 - Standard Specification for Aggregates for Masonry Grout.
 9. ASTM D698 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Standard Effort (12,400 ft-lbf/ft³).
 10. ASTM D1557 - Standard Test Method for Laboratory Compaction Characteristics of Soil Using Modified Effort (6,000 ft-lbf/ft³).
 11. ASTM D2922 - Standard Test Method for Density of Soil and Soil-Aggregate in Place by Nuclear Methods (Shallow Depth).
 12. ASTM D3017 - Standard Test Method for Water Content of Soil and Rock in Place by Nuclear Methods (Shallow Depth).
- D. American Wood-Preservers' Association:
1. AWWA C1 - All Timber Products - Preservative Treatment by Pressure Process.
 2. AWWA C3 - Piles - Preservative Treatment by Pressure Process.
- E. American Welding Society:
1. AWS D1.1 - Structural Welding Code - Steel.
- F. National Utility Contractors Association:
1. NUCA - Pipe Jacking & Microtunneling Design Guide.
 2. NUCA - Trenchless Excavation Construction Equipment & Methods Manual.

1.4 DESIGN REQUIREMENTS

- A. Design casing pipe and tunnel liner joints of leak proof construction. Design for earth and/or other pressures present plus highway H20 loading or railway E80 loading with associated recommended impact loading.
1. Highway Crossings: Design tunnel for earth and/or other pressure loads present, plus AASHTO H20 live loading.
- B. Design bracing, backstops, and use jacks of sufficient rating for continuous jacking without stoppage, except for adding pipe sections and as conditions permit, to minimize tendency of ground material to "freeze" around casing pipe.

1.5 SUBMITTALS

- A. Section 01 00 00 - Submittal Procedures: Requirements for submittals.
- B. Installation Plan: Submit description of proposed construction plan, dewatering plan, and plan to establish and maintain vertical and horizontal alignment.
- C. Submit New Mexico Department of Transportation (NMDOT) occupancy permit for installations along or under public thoroughways and lands, if not already obtained by the Owner.

- D. Submit emergency response procedures to handle situations when conduit is compromised and jeopardizes integrity of installation or safety.
- E. Manufacturer's Certificate: Certify products meet or exceed specified requirements.

1.6 CLOSEOUT SUBMITTALS

- A. Section 01 00 00 - Execution Requirements: Requirements for submittals.
- B. Project Record Documents: Record actual locations of casing or tunnel liner, carrier pipe, and invert elevations.
- C. Identify and describe unexpected variations to subsoil conditions or discovery of uncharted utilities.
- D. Record actual depth of pipe at 10 feet intervals.
- E. Record actual horizontal location of installed pipe.
- F. Show depth and location of abandoned bores.

1.7 QUALITY ASSURANCE

- A. Perform Work in accordance with applicable New Mexico state standards, NUCA Trenchless Excavation Construction Equipment & Methods Manual, NUCA Pipe Jacking & Microtunneling Design Guide, AREMA guidelines.
- B. When boring, jacking or tunneling under State or Municipality highways and railroads, make application for and obtain occupancy permit.

1.8 QUALIFICATIONS

- A. Installer: Company specializing in performing work of this section with minimum 3 years documented experience.
 - 1. Work Experience: Include projects of similar magnitude and conditions.
 - 2. Furnish list of references upon request.

1.9 PRE-INSTALLATION MEETINGS

- A. Section 01 00 00 - Administrative Requirements: Pre-Construction Conference.
- B. Convene minimum one week prior to commencing work of this section.

1.10 DELIVERY, STORAGE, AND HANDLING

- A. Section 01 00 00 - Product Requirements: Requirements for delivering, handling, storing, and protecting products.

- B. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.
- C. Protect piping system pieces from entry of foreign materials and water by temporary covers, completing sections of work, and isolating parts of completed system.
- D. Accept system components on site in manufacturer's original containers or configuration. Inspect for damage.
- E. Use wooden shipping braces between layers of stacked pipe. Stack piping lengths no more than 3 layers high.
- F. Store field joint materials indoors in dry area in original shipping containers. Maintain storage temperature of 60 to 85 degrees F.
- G. Support casing and carrier pipes with nylon slings during handling.

1.11 ENVIRONMENTAL REQUIREMENTS

- A. Section 01 00 00 - Product Requirements: Environmental conditions affecting products on site.
- B. Conduct operations so as not to interfere with, interrupt, damage, destroy, or endanger integrity of surface or subsurface structures or utilities, and landscape in immediate or adjacent areas.

1.12 FIELD MEASUREMENTS

- A. Verify invert elevations prior to excavation and installation of casing.

1.13 COORDINATION

- A. Section 01 00 00 - Administrative Requirements: Requirements for coordination.
- B. Coordinate work with NMDOT, Owner, and utilities within construction area.

PART 2 PRODUCTS

2.1 CASING AND JACKING PIPE MATERIALS

- A. Furnish materials in accordance with New Mexico state standards.
- B. Steel Casing Pipe: ASTM A53/A53M, 35,000-psi minimum yield strength, casing diameter and minimum wall thickness as indicated on Drawings. Full circumference welded joints in accordance with AWS D1.1 to withstand excavation forces.

2.2 CARRIER PIPE

- A. Furnish materials in accordance with New Mexico state standards.
- B. Carrier Pipe shall be restrained-joint Polyvinylchloride (PVC).

2.3 POLYVINYLCHLORIDE RESTRAINED JOINT PIPE

- A. Polyvinylchloride plastic material for restrained joint pipe shall conform to ASTM D2241 and ASTM D1784 cell classification 12454. Pipe sizes shall conform to ASTM D2241. Pressure class/rating and dimension ratio shall be as recommended by the pipe manufacturer for trenchless utility installation.
- B. The pipe shall be manufactured with 100% virgin resin.
- C. The new pipe shall be homogenous throughout and shall be free of visible cracks, holes, foreign material, blisters, or other deleterious faults.
- D. The pipe shall have joints with non-metallic couplings featuring thermoplastic splines inserted into mating grooves in the pipe and coupling to provide a fully restrained joint. The couplings shall incorporate elastomeric sealing gaskets meeting the requirements of ASTM F477. The pipe shall be CertainTeed CertaFlo GreenLine restrained joint pipe, or equal.
- E. The pipe shall be green in color.

2.4 COVER MATERIALS

- A. See Section 31 23 23 - Backfill.

2.5 UNDERGROUND PIPE MARKERS

- A. Tracer Wire: Magnetic detectable conductor insulated with high density polyethylene (HDPE) or UF- XHHW in accordance with physical and electrical properties per ASTM D-1248.
 - 1. Tracer wire shall be rated for "Direct Burial", 30 volts, and be appropriate for installation in trenchless utility installation applications,
 - 2. Tracer wire shall be constructed of copper clad hard drawn extra high strength (EHS) tracer wire with a steel core or Owner-approved equal, and
 - 3. Tracer wire must be appropriately sized and installed to be compatible with the pullback rating of the equipment being used.
- B. Splice Connectors: Model LV 9500 Blazing Snap-locking waterproof connectors pre-filled with silicone or Owner-approved equal.

2.6 ACCESSORIES

- A. Pipe Casing End Seals: Seamless, vulcanized edge, pull-on casing end seals composed of a minimum 1/8" thick 60 durometer synthetic neoprene rubber. Includes 1/2" wide T304 stainless steel bandings with 100% non-magnetic worm gear mechanism.
- B. Pipe Casing Spacers: Polyethylene Ranger II Midi 100 Model casing spacer, or approved equal (capacity of 875 lbs. per spacer). Spacers shall support the carrier pipe within the casing while maintaining a minimum clearance of 1" between the casing inner diameter and the spacer outer diameter. Install spacers per manufacturer's recommendations.
- C. Pressure Grout Mix: One part portland cement, and 6 parts mortar sand mixed with water to consistency applicable for pressure grouting.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Section 01 00 00 - Administrative Requirements: Verification of existing conditions before starting work.
- B. Verify connection to existing piping system size, location, and invert elevations are in accordance with Drawings.

3.2 PREPARATION

- A. Identify required lines, levels, contours, and datum locations.

3.3 DEWATERING

- A. Intercept and divert surface drainage precipitation and groundwater away from excavation through use of dikes, curb walls, ditches, pipes, sumps or other means.
- B. Develop substantially dry subgrade for prosecution of subsequent operations.
- C. Comply with New Mexico state standards and requirements for dewatering to any watercourse, prevention of stream degradation, and erosion and sediment control.

3.4 EXISTING WORK

- A. Maintain access to existing community facilities and homes as well as other remaining active installations requiring access. Modify installation as necessary to maintain access.

3.5 PITS OR APPROACH TRENCHES

- A. Excavate approach trenches or pits in accordance with installation plan and as site conditions require.

- B. Ensure casing entrance face as near perpendicular to alignment as conditions permit.
- C. Establish vertical entrance face at least 1 foot above top of casing.
- D. Install dewatering measures and excavation supports as specified in Section 31 23 17.

3.6 CASING PIPE INSTALLATION

- A. Boring:
 - 1. Push pipe into ground with boring auger rotating within pipe to remove spoil. Do not advance cutting head ahead of casing pipe except for distance necessary to permit cutting teeth to cut clearance for pipe. Arrange machine bore and cutting head to be removable from within pipe. Arrange face of cutting head to provide barrier to free flow of soft material.
 - 2. When unstable soil is encountered during boring retract cutting head into casing to permit balance between pushing pressure and ratio of pipe advancement to quantity of soil.
 - 3. When boring is obstructed, relocate, jack, or tunnel as directed by Owner.
- B. Jacking
 - 1. Construct adequate thrust wall normal to proposed line of thrust.
 - 2. Impart thrust load to pipe through suitable thrust ring sufficiently rigid to ensure uniform distribution of thrust load on full pipe circumference.

3.7 PRESSURE GROUTING

- A. Pressure grout annular space between casing pipe and surrounding earth. See Section 03 05 00.

3.8 CARRIER PIPE INSTALLATION

- A. Clean, inspect, and handle pipe in accordance with Section 33 11 00.
- B. Place carrier pipe in accordance with Section 33 11 00. Exercise care to prevent damage to pipe joints when carrier pipe is placed in casing.
- C. Support pipeline within casing on spacers at intervals identified on Drawings or according to manufacturer's instructions if interval is not identified on Drawings, so no external loads are transmitted to carrier pipe. Attach supports to barrel of carrier pipe; do not rest carrier pipe on bells.
- D. Install pipe casing end seals at ends of casing.

3.9 TOLERANCES

- A. Section 01 00 00 - Quality Requirements: Tolerances.
- B. Do not over cut excavation by more than 1 inch greater than outside diameter of casing pipe.

- C. Maximum Casing Pipe Variation From Horizontal Position: 0.10 feet
- D. Maximum Carrier Pipe Variation from Horizontal Position: Sewer pipe must be installed at slopes and inverts designated in Drawings and meet testing requirements of Section 33 01 32.
- E. Maximum Casing Pipe Variation From Vertical Elevation: 0.10 feet
- F. Maximum Carrier Pipe Variation from Vertical Elevation: Sewer pipe must be installed at slopes and inverts designated in Drawings and meet testing requirements of Section 33 01 32.
- G. Minimum Horizontal Clearance from Other Utilities: 10 feet unless specified otherwise in plans.
- H. Minimum Vertical Clearance from Other Utilities: 24 inches unless specified otherwise in plans.
- I. When pipe installation deviates beyond specified tolerances, abandon bore, remove installed pipe, re-bore, and reinstall pipe in correct alignment.
- J. Fill abandoned bores greater than 3 inches in diameter with grout or flowable fill material.

3.10 FIELD QUALITY CONTROL

- A. Section 01 00 00 - Execution Requirements: Testing, adjusting, and balancing.
- B. Compaction Testing: As specified in Section 31 23 23.
- C. When tests indicate Work does not meet specified requirements, remove Work, replace and retest.

3.11 MANUFACTURER'S FIELD SERVICES

- A. Section 01 00 00 - Quality Requirements: Requirements for manufacturer's field services.
- B. Furnish field technical assistance during following periods of casing installation:
 - 1. Unloading of casing materials and components.
 - 2. Prior to commencing excavation and during excavation as requested.

3.12 REMOVAL OF FACILITIES AND CONTROLS

- A. Remove temporary facilities for casing installation and jacking operations in accordance with Section 01 00 00.

END OF SECTION

SECTION 33 31 00

SANITARY SEWER SYSTEMS

PART 1 GENERAL

1.1 SUMMARY

- A. Section includes the furnishing and installation of all underground PVC non-pressure pipe for gravity sewer lines and all appurtenant work, complete in place, in accordance with the requirements of the Contract Documents.
- B. Related Sections:
 - 1. Section 01 00 00 – Basic Requirements.
 - 2. Section 03 05 00 - Basic Concrete Materials and Methods.
 - 3. Section 31 23 17 - Trenching.
 - 4. Section 31 23 23 - Backfill.
 - 5. Section 33 06 23.16 – Trenchless Utility Installation
 - 6. Section 33 39 13 – Precast Concrete Manholes.

1.2 UNIT PRICE - MEASUREMENT AND PAYMENT

- A. Pipe and Fittings:
 - 1. Basis of Measurement: By the linear foot.
 - 2. Basis of Payment: Includes hand trimming excavation, piping and fittings, all valves and appurtenances not listed separately on the Bid Form, bedding, and connection to public utility.
 - 3. The cost of compaction testing shall be considered incidental to related work and not be reimbursed. The cost of work associated with hydrostatic pressure testing and testing of material welds, etc. shall be considered incidental to related work and not be reimbursed. Work shall be coordinated and directed by Owner.

1.3 REFERENCES

- A. American Society for Testing and Materials (ASTM)
 - 1. ASTM D1784 - Specification for Rigid Polyvinyl Chloride (PVC) Compounds and Chlorinated Polyvinyl Chloride (CPVC) Compounds, Cell Classification 12454 or 12364.
 - 2. ASTM D2321 - Recommended Practice for Underground Installation of Flexible Thermoplastic Sewer Pipe.
 - 3. ASTM F477 - Specification for Elastomeric Seals (Gaskets) for Joining Plastic Pipe.
 - 4. ASTM F679 - Specification for Polyvinyl Chloride (PVC) Large-Diameter Plastic Gravity Sewer Pipe (18" to 24").
 - 5. ASTM D3034 - Specifications for Polyvinyl Chloride (PVC) Small Diameter (less than 18 inch) Plastic Gravity Sewer Pipe (4" to 15").
 - 6. ASTM D3212 - Joints for PVC Pipe Using Rubber Gaskets.

1.4 SUBMITTALS

- A. The Contractor shall submit to the Owner, upon request, samples of materials proposed for use on the work. Requested samples shall be clearly marked to show the manufacturer's name and product identification and shall be submitted along with the manufacturer's technical data and application instructions.
- B. Testing Plan: Contractor must submit proposed testing procedure and equipment to be employed for testing of lines for approval by Owner.
- C. Shoring and Bracing Drawings: The Contractor's attention is directed to the applicable sections of these Specifications, which may require the submittal of shoring and bracing drawings by the Contractor. Contractor to address if OSHA approved trench boxes are to be used.
- D. Shop Drawings: The Contractor shall submit shop drawings, manufacturer's details and specifications, and laying diagrams of all pipe, joints, bends, special fittings, and piping appurtenances in accordance with the applicable sections of these Specifications.
- E. The Contractor shall provide manufacturer's certificates for all materials indicating conformance to the reference specifications.

1.5 QUALITY ASSURANCE

- A. All materials testing shall be based upon applicable ASTM Test Methods referenced herein for the materials specified. All costs of such inspection and tests shall be borne by the Contractor.
- B. See Section 33 01 32 - Sewer and Manhole Testing.
- C. Certificates: Manufacturer's notarized certificates of compliance shall be furnished by the Contractor.
- D. The pipe shall be subjected to the specified flattening resistance, impact resistance and stiffness tests.

1.6 CLEAN-UP

- A. In addition to the requirements of other applicable sections of these Specifications, the Contractor, upon completion of backfilling and grading over trenches, shall remove all excess materials and equipment from the site.

PART 2 PRODUCTS

2.1 GENERAL

- A. All polyvinyl chloride (PVC) pipe will be furnished in the sizes indicated on the Drawings. All pipe, in compliance with this Specification, shall be continuously and permanently

marked with the manufacturer's name and code, pipe size, PVC minimum cell classification, pipe stiffness designation, and the designation ASTM D3034 SDR35 or ASTM F679 SDR35

- B. Include the year, month, day, shift, plant and extruder of manufacturer. This coding shall be done in conjunction with records to be held by the manufacturer for 2 years, covering quality control tests, raw material batch number, and other information deemed necessary by the manufacturer.

2.2 PIPE

- A. See Section 33 05 23.13 Horizontal Directional Drilling or 33 05 23.16 Trenchless Utility Installation for pipe to be used within steel casing.
- B. All PVC pipe shall be joined by compression joints unless otherwise shown or specified, and shall conform to the following requirements:
 - 1. PVC pipe shall conform to the requirements of ASTM F679 for all pipe 18 inches in diameter and greater. PVC pipe up to and including 15-inch diameter pipe shall conform to ASTM D3034 SDR35.
 - 2. Joints for PVC pipe shall be rubber gasket joints conforming to ASTM D3212. Rubber gaskets for compression type joints for PVC pipe and fittings shall conform to the requirements of ASTM F477.
 - 3. Pipe will be bell and spigot joints.
 - 4. Pipe shall be green for sewer.

2.3 BEDDING MATERIAL

- A. Unless otherwise specified or shown, all material used for pipe bedding shall conform to the requirements of Section 31 23 23 – Backfill.

2.4 UNDERGROUND PIPE MARKERS

- A. Furnish materials in accordance with the most recent edition of New Mexico Standard Specifications for Public Works Construction , with latest revisions.
- B. Tracer Wire: 12 AWG, Solid Copper, Single Conductor, 30 volts, Green Jacket, UF-XHHW wire or equal, for underground installation.
- C. Underground Utility Marking Tape: Bright colored, continuously printed, minimum 6 inches wide by 4 mils thick, manufactured for direct burial service, imprinted with "SEWER LINE " (or similar wording) in large letters, on green tape in conformance with APWA color code specifications for underground tape systems. The tape shall be constructed of material that is impervious to alkalis, acids, chemical reagents, and solvents found in the soils.

2.5 ABOVEGROUND PIPE MARKERS

- A. Carsonite marker posts, as per corresponding detail in the Drawings, color green for sewer and comply with industry standards, with Owner-specified decals furnished and installed by the Contractor.
- B. Install at least every 100' and on either side of road or wash crossings.

PART 3 EXECUTION

3.1 GENERAL

- A. All laying, jointing, and testing for defects and for leakage shall be performed in the presence of the Owner, and shall be subject to his approval before acceptance. All material found during the progress to have defects will be rejected and the Contractor shall promptly remove such defective materials from the site of the work.
- B. Installation shall conform to the requirements of ASTM D2321 and to the supplementary requirements or modifications specified herein. Wherever the provisions of this Section and the requirements of ASTM D2321 are in conflict, the more stringent provision shall apply.
- C. The internal diameter of the pipe barrel shall not be reduced by more than 3 percent of its base diameter when measured after backfilling and compacting but prior to final paving. If this amount of allowable pipe deflection is exceeded, the Contractor shall uncover the pipe and shall improve the quality of the pipe zone backfill material and/or compaction to the extent that the allowable pipe deflection is not exceeded. Excessive deflection shall be checked by pulling a mandrel through the pipe.
- D. Minimum cover over the sewer line shall be 30". If cover is less than 36", a concrete cap shall be installed per Drawings.
- E. Where sewer and water cross, pipes shall cross perpendicularly. Where sewer and water cross with less than 24" clearance OR where water crosses below sewer, sewer pipe shall be encased per Drawings for 10 feet in both directions. Minimum vertical separation of water and sewer shall be 12". Where sewer is less than 10 feet horizontally from water, sewer pipe shall be encased per Drawings.

3.2 TRENCHING AND BACKFILL

- A. Trench excavation and backfill shall conform to the requirements of the applicable sections of these specifications.

3.3 LAYING PIPE

- A. The pipe shall be installed in accordance with the requirements of ASTM D2321 and as specified herein. The sections shall be closely jointed to form a smooth flow line. Immediately before placing each section of pipe in final position for jointing, the bedding for the pipe shall be checked for firmness and uniformity of surface.

- B. Proper implements, tools, and facilities as recommended by the pipe manufacturer's standard printed installation instructions shall be provided and used by the Contractor for safe and efficient execution of the work. All pipe, fittings, and accessories shall be carefully lowered into the trench by means of derrick, ropes, or other suitable equipment in such a manner as to prevent damage to pipe and fittings. Under no circumstances shall pipe or accessories be dropped or dumped into the trench.
- C. Cutting and machining of the pipe shall be accomplished in accordance with the pipe manufacturer's standard procedures for this operation. Pipe shall not be cut with a cold chisel, standard iron pipe cutter, or any other method that may fracture the pipe or will produce ragged, uneven edges.
- D. The pipe and accessories shall be inspected for defects prior to lowering into the trench. Any defective, damaged or unsound pipe shall be repaired or replaced. All foreign matter or dirt shall be removed from the interior of the pipe before lowering into position in the trench. Pipe shall be kept clean during and after laying. All openings in the pipe line shall be closed with water tight expandable type sewer plugs or PVC test plugs at the end of each day's operation or whenever the pipe openings are left unattended. The use of burlap, wood, or other similar temporary plugs will not be permitted.
- E. Adequate protection and maintenance of all underground and surface utility structures, drains, sewers, and other obstructions encountered in the progress of the work shall be included in the unit price of the item.
- F. Where the grade or alignment of the pipe is obstructed by existing utility structures such as conduits, ducts, pipes, branch connections to main sewers, or main drains, the obstruction shall be permanently supported, relocated, removed, or reconstructed by the Contractor in cooperation with owners of such utility structures. Unless otherwise indicated, this work shall be included in the unit price of the bid item.
- G. Pipe grade shall be maintained using laser alignment equipment. Laser will be set at manhole locations. Batter boards for grades can be used as approved by Owner.
- H. Install tracer wire continuous, taped to top of pipeline at regular intervals not exceeding 24"; coordinate with Sections 31 23 17 and 31 23 23. Continuity of tracer wire shall be tested periodically as indicated by Owner, and prior to final acceptance of work. Any segment of tracer wire that fails the continuity test shall be repaired or replaced by Contractor at no additional cost to Owner.
- I. Expose tracer wire at every surface penetration (i.e. manholes, etc.). Protect wire ends with wire caps and protect from corrosion. Provide extra length of tracer wire at each structure, so tracer wire can be pulled 3 feet out top of structure for connection to detection equipment.
- J. Install underground utility marking tape continuous, buried directly above the pipe with an 18-inch maximum bury depth. Coordinate with Section 31 23 17 and 31 23 23.
- K. Install aboveground utility markers as specified in 2.5.

3.4 HANDLING

- A. Handling of all pipe shall be done with care to ensure that the pipe is not damaged in any manner during storage, transit, loading, unloading, and installation.
- B. Pipe shall be inspected both prior to and after installation in the trench or ditch and all defective lengths shall be rejected and immediately removed from the working area.

3.5 FIELD JOINTING

- A. Each pipe compression type joint shall be joined with a lock-in rubber ring and a ring groove that is designed to resist displacement during pipe insertion. Joints shall be made as recommended by pipe manufacturer.
- B. A thin film of lubricant shall be applied to the exposed clean surface of the interior of the bell end and to the outside of the clean pipe end. Pipe joint lubricant other than that furnished with the pipe or approved by the pipe manufacturer shall not be used. The end of the pipe shall be then forced into the bell end to complete the joint.
- C. The pipe shall not be deflected either vertically or horizontally in excess of the printed recommendations of the manufacturer of the coupling. No deflection shall be allowed at the joints.
- D. When pipe laying is not in progress, the open ends of the pipe shall be closed to prevent trench water from entering pipe. Adequate backfill shall be deposited on pipe to prevent floating of pipe. Any pipe that has floated shall be removed from the trench, cleaned, and re-laid in an acceptable manner. No pipe shall be laid when, in the opinion of the Owner, the trench conditions or weather are unsuitable for such work.

3.6 INSTALLATION OF FITTINGS

- A. Fittings shall be installed utilizing standard installation procedures. Fittings shall be lowered into trench by means of rope, cable, chain, or other acceptable means without damage to the fittings. Cable, rope, or other devices used for lowering fitting into trench, shall be attached around exterior of fitting for handling. Under no circumstances shall the cable, rope or other device be attached through the fitting's interior for handling. Fittings shall be carefully connected to pipe or other facility, and joint shall be checked to insure a sound and proper joint.

3.7 ANCHOR BLOCKS

Not Used.

3.8 TESTING

- A. Field testing of gravity sewer pipe shall conform to the requirements specified herein and/or to accepted industry standards as approved by the Owner.
- B. All sanitary sewer lines will be tested and inspected accordance with Section 33 01 32.

END OF SECTION

SECTION 33 39 13

PRECAST CONCRETE MANHOLES

PART 1 GENERAL

1.1 SUMMARY

- A. Section includes the furnishing and installation of all prefabricated manholes and vaults, complete with adapter rings, steps (if required), frame, cover, warning signs, pipe connections, and cast-in-place or prefabricated base, and any other appurtenances, as shown and specified herein, in accordance with the requirements of the Contract Documents. Precast manholes and vaults for this project are for equipment placement, protection and access.
- B. Related Sections:
 - 1. Section 01 00 00 – Basic Requirements.
 - 2. Section 31 23 17 – Trenching.
 - 3. Section 31 23 23 – Backfill.
 - 4. Section 31 25 13 – Erosion Control Devices.
 - 5. Section 33 01 32 – Sewer and Manhole Testing
 - 6. Section 33 31 00 – Sanitary Sewer Systems.

1.2 REFERENCES

- A. American Society for Testing and Materials (ASTM)
 - 1. ASTM A48 - Specification for Gray Iron Castings
 - 2. ASTM C150 - Specification for Portland Cement
 - 3. ASTM C478 - Precast Reinforced Concrete Manhole Sections
 - 4. ASTM C443 - Rubber Gaskets
 - 5. ASTM C270 - Cement Mortar

1.3 SUBMITTALS

- A. Furnish complete shop drawings for all precast manhole sections, cast iron frames and covers, and appurtenances for review by the Engineer.

1.4 QUALITY ASSURANCE

- A. After installation, the Contractor shall demonstrate that all manholes have been properly installed, level, with tight joints, at the correct elevations and orientations, and that the testing and backfilling has been carried out in accordance with the Contract Documents and the standards and specifications of the utility provider.

PART 2 PRODUCTS

2.1 MATERIALS

- A. Manholes shall be constructed of precast concrete manhole rings as shown. Precast concrete rings shall be manufactured by a process that will produce a dense, homogeneous concrete ring of high quality. The rings shall conform to the requirements of ASTM C478. Cement used in manufacturing the rings shall be Type I/II Portland Cement as specified in ASTM C150. Manhole barrel sections shall be provided with manhole steps as specified or called for on the details. Steps shall be equally spaced, with the first step being placed 2 feet from the top of the manhole ring. Mortar for bonding joints shall consist of one part cement to 2-1/2 parts of sand, by volume. Manholes with precast concrete bases and formed channel inverts to match the adjoining pipes. Precast manhole top sections shall be eccentric conical shape. Precast manhole bases shall have cast-in-adapters to accommodate a watertight connection with the sewer pipe. Precast manhole barrels shall be joined with polybutylene “rubberneck” or “ramneck” to form a watertight seal between barrel sections.
- B. Castings for manhole frames and covers shall be non-rocking and shall conform to the requirements of ASTM A48, Class 30. Unless otherwise shown, cast iron covers and frames shall be heavy duty, traffic weight rated as manufactured by NEENAH Foundry Company, meeting NEENAH R-1924 or equal, with embossed lettering to meet the requirements of the OWNER. Frame and cover shall be designed for H-20 traffic loading.
- C. When required, manhole steps shall be steel reinforced plastic, reinforcing shall be 3/8-inch diameter. Plastic shall be copolymer polypropylene meeting requirements of ASTM D4101, Grade 49108.

PART 3 EXECUTION

3.1 WORKMANSHIP

- A. All precast concrete manholes shall be installed in strict conformance with the manufacturer’s written instructions, on a well-compacted foundation, as specified in the applicable sections of these Specifications. Manhole excavations shall be sufficiently deep to allow a minimum of 12 inches of bedding material below the manhole base on top of 12 in. of native soil compacted to 95% maximum density.
- B. Manhole bases shall be set and leveled before receiving the barrel sections.
- C. Manhole barrels will be set to form watertight seals between barrel sections. Lifting holes will be grouted to seal out water. Manhole barrels will be set with the steps, when required, being aligned under the eccentric opening and directly over the effluent or downstream side of the manhole.
- D. Inverts will not be poured until the manhole is sufficiently backfilled to insure manhole structure is stable. Invert shall be formed or shaped to have invert the same size as the larger of the adjoining sewer line.

- E. Ring and cover will be adjusted with concrete or brick rings, set with non-shrink grout, not more than 6 inches in height. Ring and cover will form a watertight seal between the frame and manhole barrel or adjusting rings by using a bituminous sealing material.

END OF SECTION