

SIERRA COUNTY
STATE OF NEW MEXICO



RFP #2019-05-009
FLOOD CONTROL CUCHILLO NEGRO ARROYO
BANK STABILIZATION

NOTICE TO BIDDERS:

1. This Addendum is issued to all registered plan holders and shall be published in all locations where the original RFB is published. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
2. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
3. All terms, conditions, and requirements of the original project manual and construction documents shall remain in place unless explicitly mentioned in this Addendum.

CLARIFICATION

1. Construction Note 19, Sediment/ Silt Clean up Remediation: Contractor shall coordinate clean up with NMDOT as no work is authorized beyond the Ordinary High Water Mark (OHWM). Clean up remediation will be taken care of when spur dikes are installed by owner and general contractor (refer Sheet C-102).
2. Pre-Con sign in sheet will be added to this Addenda 2

ADDENDUM NO. 2
January 15, 2020

GENERAL QUESTIONS:

1. **How will payment be made for piles if the contractor hits refusal?**
There is no likelihood of sheet pile refusal based on Soils Investigation Report issued on November 21, 2016. The Soils Investigation Report has been provided as a part of this addendum.
As per sheet 67 of RFP 2019-05-009, Contractor shall submit a schedule of values based on the Summary of Quantities on Sheet C-003 of the approved construction documents. The schedule of values will be used to establish unit pricing for work performed.
2. **Is vibration monitoring required?**
According to NMDOT Standard Specifications for Highway and Bridge Construction, Section 617, the contractor shall perform vibration monitoring to determine if engineered structures and sensitive features are affected. The NMDOT Specifications can be found in https://dot.state.nm.us/content/dam/nmdot/Plans_Specs_Estimates/2019_Specs.pdf.
3. **What does keyed note 21 apply to?**
Keyed note 21 applies to Borrow and Base Course Type II.
Testing requirements are identified in cross sections on Sheet C-301. Testing frequency is as per NMDOT Testing Requirements. The item number for Borrow is 7 in Summary of Quantities, Sheet C-003 (refer NMDOT Specs, Section 203 for more information). Similarly, the item number for Base Course Type II is 8 in Summary of Quantities, Sheet C-003 (NMDOT Specs, Section 303).
4. **Is payment for stockpiled materials allowed?**
Partial payment for stockpiles materials will not be allowed for this project.
5. **Is ESZ 19-700 section acceptable as an alternative to PZC 18 section?**
During Bidding, alternative materials will not be accepted.
6. **Is this a FEMA project? If so, is there a preference?**
This is a FEMA related project. There is no preference requirement.
7. **Are there any monuments located?**
There have been no monuments identified for this project.
8. **In the RFP I have GF-4 and GF-98, would we be able to amend and open up to GB- 98?**
A GB-98 contractor may not bid and contract as the prime contractor of an entire project if the major portion of the work to be performed, based on dollar amount, is covered by the scope of any FA or any of the following GF classifications: GF-1, GF-2, GF-3, GF-4, GF-6, GF-8 AND GF-9.
9. **Can you provide us with a schedule of values on the Cuchillo Negro Arroyo Bank Stabilization project in CY., LF. Etc.**
Per the engineered estimates: 520' of 30' PZC18 sheet pilings, 1400 sq yds earthwork/grading, 1200 sq yds of 6" base course

ADDENDUM NO. 2
January 15, 2020

SOIL INVESTIGATION REPORT:

- 1. Soils Investigation Report to be provided in this Addendum. See additional documents:

Insert Signature

By: Teodoro Cano-Mota, PE
Project Manager

Bidder Acknowledgement:

Bidder Name: _____

Date: _____

**RFP# 2019-05-009 CONSTRUCTION SERVICES CUCHILLO NEGRO ARROYO BANK
STABILIZATION FOR SIERRA COUNTY**

PLEASE, WRITE LEGIBLY ~ UPDATE ANY CHANGES- MAGELLEN

Project: MANDATORY PRE-PROPOSAL CONFERENCE ON: January 7, 2020.
Location: NM-51, MP, (Cuchillo), Truth or Consequences, NM 87901
Date and Time: 07-JAN-2020 @ 11:00 AM
Facilitator: COUNTY OF SIERRA and FLOOD COMMISSION
Place/Room: CUCHILLO CREEK, NM

SIGN IN	FIRM/COMPANY/DEPARTMENT	CONTACT PHONE NUMBER	CONTRACT EMAIL
Jaelyn Halpin	Sierra County	575-894-6215	jhalpin@sierra.co.org
Kenny Smith	Kings Industries Corp	817-243-9625	KENNY@KINGS-PROJECTS.COM
Diana Mendoza	REVESTAOE CONSTRUCTION	575-523-2600	REVESTAOECONSTRUCTION@OUTLOOK.COM
Ben Chitwood	SPECTRUM OF W. M.	915-248-7778	SPECTRUM@C@GMAIL.COM
Travis Abuel	Sierra Co.	575-740-1247	tathwell@sierraco.org
Ryan Edgmon	SmithCO	575-740-3492	ryan@smithco.cc
Hilda Gandarilla	SmithCO	575 694 5713	Hilda@smithco.cc
Kerry Garnett	Garnett Western	575-644-1070	garnettwestern@windstream.net
Louie Saldivar	Smith & Aguirre East	575-445-5579	Louie@smithandaguirre.com
Jerome Garcia	Southwest General Construction Inc	575-649-2752	jerome@southwestgci.com
CHRISTIAN HASSE	HASSE CONTRACTING	5051400.2336	CHASSE@HASSECON.COM
CLINTA GIBBS	CF PADILLA LLC	504/400-4020	clint@cpadillallc.com

SIGN IN	FIRM/COMPANY/DEPARTMENT	CONTACT PHONE NUMBER	CONTRACT EMAIL
David Campbell	Pelligrino - Assoc	505-250-7535	dcampbell@pelligrino.us
Helen Hugel	Pelligrino - Assoc	505-250-6710	ahugel@pelligrino.us