

Addendum #1 for 2223-005 Metal Building 10/31/2022- Recognition of the Addendum is not necessary.

- 1) What type of insulation are y'all wanting, there is two types of aluminum foil looking bubble wrap and there is a 2" fiberglass with a vapor barrier? Do you want metal vertical or horizontal on the roof and walls? **2" fiberglass for the insulation and vertical roofing**