



ADDENDUM # 2

ITB REBID 2023-818, SENIOR CENTER KITCHEN RENOVATION

ADDENDUM DATE: January 12, 2023. **Revised/ Re-Issued February 23, 2023**

BID DUE DATE/ TIME: **March 16, 2023, 3:00 PM**

This addendum includes the following:

1. Revisions to Appendix A, Technical Specifications

For further information contact:
Joni Gay, Procurement Manager, CPO
Phone: 505-334-7656
Fax: 505-334-7649
email: jgay@aztecnm.gov

January 11, 2023

This addendum takes precedence over work shown on the Plans and described in the Specifications and shall become a part of the Contract Documents. All work not specifically noted as changed or modified shall be furnished and installed as shown on original Drawings and as outlined in the original specifications.

Specifications:

Item #1: Specification Section 08 3300, 2.4, A.2

- A. Curtain shall be extruded, interlocking aluminum slats of 22 gauge steel in lieu of stainless steel shown.

This precedes notes shown on Window Types B and C, Sheet A2.1.

- B. Guides shall be anodized aluminum in lieu of stainless steel shown

Drawings:

Item #2: Sheet A1. Delete Keyed Notes # 1, 2 and 8 which show removal of the existing door and frame as well as wall framing. This door and wall layout will remain.

Item #3: Sheet A2.1. Door Schedule. Delete Door 104.

Item #4: Sheet A2. Window Type A in Room 110. Provide 4x4x1/4" lintel angle on interior side prior to removal of CMU. Set window with break metal sill/drip to match frame. Finish sides and head with 2 coat stucco system to match. Wrap drywall to frame on interior, all sides.

Item #5: Sheet A1. Keyed Note #14. The temporary wall to separate the work area may utilize prefabricate dust barrier system such as Zipwall in lieu of wood or steel stud framing.

Item #6: Sheet A2.1. Window Type A. Window shall be clear anodized finish in lieu of the bronze anodized shown.

End of Addendum #2