



ADDENDUM NO. 1

Issue Date: October 11, 2019

Project Name: Sandridge Golf Club Fencing along 58th Ave

Bid Number: 2020012

Bid Opening Date: October 31, 2019

This addendum is being released to answer questions received to date.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid will be declared non-responsive.**

Questions and Answers

1. Is it 9 gage core chain-link fence or 9 gage finish?
It is 9 gauge black wire finish. Additionally, line post shall be 1 5/8" and top rail 1 3/8".