

**ADDENDUM NUMBER 2
BID NUMBER IFB 21-005**

Monument Sign for Washington High School

ISSUED: March 22, 2021

PURCHASING DEPARTMENT
UNIFIED SCHOOL DISTRICT 500
2010 N. 59th STREET, ROOM 370
KANSAS CITY, KANSAS 66104
(913) 551-3200

Note the following changes to the above-mentioned bid. This information is to be taken into consideration when responding to the original bid document.

1. Response to Bidder Question:

1	Can contractor pull power from the nearby parking lot light that is approximately 150' west? If KCKPS
KCKPS	The power source for the sign tied to parking lot or streetlights would be detrimentally impacted by those sources controlled by a timer and not powered during the day
2	Does KCKPS want to pull power from the maintenance building? Is there a power pole directly north of there servicing the houses in the nearby neighborhood? Contractor could land a meter on that pole and have BPU set up a service for it.
KCKPS	If it would be possible to have BPU set a meter on the existing power pole just to north of the target sign location, the District would consider that as a possible alternative source. Bidders should provide that option as an alternative bid (addition or deduct amount from base bid).
3	Where can contractor hook up to power for the new sign?
KCKPS	The planned location of the power source is at the north end of the maintenance shop at 2220 N. 59 th St.

2. No Other Changes: No other changes or modification are intended by this Addendum. All other terms and conditions of the solicitation remain in effect.

WE HEREBY ACKNOWLEDGE AND UNDERSTAND THE ABOVE NOTED CHANGES TO THE ORIGINAL BID DOCUMENT AND AGREE TO FURNISH THE ITEMS ON WHICH PRICES ARE QUOTED IN ACCORDANCE WITH ALL TERMS AND CONDITIONS PREVIOUSLY LISTED AND ANY ATTACHED SPECIFICATIONS AND AMENDMENTS.

BY: _____ DATE: _____
TITLE: _____ PHONE: _____
FIRM _____