



**CITY OF CALLAWAY  
PAVING IMPROVEMENTS  
BID NO: PW2022-12**

**ADDENDUM #3**

Date Issued: July 11, 2022

This addendum is being released to clarify the following:

Enzor Street

1. The Turnouts at intersections like Highline drive, Gay Avenue, and Georgia Avenue, do they get milled?

**A. Enzor St., including intersections shall be full depth reclamation as noted in the typical cross section. Driveways are either newly constructed or are overlaid per the typical sections.**

Janice L. Peters  
Janice L. Peters, City Clerk

\*\*\*\*\*

This Addendum must be acknowledged and included with the bid packet submission.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date