



**CITY OF CALLAWAY  
PAVING IMPROVEMENTS  
BID NO: PW2022-12**

**ADDENDUM #5**

Date Issued: July 19, 2022

This addendum is being released to clarify the following questions:

**Enzore**

- 1. Addendum 3 states that the intersections shall be full depth reclamation as noted in the typical section, does this mean the whole Enzor Street get Reclaimed?**

**A. Yes**

- If it does, then on page 2 of 7 Item B. 4) is 2" Milling of existing asphalt and haul to City yard within City Limits? **There will be no millings.**
- There would be no Millings to be hauled if you are reclaiming. **Correct**
- If you are doing reclaim you are going to need to bring in base material to bring the road back to grade and Earthwork and Grading. **Incorrect, no other base is needed.**

- 2. The typical detail is showing that the main road is getting milled 2" and overlaid 2". The note under the detail says full depth reclamation unless noted otherwise. I don't see anywhere in the plans call for a full depth reclamation.**

**A. See No. 1 above.**

**Loop Rd**

- 3. The bid tab does not show the new C inlets and ADS storm pipe. Are they not included?**

**A. The bid form has been revised to add stormwater pipe and inlets. See attached.**

- 4. Section B, line item 1 says full depth reclaim per design, but the typical roadway section for loop road shows 1.5" asphalt with 6" base. The existing plan does not show any existing asphalt, other than the small amount of demo.**

**A. The bid form has been revised to require 1.5" of asphalt with 6" of base.**

- 5. Section B, line item 2 calls for asphalt and base for new driveways, but the plans do not show any new driveways. Please advise.**

**A. There are no driveways. This line item has been removed from the bid section. See attached revised Bid Certification Form.**

6. Section B, line item 3 calls for 1.5" overlay of existing driveways, but there are not any existing driveways. Please advise.

**A. Same as No. 5 above.**

7. Section B, line items 9 and 10 call for manhole adjustment and valve adjustment with concrete pads, but they are not shown on the plans. Please advise.

**A. This line item has been removed. See attached revised Bid Certification Form.**

### Imperial Drive

8. Section F, line item 1 says full depth reclaim per design, but the typical roadway section for Imperial Drive shows 1.5" asphalt with 6" base. The existing plan does not show any existing asphalt, only gravel where the new road is going. Please advise.

**A. This line item in the bid has been revised to require 1.5" of asphalt and 6" of base.**

9. Section F, line item 2 calls for asphalt and base for new driveways, but the plans do not show any new driveways. Please advise.

**A. There are driveway turn outs for this road and the cost should be included in the bid.**

10. Section F, line item 5 is show select import fill. Our takeoff report is show this as an export.

**A. Our calculations show that import fill is required. If you think there is not import, then price the project as you see fit and include the cost for export.**


11. On page E11 in the typical section it calls out 12.5 SP Surface Course but the Bid Items call SP 9.5 Asphalt Paving.

**A. Use SP 9.5 for asphalt.**

12. On page E11 it calls for Zoysia Sod and the other two projects call for Bermuda Sod. See pages I2 and L2. Is this Correct?

**A. Use Zoysia for all sod.**

13. In the detail below, the note says to overlay, crack seal, full depth patch and level can you show on the plans which location needs which activity before overlaying occurs?



**A. All existing asphalt driveways shall have simple 1.5” of asphalt overlay and all new proposed asphalt driveways shall have 6” of base and 1.5” of asphalt. There is no full depth reclamation or crack seal of any driveways**

14. See attached **revised Bid Certification Form.**

Janice L. Peters  
Janice L. Peters, City Clerk

\*\*\*\*\*

This Addendum must be acknowledged and included with the bid packet submission.

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Date

**AMENDED\* BID/RFP CERTIFICATION FORM**

**CITY OF CALLAWAY  
PAVING IMPROVEMENTS  
BID NO: PW2022-12**

\*Deletions stricken in **Red**;  
Additions Underlined in **Blue**

PROPOSERS CERTIFICATION TO THE CITY OF CALLAWAY:

1. The undersigned warrants that: (A) This Proposal is submitted in response to, and is in compliance with, all terms and conditions applicable thereto as set forth in the Advertisement, Instructions to Proposers, General Instructions and Conditions, Special Instructions and Conditions, Bid/RFP Certification Forms, the Minimum Technical Specifications, Addendum, Exhibits, Agreement, Bonds, and Insurance Requirements, each of which has been carefully examined, (B) Proposer or Proposer’s representative has made such investigation as is necessary to determine the character and extent of the work and their capability to perform the work, and (C) agrees that if the Proposal is accepted by the City, Proposer will provide the necessary labor, materials, machinery, equipment, tools or apparatus, and perform all the work or services required to complete the assignment and/or contract within the time specified according to the requirements of the City as herein and hereinafter set forth, and (D) he/she is authorized to legally execute binding contracts for and on behalf of the Proposer.

2. Please check one:

- Proposer declares that the only person, persons, company, or parties interested in this Proposal are named in the Proposal.
- Proposer, or one or more of Proposer’s officers, principals, or any owner of more than 5% in or of proposer, or members of their immediate families: (A) have a financial interest in another company, project, or property that could benefit financially from this proposed project; and/or (B) another individual or business will be compensated by (or on behalf of proposer) if Proposer is selected by the City for the requested services. (Attach a detailed explanation for either.)

3. Bid Bond - If the Proposal is accepted by the City, it will become a binding contract on both parties. If a Bid Bond or Cashier’s Check/Certified Check is required, it shall be submitted with the Proposal. If the undersigned shall fail to deliver or perform, or if applicable, execute a Contract as stated herein, then the City may, at its option, determine that the undersigned has abandoned the Award/Contract, and thereupon such Bid and/or Award shall be null and void, and any Cashier’s Check/Certified Check or Bond accompanying this Bid shall be forfeited to and become the property of the City, and the full amount of said check, or if a Bid Bond, the full amount of such bond, shall be paid to the City as partial liquidated damages; otherwise, any Bond or Cashier’s Check/Certified Check accompanying this Bid shall be returned to the undersigned within 30 calendar days from the date of Award, or if provisions for a Notice to Proceed are included, from the date of the Notice to Proceed.

4. Vendor proposes and agrees to provide all materials, services or equipment required for the City of Callaway **PAVING IMPROVEMENTS BID NO: PW2022-12**, for the Total Sum(s) as follows: (Totals must match breakdown of costs for each part on next page.) Dollar Amount (\$ \_\_\_\_\_)  
Written Amount: \_\_\_\_\_

5. Number of days from date of the Notice to Proceed that will be required for the final completion of all work as described herein. \_\_\_\_\_

**(Maximum 90 Calendar Days)**

6. The City reserves the right to accept any or all prices itemized in any combination that best serves the interests of the City. The City further reserves the right to accept or reject any of the components of this Proposal, including alternates.

**BID SCHEDULE**

NOTE: BIDS shall include sales tax and all other applicable taxes and fees.

**JOB #1 ENZOR STREET**

<u>ITEM</u>	<u>DESCRIPTION</u>	<u>UNIT</u>	<u>QTY</u>	<u>EXTENSION</u>
<b>A.</b>	<b>GENERAL ITEMS</b>			
1)	Mobilization/Demobilization	LS	1	\$ _____
2)	Bonds and Insurance	LS	1	\$ _____
3)	Traffic Control (MOT) per FDOT Standards	LS	1	\$ _____
4)	Erosion Control/INPDES Permitting (Includes Silt Fence and Hay Bales)	LS	1	\$ _____
5)	Stakeout and Asbuilts by Registered Florida Surveyor	LS	1	\$ _____
6)	Testing	LS	1	\$ _____
7)	Erosion Control	LS	1	\$ _____
8)	Demolition	LS	1	\$ _____
9)	Allowance for changes/additions by the City and Engineer	LS	1	\$ <u>20,000</u>
	<b>SUBTOTAL A</b>			\$ _____
<b>B.</b>	<b>BID ITEMS</b>			
1)	2" SP 9.5 Asphalt Paving	LS	1	\$ _____
2)	1 1/2" SP 9.5 Asphalt Paving with 6" Limerock Base for new driveways	LS	1	\$ _____
3)	1 1/2" SP 9.5 Asphalt Paving overlay of existing driveways	LS	1	\$ _____
<del>4)</del>	<del>2" Milling of existing asphalt and haul to City yard within City Limits</del>	<del>LS</del>	<del>1</del>	<del>\$ _____</del>
<del>5</del> 4)	Striping - Thermoplastic	LS	1	\$ _____
<del>6</del> 5)	Permanent Signage	LS	1	\$ _____
<del>7</del> 6)	Sod	LS	1	\$ _____
<del>8</del> 7)	Manhole Adjustments/Concrete Collars/Pads	LS	1	\$ _____
<del>9</del> 8)	Water Valve Box Adjustments/Concrete Pads	LS	1	\$ _____
	<b>SUBTOTAL B</b>			\$ _____
	<b>ENZOR STREET TOTAL LUMP SUM A &amp; B</b>			\$ _____

**JOB #2 LOOP ROAD**

<u>ITEM</u>	<u>DESCRIPTION</u>	<u>UNIT</u>	<u>QTY</u>	<u>EXTENSION</u>
<b>C</b>	<b>GENERAL ITEMS</b>			
1)	Mobilization/Demobilization	LS	1	\$ _____
2)	Bonds and Insurance	LS	1	\$ _____
3)	Traffic Control (MOT) per FDOT Standards	LS	1	\$ _____
4)	Erosion Control/INPDES Permitting (Includes Silt Fence and Hay Bales)	LS	1	\$ _____
5)	Stakeout and As-builts by Registered Florida Surveyor	LS	1	\$ _____
6)	Testing	LS	1	\$ _____
7)	Erosion Control	LS	1	\$ _____
8)	Demolition	LS	1	\$ _____
9)	Allowance for changes/additions by the City and Engineer	LS	1	\$ <u>30,000</u>
<b>SUBTOTAL C</b>				<b>\$ _____</b>

<b>D</b>	<b>BID ITEMS</b>			
1)	<del>2</del> <u>1 1/2</u> " SP 9.5 Asphalt Paving <u>with 6"</u> <del>and</del> Limerock Base <del>mix as specified with Full Depth Reclamation per design plans</del>	LS	1	\$ _____
<del>2)</del>	<del>1 1/2</del> " SP 9.5 Asphalt Paving with 6" Limerock Base for <del>new driveways</del>	<del>LS</del>	<del>1</del>	<del>\$ _____</del>
<del>3)</del>	<del>1 1/2</del> " SP 9.5 Asphalt Paving overlay of existing driveways	<del>LS</del>	<del>1</del>	<del>\$ _____</del>
<del>4</del> <u>2</u> )	Earthwork/Grading	LS	1	\$ _____
<del>5</del> <u>3</u> )	Striping - Thermoplastic	LS	1	\$ _____
<del>6</del> <u>4</u> )	Signage	LS	1	\$ _____
<del>7</del> <u>5</u> )	Sod	LS	1	\$ _____
<del>8</del> <u>6</u> )	Seed/Mulch	LS	1	\$ _____
<del>9)</del>	<del>Manhole Adjustments/Concrete Collars/Pads</del>	<del>LS</del>	<del>1</del>	<del>\$ _____</del>
<del>10)</del>	<del>Water Valve Box Adjustments/Concrete Pads</del>	<del>LS</del>	<del>1</del>	<del>\$ _____</del>
<u>7</u>	<u>Stormwater Pipe and Inlets</u>	<u>LS</u>	<u>1</u>	<u>\$ _____</u>
<b>SUBTOTAL D</b>				<b>\$ _____</b>

**LOOP ROAD TOTAL LUMP SUM C & D** \$ \_\_\_\_\_

**JOB #3 IMPERIAL DRIVE**

<u>ITEM</u>	<u>DESCRIPTION</u>	<u>UNIT</u>	<u>QTY</u>	<u>EXTENSION</u>
<b>E</b>	<b>GENERAL ITEMS</b>			
1)	Mobilization/Demobilization	LS	1	\$ _____
2)	Bonds and Insurance	LS	1	\$ _____
3)	Traffic Control (MOT) per FDOT Standards	LS	1	\$ _____
4)	Erosion Control/INPDES Permitting (Includes Silt Fence and Hay Bales)	LS	1	\$ _____
5)	Stakeout and Asbuilts by Registered Florida Surveyor	LS	1	\$ _____
6)	Testing	LS	1	\$ _____
7)	Erosion Control	LS	1	\$ _____
8)	Demolition	LS	1	\$ _____
9)	Allowance for changes/additions by the City and Engineer	LS	1	\$40,000 _____
<b>SUBTOTAL E</b>				<b>\$ _____</b>
<b>F.</b>	<b>BID ITEMS</b>			
1)	<del>2 1 1/2</del> " SP 9.5 Asphalt Paving and <u>6</u> " Limerock Base <del>mix as specified with Full Depth Reclamation per design plans</del>	LS	1	\$ _____
2)	1 1/2" SP 9.5 Asphalt Paving with 6" Limerock Base for new driveways	LS	1	\$ _____
3)	1 1/2" SP 9.5 Asphalt Paving overlay of existing driveways	LS	1	\$ _____
4)	Earthwork/Grading	LS	1	\$ _____
5)	Import Select Fill	<u>LS</u>	<u>1</u>	\$ _____
6)	Striping - Thermoplastic	LS	1	\$ _____
7)	Signage	LS	1	\$ _____
8)	Sod	LS	1	\$ _____
9)	Seed/Mulch	LS	1	\$ _____
10)	Manhole Adjustments/Concrete Collars/Pads	LS	1	\$ _____
11)	Water Valve Box Adjustments/Concrete Pads	LS	1	\$ _____
12)	1" Water Service Assembly	LS	1	\$ _____
13)	6" PVC Water Main	LS	1	\$ _____
14)	6" DI MJ 22.5° Bends	LS	1	\$ _____

15)	6'' SS Tapping Sleeve and Valve	LS	1	\$ _____
16)	Fire Hydrant Assemblies	LS	1	\$ _____
17)	6'' MJ Gate Valves	LS	1	\$ _____
18)	6'' MJ Tees	LS	1	\$ _____
19)	Gravity Sewer Service Laterals	LS	1	\$ _____
20)	8'' Gravity Pipe (4' to 6' Deep)	LS	1	\$ _____
21)	Existing Gravity Manhole Connection	LS	1	\$ _____
22)	Manhole 4'-6' with HDPE Liner	LS	1	\$ _____
23)	Line Existing Manholes with Triplex or Spectra Shield Liner System	LS	1	\$ _____

**SUBTOTAL F** \$ \_\_\_\_\_

**IMPERIAL DRIVE TOTAL LUMP SUM E & F** \$ \_\_\_\_\_

**SUBTOTAL OF LUMP SUM BIDS**

**JOB #1 - ENZOR STREET**    A + B    \$ \_\_\_\_\_

**JOB #2 - LOOP ROAD**        C + D    \$ \_\_\_\_\_

**JOB #3 - IMPERIAL DRIVE**   E + F    \$ \_\_\_\_\_

**TOTAL BID AMOUNT**         \$ \_\_\_\_\_

\_\_\_\_\_ **DOLLARS & \_\_\_\_\_ CENTS.**

**TOTAL BID Written amount**

The pay item quantities shown on sheet D5 of the plan sheets are provided for reference only and are estimates. If quantities conflict with bidders takeoff, bidder shall include the costs to cover the conflict in the lump sum bid above.

Jobs are to be done in numbered order.



**FEES FOR ADDITIVE WORK:  
(If Applicable)**

The undersigned agrees that he will, when so instructed by the Engineer, perform additional work (for which the Unit Prices stated above are not applicable) at the following rates:

1. For extra work performed by your Subcontractors, the net amount of the Subcontractor's charge plus a percentage fee of 10%, which fee shall include all charges for supervision, overhead and profit, bonds, taxes and insurance.
2. For work performed by the Contractor's own forces, a reasonable estimate of the net cost of the work (less all discounts) plus a fee of 18% which fee shall include all charges for supervision, field office, general expenses, overhead and profit. Net cost, to which the percentage fee shall be applied, is understood to include state sales taxes, bonds, and delivery expenses of materials: cost of labor is to include all union fringe benefits, applicable insurance and payroll taxes.

**Provide the subcontractor(s) or vendor(s) information requested below.** Failure to submit this information shall result in a bid rejection and non-compliance with the bid requirements. If any category will be self-performed, please indicate.

All changes after bid award must be approved by the City.

Respectfully submitted:

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Company

\_\_\_\_\_  
Title

\_\_\_\_\_  
Address

\_\_\_\_\_  
License Number

\_\_\_\_\_  
Date

7. BIDDER HEREBY ACKNOWLEDGES RECEIPT OF THE FOLLOWING ADDENDUMS: \_\_\_\_\_

Name of Bidder: \_\_\_\_\_

Business structure: ( ) Corporation, ( ) Partnership, ( ) Individual, ( ) Other:  
\_\_\_\_\_

If a Partnership: \_\_\_\_\_

Name(s) of Partner(s): \_\_\_\_\_

If a Corporation: \_\_\_\_\_

Incorporated in State of: \_\_\_\_\_ Date of Incorporation: \_\_\_\_\_

Business Address: \_\_\_\_\_

City: \_\_\_\_\_ State \_\_\_\_\_ Zip \_\_\_\_\_

Telephone Number: ( ) \_\_\_\_\_ Fax ( ) \_\_\_\_\_

E-mail Address: \_\_\_\_\_

Submitted By: \_\_\_\_\_  
(Print)

Affix Corporate Seal  
(If Corporation)

Title: \_\_\_\_\_

Signature: \_\_\_\_\_

ATTEST: \_\_\_\_\_  
Secretary

By: \_\_\_\_\_  
Print Name

State of Florida  
before  
County of \_\_\_\_\_

The foregoing instrument was acknowledged  
me by means of  Physical Presence or  
 Online Notarization

The foregoing instrument was acknowledged before me this \_\_\_\_\_ day of \_\_\_\_\_, 20\_\_\_\_, by  
\_\_\_\_\_, who is personally known to me or who presented \_\_\_\_\_ as  
identification, and who (did) (did not) take an oath.

\_\_\_\_\_  
[Signature of Notary Public]

[Printed, typed or stamped name of Notary Public]

**NOTE: BIDS MAY BE REJECTED IF ALL DOCUMENTS ARE NOT COMPLETE AND EXECUTED, AND THE NUMBER OF COPIES SPECIFIED/REQUESTED OF EACH ARE NOT SUBMITTED WITH THE BID.**