



ADDENDUM NO. 2

Issue Date: January 31, 2024

Project Name: New Restroom Facility at Fran B. Adams North County Regional Park

Bid Number: 2024031

Bid Opening Date: **February 7, 2024**

This addendum is being released to provide answers to questions received to date. The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the Bid form, or the bid may be declared non-responsive.**

Questions and Answers

1.	I didn't see any specs on the materials for the plumbing pipes for the new building. Is CPVC an approved material?
	CPVC or Copper is acceptable as approved plumbing materials.
2.	I didn't see any specs on the materials for the bathroom toilet partitions. Is Solid Plastic an approved material?
	Toilet partitions to be solid plastic Santana or equal in color to be selected by County.