

## BACKFLOW DEVICE TEST REPORT

Service Address 211 W. Tyler St Dalton, GA, 30720

Name of Premises SSC Location of device water pit by road

Device Wilkins 950XLTZ 3/4" 4356040  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 1:35pm Certified Tester # B Pat - 03521

Test by (Signature) *Mr. Han* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 211 W. Tyler St. Dalton, GA 30720  
 Name of Premises SSC Location of device warehouse  
 Device Wilkins 950XLTZ 2" 3549555  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCD A   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 1:40 pm Certified Tester # BPA-03821  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel Hill Varrell Rd. Tunnel Hill GA 30755

Name of Premises NW Whitfield High Location of device Riser room (CFB field)

Device Wilkins 975XL 2" W034188  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>3.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>8.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 9:30 am Certified Tester # Bpat-03521  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel Hill varnell Rd Tunnel Hill GA 30755

Name of Premises NW Whittied high Location of device irragation CFB field

Device Wilkins 975 XL 2" 1356240  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08116118  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>3.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>9.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 11:00 Am Certified Tester # Bpat-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel Hill Vernell Rd. Tunnel Hill GA 30755

Name of Premises NW Whitfield High Location of device Fiser in Weight Rm.

Device Ames 2000B 3/4" 31090  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 8:10am Certified Tester # Bpat-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel Hill Varnell Rd. Tunnel Hill GA 30755

Name of Premises NW Whitfield High Location of device FIRST IN WEIGHT RM.

Device Ames 300SS 4" 126556  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>6.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 8:20am Certified Tester # Bpat-03521  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel Hill Varnell Rd. Tunnel Hill GA 30755

Name of Premises NW high school Location of device CONCESSIONS

Device Wilkins 950XL 2" 3685322  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>3.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 9:40am Certified Tester # BPat-03521  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address V51 Tunnel Hill Vernell Rd. Tunnel Hill GA 30755

Name of Premises NW High Location of device green house

Device Wilkins 950XL 3/4" W096589  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 10:00 AM Certified Tester # Bpat-03521  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



## BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel Hill Varnell Rd. Tunnel Hill GA 30755

Name of Premises NW Whitefield High Location of device green house

Device Wilkins 975XL 19 2292099  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>2.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>9.4</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>2.9</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/18 Time 10:20 Am Certified Tester # Brad-03521  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnelhill varnell Rd Tunnel Hill GA 30755

Name of Premises NW Whittfield high Location of device FS P.+

Device Watts 007M1 3/4" unreadable  
Manufacturer Model Size Serial Number

Test Kit Wilkins 0451821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 9:10 Am Certified Tester # Bpat-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel hill varnell Rd. Tunnel hill Ga 30755

Name of Premises NW Whitfield High Location of device Stage (left)

Device Wilkins 950 XL 2" 1197618  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>2.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 7:40 am Certified Tester # BPat -03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel hill varnell Rd. Tunnelhill ga 30755

Name of Premises NW Whitfield high Location of device Stage (middle)

Device Wilkins 950XL 2" 1197610  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 7:30 am Certified Tester # BPAI-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel Hill Varnell Rd. Tunnel Hill GA 30755

Name of Premises MW Whitfield High Location of device Stage (Right)

Device Wilkins 950 XL 2" 870747  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>3.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 7:20 am Certified Tester # BPAT-0354

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel Hill Varnell Rd. Tunnel Hill GA 30755

Name of Premises NW Whitfield High Location of device Rm. S6 103

Device Wilkins 975XL 2" W034181  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08116/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>3.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>8.4</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>2.6</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 7:50 am Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1651 Tunnel Hill Varneck Rd. Tunnel Hill GA 30755

Name of Premises NW Whitfield High Location of device green house (land scaping box)

Device Wilkins 950XLT 1" 252211  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>3.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 10:30 Am Certified Tester # BPAT-03501

Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1306 S. Thornton Ave. Dalton GA 30720

Name of Premises Central office Location of device basement

Device Wilkins 950XLT 1 1/4" 1533336  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 2:20 PM Certified Tester # BPAT-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



## BACKFLOW DEVICE TEST REPORT

Service Address 1306 S. Thornton Ave. Dalton GA 30720

Name of Premises Central office Location of device basement

Device Wilkins 950 KLT 1 1/4" 1533987  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04651821 08116/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 2:40 pm Certified Tester # BPat - 03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 1111 New Hope Rd. Dalton, GA 30721  
 Name of Premises New Hope Middle Location of device Pit  
 Device Wilkins 950KT 2" 1643891  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>30</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 7:20 AM Certified Tester # BPA-03521  
 Test by (Signature) Bradley Thomas Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 1111 New hope Rd. Dalton, GA 30721

Name of Premises New Hop middle Location of device Pit

Device Wilkins 950XLT 2" 1643855  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 7:30 Am Certified Tester # BRat-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 1111 New Hope Road, Dalton GA 30721

Name of Premises New hope middle Location of device irrigation bldg by baseball field

Device Ames 4000b 2" 15065  
Manufacturer Model Size Serial Number

Test Kit Wilkins 0415821 08116118  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>2.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>9.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.0</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 7:40 AM Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 203 School St. Tunnel Hill, GA 30755

Name of Premises Tunnel Hill elem Location of device FSP:d

Device Ames 3000SS 6" unreadable  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08116118  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>	Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>
Did not open <input type="checkbox"/>				

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>4.2</u> psid Leaked <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>2.0</u> psid Leaked <input type="checkbox"/>	Passed <input checked="" type="checkbox"/> Failed <input type="checkbox"/>

Date 6/12/19 Time 8:20 AM Certified Tester # BPat-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 203 School St. Tunnel Hill, GA 30755

Name of Premises Tunnel Hill elem

Location of device Domestic water box

Device Wilkins  
Manufacturer

350XL  
Model

2"  
Size

A312994  
Serial Number

Test Kit Wilkins  
Manufacturer

04151821  
Serial Number

08/16/18  
Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/17/19 Time 8:40 Am Certified Tester # BPAT-03521  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 203 School St Tunnel Hill, GA 30755

Name of Premises Tunnel Hill elem. Location of device FS Pit

Device watts 007M1 3/4" unreadable  
Manufacturer Model Size Serial Number

Test Kit wilkins 0151821 08116118  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 8:30 Am Certified Tester # BPat -03521  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 285 Cedar ridge S E Rd Dalton GA 30721

Name of Premises Cedar ridge elem Location of device FSPit

Device Apollo 456600 6" 01705  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08116118  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.8</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>2.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 10:50 Am Certified Tester # BPAT-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



## BACKFLOW DEVICE TEST REPORT

Service Address 285 Cedar ridge Rd SE Dalton GA 30721

Name of Premises Cedar ridge elem Location of device mech. rm.

Device Watts 919AT 1 1/2" 06641  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>1.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>8.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.6</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 10:00Am Certified Tester # BPgt-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 285 Cedar Ridge SE RD Dalton GA 30721

Name of Premises Cedar Ridge elem. Location of device Mech. Rm.

Device Wilkins 375 3" L49259  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04156821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>2.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>7.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 10:10 Am Certified Tester # Bpat-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 285 Cedar Ridge SE Dalton GA 30721

Name of Premises Cedar ridge elem Location of device mech. rm.

Device Wilkins 375 3" L350800  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>2.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>8.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 10:20 Am Certified Tester # Bpat-03521

Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 285 Cedar ridge SE Dalton GA 30721  
 Name of Premises Cedar ridge elem Location of device Water Pit  
 Device conbraco Double check 4" MDR65  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 10:30am Certified Tester # BPat-07521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 3361 Crow Rd. NE Dalton, GA 30721  
 Name of Premises Coahulla creek high Location of device Pit by baseball field  
 Device Febco 856 8" NO901190225  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 06/12/19 Time 1:10 pm Certified Tester # BRat-03521  
 Test by (Signature) Ben Hain Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 3361 Crow Rd. NE Dalton, GA 30721

Name of Premises COA holly creek high Location of device mech. Room

Device Wilkins 007M1QT 1" 401557  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 1:50 pm Certified Tester # Bpat-03521

Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 3361 Crow Rd NE Dalton GA 30721

Name of Premises Coahalla creek high Location of device Mech. Rm.

Device Wilkins 975XL 1" 3274674  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>2.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>8.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 2:00 PM Certified Tester # BPAT-03521  
 Test by (Signature) Bradley Thomas Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 9196 GA-2 Dalton, GA 30721  
 Name of Premises Beavordale elem. Location of device Mech. Rm.  
 Device Wilkins 975XL 1 1/2" 1932386  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>3.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>8.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 2:30 PM Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



## BACKFLOW DEVICE TEST REPORT

Service Address 9196 GA-2 Dalton, GA 30721

Name of Premises Beaverdale elem Location of device FS Pit

Device Ames 3000SE 8" 10300/0104  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>		Leaked <input type="checkbox"/>		Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>1.8</u> psid Leaked <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>2.8</u> psid Leaked <input type="checkbox"/>	Passed <input checked="" type="checkbox"/> Failed <input type="checkbox"/>

Date 6/12/19 Time 2:50 PM Certified Tester # BPat-03521

Test by (Signature) *Mr Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 9196 GA-2 Dalton GA 30721  
 Name of Premises Beaverdale elem. Location of device FS Pit  
 Device Watts 007M1 3/4" 59229  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCD A   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 3:00 PM Certified Tester # Bpat-03521  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 1175 New Hope Rd Dalton GA 30720

Name of Premises New hope elem Location of device Mech Rm.

Device Wilkins 975XL 3/4" 947471  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 02/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>2.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>9.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 1:10 PM Certified Tester # BPA-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 1175 New Hope Rd. Dalton GA 30728  
 Name of Premises New Hope elem Location of device Rm. 403 (Right)  
 Device Wilkins 950 XLT 2" 1522978  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 0415421 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>2.4</u> psid	Passed <input checked="" type="checkbox"/> Failed <input type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	

Date 6/11/19 Time 1:20 PM Certified Tester # BRAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1175 New Hope Rd, Dalton GA 30720  
 Name of Premises New Hope elem. Location of device Rm. 403 (Left)  
 Device Wilkins 950 XLT 2" 1522980  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 1:30 PM Certified Tester # Bpat-03521  
 Test by (Signature) Bradley Thomas Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 1175 New Hope Rd. Dalton GA 30720

Name of Premises New hope elem. Location of device FS Pit

Device Ames 3000SS 6" Unscalable  
Manufacturer Model Size Serial Number

Test Kit Willkins 04151821 08116118  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 1:40 PM Certified Tester # BPAT-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**BACKFLOW DEVICE TEST REPORT**

Service Address 1175 New hope Rd Dalton GA 30721

Name of Premises New hope elem Location of device FS Pit

Device Watts 007ml 3/4" unreadable  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08116118  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 6:50 pm Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 2300 Maddox Chapel Rd NW Dalton GA 30740

Name of Premises NWG CCA

Location of device 505 Riser room

Device Wilkins  
Manufacturer

975XL  
Model

2" 548142  
Size Serial Number

Test Kit Wilkins  
Manufacturer

04151821  
Serial Number

08/16/18  
Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>2.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>8.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 8:40 Am Certified Tester # BPak-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



## BACKFLOW DEVICE TEST REPORT

Service Address 2300 Maddox Chapel Rd NW Dalton GA 30740

Name of Premises NWGCCA Location of device FS Pit

Device Wilkin 350 DA 8" M1504  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

### Reduced Pressure Principle Assembly

Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

### Double Check Valve Assembly

Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	Backflow Assembly Status
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 8:50 Am Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2300 Maddox Chapel Rd NW Dalton GA 30740  
 Name of Premises NW9 CCA Location of device FS Pit  
 Device Wilkins 350XL 3/4" 1796514  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 9:00AM Certified Tester # BPAT-03521  
 Test by (Signature) Bradley Thomas Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 2300 Maddox Chapel Rd NW Dalton GA 30740  
 Name of Premises NWGCCA Location of device water Pit  
 Device Wilkins 350 4" 516368  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08116118  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 9:10 Am Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2300 Maddox Chapel Rd NW Dalton GA 30740

Name of Premises NWGCCA

Location of device 505 Riser Room

Device Wilkins

975K

2"

1263978

Test Kit Wilkins

04151821

08/16/18

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>3.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>9.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/14 Time 8:30 AM Certified Tester # BP-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 254 Wolfe St Dalton GA 30721

Name of Premises Chatta elem Location of device landscaping box

Device Wilkins 950 XL 2" W02708  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04121821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 3:00 pm Certified Tester # BPAT-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 254 Wolfe St Dalton GA 30721

Name of Premises Cohutta elem. Location of device FS Pit

Device Watts 007m1 3/4" 56463  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 3:10 pm Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 254 Wolfe St Dalton GA 30721

Name of Premises Cohutta elem. Location of device FS Pit

Device Ames 3000SS 6" 124127  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDÁ   
 RPDA

#### Reduced Pressure Principle Assembly

Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

#### Double Check Valve Assembly

Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	Backflow Assembly Status
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 3:20 PM Certified Tester # BPat-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1815 Utility Rd. Rocky Face, GA 30740

Name of Premises Westside elem. Location of device boiler rm.

Device Wilkins 950KLT 3/4 353600  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 10:40 AM Certified Tester # BPA-03521

Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



## BACKFLOW DEVICE TEST REPORT

Service Address 1815 Utility Rd. Rocky Face, GA 30740

Name of Premises West side elem.

Location of device Pit by Playground

Device Wilkins  
Manufacturer

950XL1  
Model

2" 1759407  
Size Serial Number

Test Kit Wilkins  
Manufacturer

04151821  
Serial Number

08/16/18  
Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 9:50 AM Certified Tester # BPAT-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1815 Utility Rd. Rocky Face, GA 30740  
 Name of Premises Westside elem. Location of device Pit by Playground  
 Device Wilkins 950XLI 2" 2047529  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04154821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>2.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 10:00 AM Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2900 Airport Rd. Dalton GA 30721  
 Name of Premises East side elem Location of device Water P.t  
 Device Wilkins 350 3" 546419  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04651821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>2.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 7:00 AM Certified Tester # Bpat-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2900 Airport Rd Dalton GA 30721  
 Name of Premises Eastside chem. Location of device FS Pit  
 Device Wilkins 350DA 6" N47027  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.4</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 7:10 Am Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2900 Airport Rd Dalton GA 30721  
 Name of Premises Eastside elem Location of device FS Pit  
 Device Wilkins 950XLD 3/4" 4100260  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 7:20 Certified Tester # BPAT-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2900 Airport Rd, Dalton GA 30721

Name of Premises East side elem. Location of device Mech. Rm.

Device Wilkins 950 KLT 2" 1636331  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 7:30 Certified Tester # BPat-03521  
 Test by (Signature) Bradley Thomas Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2900 Air Port Rd. Dalton, GA 30721

Name of Premises East side elem. Location of device Mech. Rm.

Device Wilkins 950RLT 2" 1617521  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 7:50 AM Certified Tester # B Pat-03521

Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2032 Dug gap Rd. Dalton, GA 30720  
 Name of Premises Dug gap chem. Location of device soccer field  
 Device Wilkins 975XL 1 1/2" 3877010  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>3.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>8.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 12:00 pm Certified Tester # BPat-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



## BACKFLOW DEVICE TEST REPORT

Service Address 2032 Dug gap Rd. Dalton, GA 30720  
 Name of Premises Dug gap elem. Location of device water pit  
 Device Wilkins 950XLT 2" 1643872  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08116118  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 12:16pm Certified Tester # BPAT-03521

Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2032 Dug gap Rd. Dalton Ga 30720  
 Name of Premises Dug gap elem. Location of device water pit  
 Device Wilkins 950XLT 2" 1643888  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 12:20pm Certified Tester # BPat-03521

Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1380 Dawnville RD NE Dalton, GA 30721  
 Name of Premises Dawnville chem. Location of device Mech. Rm.  
 Device Wilkins 975 3" B35818  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>1.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>8.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.8</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 3:30 PM Certified Tester # Bpat-03521  
 Test by (Signature) Bradley Thomas Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1380 Dawnville Rd. NE Dalton GA 30721

Name of Premises Dawnville elem. Location of device Kitchen

Device Wilkins 950 XL 3/4" W060587  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>		Leaked <input type="checkbox"/>		Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>2.4</u> psid Leaked <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>2.6</u> psid Leaked <input type="checkbox"/>	Passed <input checked="" type="checkbox"/> Failed <input type="checkbox"/>

Date 6/12/18 Time 4:00 PM Certified Tester # BPAT-03521

Test by (Signature) *Jim Now* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1380 Dawnville Rd NE Dalton GA 30721

Name of Premises Dawnville elem. Location of device Water box by road

Device Wilkins unreadable 1" A563791  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Closed Tight	Held at <u>1.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 4:20 pm Certified Tester # BPAT-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 1380 Dawnville Rd NE Dalton GA 30721

Name of Premises Dawnville elem. Location of device FS Pit

Device Watts 007M1 3/4" 48459  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 5:00 PM Certified Tester # 13Pat-03521

Test by (Signature) [Signature] Print Name Kevin Glen Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 3798 S. Dixie Rd. Dalton GA 30721

Name of Premises Valley Point elem. Location of device Riser room

Device Wilkins 975XL 3/4" 292859  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>3.2</u> psid Did not open <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>8.6</u> psid Leaked <input type="checkbox"/>	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>2.4</u> psid Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>	Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>	Passed <input checked="" type="checkbox"/> Failed <input type="checkbox"/>

Date 6/13/19 Time 9:10 Certified Tester # BPost-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 3798 S. Dixie Rd Dalton GA 30720  
 Name of Premises Valley Point elem Location of device water box by food  
 Device Wilkins 950 KLT 2" 3402099  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCD   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 06/13/19 Time 8:50 Am Certified Tester # BPat - 03521

Test by (Signature) [Signature] Print Name Bralley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_



## BACKFLOW DEVICE TEST REPORT

Service Address 3798 S. Dixie Rd. Dalton GA 30720  
 Name of Premises Valley Point dem. Location of device Ti Ser room  
 Device Ames 200SS 4" 107249  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.4</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 9:00 AM Certified Tester # BPAst-03521  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 4421 GA-2 Dalton GA 30721

Name of Premises Varnell elem Location of device FS Pit

Device Ames coll 300bf 6" IF1709  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>4.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 12:50pm Certified Tester # Bpat-03521  
 Test by (Signature) Mr Tom Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 4421 GA-2 Dalton GA 30721

Name of Premises Varnell elem. Location of device FS Pit

Device Ames 2000Bm3 3/4" UNreadable  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 1:00pm Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 4421 GA-2 Dalton GA 30721

Name of Premises Varnell elem. Location of device water box

Device Conbraco Holo999T 2" J4976  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.4</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>1.8</u> psid	Passed <input checked="" type="checkbox"/> Failed <input type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	

Date 6/10/19 Time 1:30 PM Certified Tester # Bpat-03521  
 Test by (Signature) Bradley Thomas Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 4421 GA-2 Dalton GA 30721  
 Name of Premises Varnell elem Location of device Kitchen  
 Device Wilkins 950XLT 3/4" 1735583  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.4</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 1:40 PM Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 4421 GA-2 Dalton GA 30721  
 Name of Premises Varnell elem. Location of device Kitchen  
 Device Wilkins 950XLt 3/4" 1918405  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 1:50pm Certified Tester # BPAT-03521  
 Test by (Signature) Brad Thomas Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

### BACKFLOW DEVICE TEST REPORT

Service Address 3796 S. Dixie Rd. Dalton Ga. 30720

Name of Premises Valley Point Mid. Location of device Water box

Device Wilkins 950XL 2" 1198818  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.4</u> psid	Closed Tight	Held at <u>3.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/13/19 Time 9:30 AM Certified Tester # Brad - 03521  
 Test by (Signature) Tom Han Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: Number 2 Shut off on device would not turn. Reccomend replacing shutoff with wilkins 2" ball valve.

### BACKFLOW DEVICE TEST REPORT

Service Address 2725 Cleveland Hwy Dalton GA 30721

Name of Premises Pleasant grove elem Location of device Kitchen

Device Wilkins 950XLT 3/4" 1461855  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

#### Reduced Pressure Principle Assembly

Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

#### Double Check Valve Assembly

Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	Backflow Assembly Status
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 11:20AM Certified Tester # BRAT-03521

Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



## BACKFLOW DEVICE TEST REPORT

Service Address 2725 Cleveland Hwy Dalton GA 30721

Name of Premises Pleasant grove elem Location of device Kitchen

Device Wilkins 950XLT 3/4" 1461824  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/19  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 11:30 AM Certified Tester # BPAT-03521  
 Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2725 Cleveland Hwy Dalton GA 30721

Name of Premises Pleasant grove elem. Location of device mech. rm.

Device Wilkins 950 XLT 2" 1522999  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 11:40 Am Certified Tester # BPA-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2725 Cleveland Hwy Dalton GA 30721  
 Name of Premises Pleasant grove elem Location of device Mech RM.  
 Device Wilkins 950 XLT 2" 1523066  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 11:50 Am Certified Tester # BRat-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2725 Cleveland Hwy Dalton GA 30721

Name of Premises Pleasant grove elem. Location of device FS Pit

Device Watts 007m1 3/4" Unscalable

Test Kit Wilkins 04151821 08/16/18

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.0</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 12:00pm Certified Tester # BPat-03521

Test by (Signature) *Bradley Thomas* Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 2725 Cleveland Hwy Dalton GA 30721  
 Name of Premises Pleasant grove elem Location of device FS Pit  
 Device Ames 3000SS 6" 105146  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP   
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>4.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/10/19 Time 12:10 pm Certified Tester # Bpat-03521  
 Test by (Signature) Bradley Thomas Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 3264 Cleveland Hwy. Dalton GA 30721

Name of Premises M. Whittfield middle Location of device Pit

Device Wilkins 950KLT 2" 1608774  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 10:50 Am Certified Tester # BPAT-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 3264 Cleveland Hwy. Dalton GA 30721

Name of Premises N. Whitfield mid. Location of device Pit

Device Wilkins 950XLT 2" 1608776  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

### Reduced Pressure Principle Assembly

Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

### Double Check Valve Assembly

Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	Backflow Assembly Status
Closed Tight <input checked="" type="checkbox"/>	Held at <u>3.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/12/19 Time 1:00 Am Certified Tester # BPat-03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 580 LaFayette Rd. Rocky Face GA 30740

Name of Premises West Side Middle Location of device FS Pit

Device Watts 007M1 3/4" 60881  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP    
 DC   
 DCDA   
 RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>1.6</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 3:20 PM Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



### BACKFLOW DEVICE TEST REPORT

Service Address 580 LaFayette Rd. Rocky Face GA, 30740  
 Name of Premises West side middle Location of device Pit  
 Device Wilkins 950 XLT 2" 1480734  
Manufacturer Model Size Serial Number  
 Test Kit Wilkins 04181821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.2</u> psid	Closed Tight <input type="checkbox"/>	Held at <u>3.2</u> psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input checked="" type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 3:30 PM Certified Tester # BEAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 580 LaFayette Rd Rocky face GA 30740

Name of Premises West Side Middle Location of device Mech Rm.

Device Wilkins 975XL 2" 1746673  
Manufacturer Model Size Serial Number

Test Kit Wilkins 01151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>2.6</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>8.8</u> psid	Closed Tight <input checked="" type="checkbox"/>	Held at <u>2.8</u> psid
Did not open <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>

Double Check Valve Assembly				Backflow Assembly Status
Check Valve #2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/>	Held at _____ psid	Closed Tight <input type="checkbox"/>	Held at _____ psid	Passed <input checked="" type="checkbox"/>
Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Leaked <input type="checkbox"/>	Failed <input type="checkbox"/>

Date 6/11/19 Time 3:40 pm Certified Tester # B Pat - 03521

Test by (Signature) [Signature] Print Name Bradley Thomas

Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

## BACKFLOW DEVICE TEST REPORT

Service Address 580 LaFayette Rd. Rocky Face GA 30740

Name of Premises West side middle Location of device Mech Rm.

Device Wilkins 975XL 2" 1746674  
Manufacturer Model Size Serial Number

Test Kit Wilkins 04151821 08/16/18  
Manufacturer Serial Number Date Certified

- RP
- DC
- DCDA
- RPDA

Reduced Pressure Principle Assembly				
Relief Valve Opening Point	Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2
Opened at <u>2.6</u> psid	Closed Tight <input checked="" type="checkbox"/> Leaked <input type="checkbox"/>	Held at <u>9.4</u> psid Leaked <input type="checkbox"/>	Closed Tight <input type="checkbox"/> Leaked <input checked="" type="checkbox"/>	Held at <u>2.6</u> psid Leaked <input type="checkbox"/>
Did not open <input type="checkbox"/>				

Double Check Valve Assembly				Backflow Assembly Status
Check Valve # 2 Backpressure Test	Check Valve #1	No. 2 Shutoff Valve	Check Valve #2	
Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>	Closed Tight <input type="checkbox"/> Leaked <input type="checkbox"/>	Held at _____ psid Leaked <input type="checkbox"/>	Passed <input checked="" type="checkbox"/> Failed <input type="checkbox"/>

Date 6/11/19 Time 3:50 PM Certified Tester # BPAT-03521  
 Test by (Signature) [Signature] Print Name Bradley Thomas  
 Your signature certifies that all information provided on this section is correct.

Comments: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_