

CITY OF CALLAWAY JAN DR. & GENEVIEVE AVE. DRAINAGE IMPROVEMENTS BID NO.: CM2023-07

ADDENDUM #1

Date Issued: April 28, 2023

This addendum is being released to address the following questions and extend the deadline for submitting a bid:

- 1. The contractor is only responsible for coordinating with any Utility Owners for any relocates that is in conflict with construction, the City will handle any cost correct? **A. Correct**
- 2. Have all the permits been obtained? A. We have obtained the necessary WMD permits, but still await approved permits from the USACOE.
- 3. The clearing and grubbing notes on the plans state to demo all brush vegetation to existing top of bank, do not destroy roots or trees, but in the clearing and grubbing description for bid item 4, it has all tree and shrub removal, equipment operated stump removal, chainsaw operation, excavation associated with vegetation removal etc. Can we get a clarification if the roots, stumps, and trees stay and just the brush is removed down to the roots?
 - A. Stumps and trees shall remain and only the brush is to be removed down to the roots.
- 4. Is there is a certain diameter of tree that will determine if it will stay or be considered brush?

 A. Trees with a diameter less than three inches shall be considered brush and removed.

NOTE FOR CLARIFICATION: The two projects had separate bid tabs and descriptions. Only the Genevieve project had the description to include stump and root removal because we have specific trees called out for demo in the plans. Task 1 (S Jan Dr.) is only clearing brush down to grade within the ditch just as it states in the notes.

5. The Bid Opening Date is hereby amended as follows:

Current Bid Opening Date: Monday, May 1, 2023

Amended Bid Opening Date: Thursday, May 4, 2023 2:00 PM – City Hall

Janice L. Peters, City Clerk

This Addendum must be acknowledged and included with the bid packet submission.

Signature

Company Name

Date
