



ADDENDUM NO. 1

Issue Date: January 23, 2020

Project Name: North County Deck Lighting

Bid Number: 2020024

Bid Opening Date: February 04, 2020

This addendum is being released to answer questions received to date.

The information and documents contained in this addendum are hereby incorporated in the invitation to bid. **This addendum must be acknowledged where indicated on the bid form, or the bid will be declared non-responsive.**

Questions and Answers

1. What is the voltage for the lights?
Not sure the exact voltage.
2. What is the current wattage of the existing lights?
Wattage is 150 and 300.
3. Do you have an official map with layout and dimensions for us to do the photometries off of?
We don't have an official map, we've used google map in the past.
4. Do they know of any weight limitations for the deck of the pool for moving a lift around?
We have used a county bucket truck and a scissor lift at all the lights in the past without any problems.

- Can they confirm the number of poles is 14 and the number of heads is 24 in total with no others that need to be addressed?
5. **Yes, 14 poles 24 lights.**

We cannot find health code 64E-0.006, do you have a link we can get from you? We have found the codes around this one but not that one.

6. http://www.floridahealth.gov/environmental-health/swimming-pools/documents/64E-9_FAC_Draft_Rev7_no_strike.pdf

Page 12 Section C