

## Spartanburg School District 2 RFB1802 Water Line Replacement ADDENDUM 1

## July 10, 2017

This Addendum #1 is intended to address questions or clarify District requirements on the above referenced project. This addendum should be acknowledged by returning an initialed copy with the offer.

- 1. On the base bid, a new ball valve and concrete valve box at the meter will be included.
- 2. On the alternate bid, Type L Copper should be quoted.

| Amendment |
|-----------|-----------|-----------|-----------|-----------|-----------|-----------|
| No.       |
| 1         | 2         | 3         | 4         | 5         | 6         | 7         |
| Initial   |