



St. Johns River

Water Management District

Ann B. Shortelle, Ph.D., Executive Director

525 Community College Parkway S.E. • Palm Bay, FL 32909 • 321-984-4940
On the internet at www.sjrwmd.com.

DATE: May 3, 2021
TO: Prospective Respondents
FROM: Amy Lucey, Contracts Administrator
SUBJECT: Addendum #1 to Quote Request # 36783, Burrell Lock and Dam Generator Replacement

As a result of inquiries, the following clarifications/changes are provided for your information. Please make all appropriate changes to your quote documents. Note: changes are reflected with original language shown with strike-through and new language is underlined.

Q1: Will the ATS be located outside or is it in an existing building?
A1: The ATS is inside the building just outside of the block wall.

Q2: What is the distance from the ATS the generator?
A2: The ATS is two feet away from the Generator.

Q3: Is a remote annunciator required?
A3: No, a remote annunciator is not required.

NOTE: The Quote Request Due Date **remains** 3:00 p.m., **Thursday, May 27, 2021**

Please acknowledge receipt of this Addendum on the **Quote Cost Schedule** FORM provided in the quote package.

If you have any questions, please e-mail me at alucey@sjrwmd.com.